

Test Performed By: **Rafael Giro, P.E.**
Tester Certification Type: **RESNET RTIN (Energy Rater)**
Tester ID: **1931066**

QA Provided By: **Florida Solar Energy Center**
FSEC Report ID: **598-215-358**

Verify this report or the tester online at: <https://www.enspectorpro.com/verify>

Envelope Leakage Test Report (Blower Door Test)

Residential Prescriptive, Performance or ERI Method Compliance

2017 Florida Building Code, Energy Conservation, 6th Edition

Jurisdiction: **Columbia County, Florida**

Permit #: **000036871**

Job Information

Builder: **Wigglesworth**

Community:

Lot: **N/A**

Address: **962 SW Wilson Springs Rd**

City: **Fort White**

State: **Florida**

Zip: **32038**

Air Leakage Test Results

Passing results must meet either the Performance, Prescriptive, or ERI Method

☐ **PRESCRIPTIVE METHOD**-The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding 7 air changes per hour at a pressure of 0.2 inch w.g. (50 Pascals) in Climate Zones 1 and 2.

☒ **PERFORMANCE or ERI METHOD**-The building or dwelling unit shall be tested and verified as having an air leakage rate not exceeding the selected ACH(50) value, as shown on Form R405-2017 (Performance) or R406-2017 (ERI), section labeled as infiltration, sub-section ACH50.

ACH(50) specified on Form R405-2017 Energy Calc (Performance) or R406-2017 (ERI):

7.00

$$\frac{267.30}{\text{CFM}(50)} \times 60 + \frac{13,968}{\text{Building Volume}} = \frac{1.15}{\text{ACH}(50)}$$



PASS

☒ When ACH(50) is less than 3, Mechanical Ventilation installation must be verified by building department.

Method for calculating building volume:

☒ Retrieved from architectural plans

☐ Code software calculated

☐ Field measured and calculated

R402.4.1.2 Testing. Testing shall be conducted by either individuals as defined in Section 553.993(5) or (7), Florida Statutes or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i) or an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures;
2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures;
3. Interior doors, if installed at the time of the test, shall be open;
4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed;
5. Heating and cooling systems, if installed at the time of the test, shall be turned off; and
6. Supply and return registers, if installed at the time of the test, shall be fully open.

Testing Company

Company Name: **The Sustainable Design Group**

Phone: **(352) 339-3899**

I hereby verify that the above Air Leakage test results are in accordance with the 2017 Florida Building Code, Energy Conservation, 6th Edition requirements according to the compliance method selected above.

Signature of Tester: 

Date of Test: **01/03/2019**

Printed Name of Tester: **Rafael Giro, P.E. #20488**

License/Certification #: **1353 Rater**

Issuing Authority: **FSEC**