

FIELD DENSITY WORKSHEET

CLIENT Cannon Builders DATE 7-31-24
 PROJECT NO. _____
 PROJECT NAME Cannon Res PERMIT NO. _____
 EARTH CONTRACTOR 179 SE Tristin Ln. Lake City TESTED BY CC
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor
☒ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 15' NW of SE corner	1088	9.9	FG	12'	54	111.6	1059	973
Center of Pad	1	1	1	1	64	114.6	1077	990
15' SE of NW corner	1	1	1	1	59	113.1	1068	982

REMARKS _____

* Density failed to meet minimum project requirement
 ** Retest indicates minimum density requirement was obtained.
 () Client is aware of unsatisfactory test results.