

Inspection Checklist for Permit #000054072

Notes:

Order	Category	Inspection	Requirements
1	Building	Framing <i>Reviews structural framing, load paths, fire blocking, and MEP rough-ins prior to insulation. Ref: FBC 110.3(3)</i>	
2	Building	Wall Sheathing <i>Confirms nail/screw spacing and panel installation per plans. Ref: FBC 110.3(3)</i>	
3	Building	Window Attachment <i>Verifies fastening of windows/doors for impact and wind load compliance. Ref: FBCR 609</i>	
4	Electrical	2nd Rough-In <i>Checks wiring, panel placement, and boxes before cover-up. Ref: NEC Art. 110.3</i>	
5	Building	Insulation <i>Verifies insulation type, R-value, and installation before drywall. Ref: FBC Energy C101.5</i>	
6	Building	Final <i>Ensures structure is complete, safe, and code-compliant before Certificate of Occupancy. Ref: FBC 110.5</i>	
7	Certificate	Release Certificate <i>Official Release for CO or final completion. Ref: FBC 110.5</i>	