





REINFORCEMENT MAY BE BENT IN THE SHOP OR THE FIELD PROVIDED:

1. ALL REINFORCEMENT IS BENT COLD.
2. THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS AND
3. REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.

EXCEPTION: WHERE BENDING IS NECESSARY TO ALIGN DOWEL BARS WITH A VERTICAL CELL, BARS PARTIALLY EMBEDDED IN CONCRETE SHALL BE FIELD BENT AT AN ANGLE OF NOT MORE THAN 1 INCH HORIZONTAL DISPLACEMENT TO 8 INCHES OF VERTICAL BAR LENGTH.

CONCRETE:
CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH
OF 2500 PSI AT 28 DAYS.


COVER OVER REINFORCING STEEL
FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS
SHALL BE:
3 INCHES IN FOUNDATIONS WHERE THE CONCRETE IS CAST AGAINST AND
PERMANENTLY IN CONTACT WITH THE EARTH OR EXPOSED TO THE EARTH
AND OTHER AREAS AND 1/2 INCHES ELSEWHERE. REINFORCING BARS EMBEDDED
IN GROUTED CELLS SHALL HAVE A MINIMUM CLEAR DISTANCE OF 1/4 INCH FOR
FINE GROUT OR 1/2 INCH FOR COARSE GROUT BETWEEN REINFORCING BARS
AND ANY FACE OF A CELL. REINFORCING BARS USED IN MASONRY WALLS
SHALL HAVE A MINIMUM COVER (INCLUDING GROUT) OF NOT LESS THAN
2 INCHES FOR MASONRY UNITS WITH FACE EXPOSED TO EARTH OR WEATHER
1 1/2 INCHES FOR MASONRY UNITS NOT EXPOSED TO EARTH OR WEATHER

GALVANIZATION:
METAL ACCESSORIES FOR USE IN EXTERIOR WALL CONSTRUCTION AND NOT DIRECTLY EXPOSED TO THE WEATHER SHALL BE GALVANIZED IN ACCORDANCE WITH ASTM A 153, CLASS B-2. METAL PLATE CONNECTORS, SCREWS, BOLTS AND NAILS EXPOSED DIRECTLY TO THE WEATHER SHALL BE STAINLESS STEEL OR HOT DIPPED GALVANIZED.

REINFORCING STEEL:
THE REINFORCING STEEL SHALL BE MINIMUM GRADE 40.

BEARING CAPACITY:
THE FOOTING IS DESIGNED FOR SOIL WITH AN ALLOWABLE BEARING CAPACITY OF 1,000 PSF. THE FOOTINGS SHALL REST ON UNDISTURBED OR COMPACTED SOIL OF UNIFORM DENSITY AND THICKNESS. AT THE OWNER'S REQUEST, COMPACTED SOILS SHALL BE TESTED TO A MINIMUM OF 95% OF MODIFIED PROCTOR AND COMPACTED IN LIFTS NOT TO EXCEED 12 INCHES.

161 NW MADISON STREET
SUITE #102
LAKE CITY, FL. 32055
(386)758-4209



Freeman
Design Group inc

DATE	DRAWN BY
09/21/05	W.H.F.

REVISIONS

SHEET A-3

OF 6

PROJECT N°

ST. JOHNS MODEL
CANNON CREEK PLACE LOT#45

Walter H. Lee
9/26/65