

**April 23, 2019**

Chase Larson  
258 SW Morning Glory Drive  
Lake City, FL 32024

**Subject: Permit # 37739 - Lot 8, Rolling Meadows**

Dear Chase:

Daniel & Gore, LLC has performed a vertical survey on Lot 8, Rolling Meadows, Columbia County, Florida from a benchmark being a FDOT rebar and aluminum cap stamped TBM 37 at the intersection of State Road No. 247 and Nursery Road (elevation – 101.116', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 101.00'.
- The slab elevation of the concrete foundation is at 102.36', being 1.36' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM