



Britt Surveying and Mapping, LLC
1438 SW Main Boulevard • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/15/2022

Permit # 000043633

L-28526

Cornerstone Developers

Re: Lot 84 Emerald Cove Phase 2

To Whom It May Concern:

The top of the finished slab on Lot 84 is found to be 109.39 feet. The building permit shows the minimum floor elevation to be 107 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757