

FBCR Table 602,3(2) & FBCR 803 ROOF SHEATHING

69	Include all materials which will make up the roof decking, identification of structural panel sheathing, grade, thickness	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
70	Show fastener Size and schedule for structural panel sheathing on the edges & intermediate areas	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

FBCR ROOF ASSEMBLIES FRC Chapter 9

71	Include all materials which will make up the roof assemblies covering	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
72	Submit Florida Product Approval numbers for each component of the roof assemblies covering	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FBCR Chapter 11 Energy Efficiency Code for residential building

Residential construction shall comply with this code by using the following compliance methods in the FBCR chapter 11 Residential buildings compliance methods. **Two of the required forms are to be submitted, N1100.1.1.1 As an alternative to the computerized Compliance Method A, the Alternate Residential Point System Method hand calculation, Alternate Form 600A, may be used. All requirements specific to this calculation are located in Sub appendix C to Appendix G. Buildings complying by this alternative shall meet all mandatory requirements of this chapter. Computerized versions of the Alternate Residential Point System Method shall not be acceptable for code compliance.**

GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL		Items to Include- Each Box shall be Circled as Applicable		
		YES	NO	N/A
73	Show the insulation R value for the following areas of the structure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
74	Attic space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
75	Exterior wall cavity	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
76	Crawl space	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

HVAC information

77	Submit two copies of a Manual J sizing equipment or equivalent computation study	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
78	Exhaust fans shown in bathrooms Mechanical exhaust capacity of 50 cfm intermittent or 20 cfm continuous required	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
79	Show clothes dryer route and total run of exhaust duct	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Plumbing Fixture layout shown

80	All fixtures waste water lines shall be shown on the foundation plan	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
81	Show the location of water heater	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Private Potable Water

82	Pump motor horse power	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
83	Reservoir pressure tank gallon capacity	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
84	Rating of cycle stop valve if used	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

PRODUCT APPROVAL SPECIFICATION SHEET

Location: Lake City, FL

Project Name: _____

As required by Florida Statute 553.842 and Florida Administrative Code 9B-72, please provide the information and the product approval number(s) on the building components listed below if they will be utilized on the construction project for which you are applying for a building permit on or after April 1, 2004. We recommend you contact your local product supplier should you not know the product approval number for any of the applicable listed products. More information about statewide product approval can be obtained at www.floridabuilding.org

Category/Subcategory	Manufacturer	Product Description	Approval Number(s)
A. EXTERIOR DOORS			
1. Swinging	Thermo-Tru	Exterior Hinged doors	FL 5262-R2
2. Sliding	P&T	Sliding Glass Doors	FL 251-R15
3. Sectional	Cl. Pan	Garage Doors	FL 5675-R4
4. Roll up			
5. Automatic			
6. Other			
B. WINDOWS			
1. Single hung	P&T	Window Low E	FL 236-R16
2. Horizontal Slider	P&T	Window Low E	FL 242-R12
3. Casement			
4. Double Hung			
5. Fixed	P&T	Window Low E	FL 243-R10
6. Awning			
7. Pass-through			
8. Projected			
9. Mullion			
10. Wind Breaker			
11. Dual Action			
12. Other			
C. PANEL WALL			
1. Siding	CertainTeed	Cement Fibered Siding	FL 1573-R2
2. Soffits	Kaycan	Alum soffit / fascia	FL 12198-R1
3. EIFS	Sto	Stucco/accucoat finish	FL 7229-R1
4. Storefronts			
5. Curtain walls			
6. Wall louver			
7. Glass block			
8. Membrane			
9. Greenhouse			
10. Other			
D. ROOFING PRODUCTS			
1. Asphalt Shingles	CertainTeed	Arch Shingles 30 yr	FL 5444-R3
2. Underlayments	GAF	Tar paper	FL 9637-F1
3. Roofing Fasteners	OmG	Roofing nails	FL 699-F3
4. Non-structural Metal Rf			
5. Built-Up Roofing			
6. Modified Bitumen			
7. Single Ply Roofing Sys			
8. Roofing Tiles			
9. Roofing Insulation			
10. Waterproofing			
11. Wood shingles /shakes			
12. Roofing Slate			

