



Columbia County, Florida  
Building Department  
135 NE Hernando Avenue  
Lake City, Florida 32055  
Phone: 386-758-1008  
[www.columbiacountyfla.com](http://www.columbiacountyfla.com)

**ROOFING AFFIDAVIT**

JOB ADDRESS: 410 SE peacock Terrace

I (Print Name) Robert Feasel, licensed under Chapter 468, Florida Statutes as a(n):

(Check One) ☒ Contractor ☐ Engineer ☐ Architect

License Number: RC29027319

On this (Date) 6-10-21, did personally examine the roof at the above address for regulatory compliance as required for: (Check all that apply)

☒ Roof Deck Attachment

☒ Secondary Water Barrier

☐ Roof to Wall Connection

Based on my examination, I have determined and affirm the installation is in accordance with the Florida Building Code 2020 7<sup>th</sup> Edition and 2020 Florida Statute (553.844).

Robert Feasel  
(Affiant Signature)

STATE OF Florida  
COUNTY Columbia

The foregoing instrument acknowledged before me by means of ☐ physical presence or ☐ online notarization, this 8<sup>th</sup> day of June 2021, by Robert Feasel, who is ☒ personally known to me or ☐ has provided the following identification \_\_\_\_\_.

Notary Public Signature Melissa Garber (Seal)

Notary Printed Name Melissa Garber

**FINAL INSPECTION & CERTIFICATE OF COMPLETION:**

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) [Welcome to Columbia County Online \(columbiacountyfla.com\)](http://Welcome to Columbia County Online (columbiacountyfla.com)).

Clearly visible in the Photographs must be the permit number or address and must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge and valley flashing.

## ROOF OPTIONS

Sealed roof decking options. (Must select one option per FBC 2020 7th Edition) \*



**a self-adhering polymer-modified bitumen underlayment complying with ASTM D1970 applied over the entire roof.**



**a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire roof.**



**two layers of felt underlayment comply ASTM 0226 Type II or ASTM D4869 Type III or IV, or two layers of a synthetic underlayment meeting the performance requirements specified, lapped and fastened as specified.**



**Other (explain)**

**Sealed roof decking explanation for other option.**