



GENERAL NOTES

- ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST ADOPTED EDITION OF THE NATIONAL ELECTRICAL CODE (NFPA 70), AND THE LATEST ADOPTED EDITION OF THE FLORIDA BUILDING CODE.
- CONTRACTOR SHALL FIELD VERIFY ALL CONDITIONS AND COORDINATE WITH ALL EQUIPMENT MANUFACTURER/INSTALLERS PRIOR TO BIDDING.
- ALL ELECTRICAL MATERIALS, DEVICES, APPLIANCES, AND EQUIPMENT SHALL BE LABEL LISTED BY AN APPROVED THIRD-PARTY TESTING AGENCY.
- BUILDING:**
RECEPTACLE = 18"
CLOCK = 7'-5"
SWITCH = 44"
MODULAR JACK FOR WALL MOUNTED TELEPHONE = 48"
MODULAR TELEPHONE JACK = 18"
TELEVISION OUTLET = 84"
COMPUTER OUTLET = 18"
CALL SWITCH = 44"
REMOTE TEST STATION FOR DUCT DETECTOR = 52"
C = ABOVE COUNTER BACKSPASH, COORDINATE WITH ARCHITECTURAL ELEVATIONS AND MILLWORK.
- ALL CONDUIT AND WIRING SHALL BE CONCEALED IN WALLS OR ABOVE CEILINGS UNLESS NOTED OTHERWISE OR APPROVED BY THE ARCHITECT/ENGINEER. ALL DEVICE OUTLET BOXES SHALL BE RECESSED UNLESS NOTED OTHERWISE OR APPROVED BY THE ARCHITECT/ENGINEER. WHERE APPROVED OR NOTED SURFACE METAL RACEWAYS AND DEVICE BOXES SHALL BE USED IN LIEU OF CONDUIT AND CONCEALED BOXES AT NO EXTRA COST TO THE OWNER.
- CONDUIT RUNS SHOWN ARE SCHEMATIC AND DO NOT INDICATE THE NECESSARY FITTINGS AND JUNCTION BOXES THAT ARE INCLUDED IN THE SCOPE OF THE WORK.
- CONTRACTOR SHALL PERMANENTLY IDENTIFY ALL WIRING WITH THE SOURCE AND CIRCUIT AT ALL ELECTRICAL EQUIPMENT, PULL AND JUNCTION BOXES AND ELECTRICAL TERMINATIONS PROVIDED OR ASSOCIATED WITH THIS CONSTRUCTION.
- COORDINATE EXACT LOCATION OF LIGHTING FIXTURES IN MECH. ROOMS/SPACES WITH DUCTWORK INSTALLER PRIOR TO ROUGH-IN. LOCATE BELOW DUCTWORK(8"-0" AFF MINIMUM) CENTERED IN ROOM AS MUCH AS POSSIBLE.
- COORDINATE EXACT INSTALLATION REQUIREMENTS OF OUTLETS IN MILLWORK WITH ARCHITECTURAL DRAWINGS, APPROVED SHOP DRAWINGS AND MILLWORK INSTALLER PRIOR TO ROUGH-IN.
- VERIFY EXACT LOCATION OF ALL MECHANICAL EQUIPMENT WITH MECHANICAL INSTALLER PRIOR TO ROUGH-IN.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF ALL LIGHT FIXTURES.
- PROVIDE NYLON PULLSTRINGS IN ALL EMPTY CONDUITS.
- COORDINATE THE EXACT LOCATION OF ALL ELECTRICAL EQUIPMENT LOCATED IN ELEVATOR MACHINE ROOMS, SHAFTS AND PITs. LOCATE EQUIPMENT AS REQUIRED TO MEET APPLICABLE CODES.PROVIDE AUTOMATIC DISCONNECTION OF THE ELEVATOR MAIN POWER SUPPLY (PER ANSI A17.1, RULE 102.2.1987 ED.) PRIOR TO ACTIVATION OF AUTOMATIC SPRINKLER SLOCATED WITHIN THE ELEVATOR MACHINE ROOM, PIT OR SHAFT. COORDINATE WITH FIRE PROTECTION AND FIRE ALARM INSTALLER.
- COORDINATE THE REQUIRED SIZE OF ALL CIRCUIT BREAKERS FEEDING EQUIPMENT, (I.E. MOTORS, HVAC, KITCHEN EQUIPMENT, SPECIAL PURPOSE OUTLETS, ELEVATORS, OWNER FURNISHED EQUIPMENT ETC.) WITH APPROVED EQUIPMENT SHOP DRAWINGS AND OWNER REPRESENTATIVES PRIOR TO ORDERING PANELBOARDS. BREAKERS SHALL BE SIZED PER THE NEC, THE EQUIPMENT NAME PLATE AND MANUFACTURERS RECOMMENDATIONS.
- ALL DIMMED CIRCUITS SHALL BE PROVIDED WITH DEDICATED NEUTRALS FOR EACH DIMMER AND PHASE CONDUCTOR THROUGHOUT THE ENTIRE CIRCUIT.
- THE POWER COMPANY SHALL BE CONTACTED WITHIN 10 DAYS OF THE AWARD OF THE CONTRACT BY THE CONTRACTOR TO VERIFY THE ACTUAL AVAILABLE SHORT CIRCUIT FAULT CURRENT (AIC) AT THE TRANSFORMER SECONDARY BUSHINGS. THE CONTRACTOR SHALL PROVIDE ELECTRICAL DISTRIBUTION AND UTILIZATION EQUIPMENT AND PANELBOARDS WHICH HAVE AIC/WITHSTAND RATINGS GREATER THAN THE AVAILABLE AIC AT EACH POINT IN THE ELECTRICAL SYSTEM.
- VISIT THE EXISTING FACILITY AND CAREFULLY EXAMINE THOSE PORTIONS OF THE BUILDING AND SITE AFFECTED BY THIS WORK BEFORE SUBMITTING PROPOSALS, SO AS TO BECOME FAMILIAR WITH THE EXISTING CONDITIONS AND DIFFICULTIES THAT WILL AFFECT EXECUTION OF THE WORK. SUBMISSION OF A PROPOSAL WILL BE CONSIDERED AS EVIDENCE THAT SUCH EXAMINATION HAS BEEN MADE AND LATER CLAIMS FOR LABOR, EQUIPMENT OR MATERIALS REQUIRED BECAUSE OF DIFFICULTIES ENCOUNTERED WILL NOT BE RECOGNIZED.
- CONTRACTOR SHALL INCLUDE IN HIS BID THE TRANSPORT AND DISPOSAL OR RECYCLING OF ALL WASTE MATERIALS GENERATED BY THIS PROJECT IN ACCORDANCE WITH ALL RULES, REGULATIONS AND GUIDELINES APPLICABLE.
- PANEL SCHEDULES INDICATE CIRCUIT DESIGNATIONS ONLY. CONTRACTOR TO PROVIDE MATERIALS AS REQUIRED WHEN NEUTRALS ARE SHARED TO COMPLY WITH NEC REQUIREMENTS. ALL SINGLE PHASE MULTIWIRE BRANCH CIRCUITS SHALL BE FED VIA A TWO POLE BREAKER OR TWO SINGLE POLE BREAKERS WITH AN IDENTIFIED HANDLE TIE. ALL THREE PHASE MULTIWIRE BRANCH CIRCUITS SHALL BE FED VIA A THREE POLE BREAKER OR THREE SINGLE POLE BREAKERS WITH AN IDENTIFIED HANDLE TIE (PER NEC 210.4B).
- PER NEC 110.22: PROVIDE PERMANENT LABELING FOR ALL SERIES RATED PANEL ENCLOSURES TO READ AS FOLLOWS: CAUTION - SERIES COMBINATION SYSTEM RATED _____ AMPERES. IDENTIFIED REPLACEMENT COMPONENTS REQUIRED.

GROUNDINGS:

- ALL METAL RACEWAYS, INCLUDING CONDUIT, WIRE TROUGHS, WIREMOLD, ETC., SHALL BE GROUNDED. ALL CONNECTIONS IN METAL RACEWAYS SHALL BE COMPLETED IN SUCH A MANNER AS TO MAINTAIN A CONTINUOUS PATH TO GROUND THROUGHOUT THE ENTIRE LENGTH OF THE RACEWAY.

WIRING:

- UNLESS NOTED OTHERWISE ON THE DRAWINGS OR ON THE EQUIPMENT WIRING SCHEDULE, EACH BRANCH CIRCUIT HOME RUN SHALL BE THREE (3) #12 AWG THHN/THWN (1 HOT, 1 NEUTRAL & 1 EQUIPMENT GROUND) IN 3/4" EMT. PROTECT EACH CIRCUIT WITH A 20 AMPERE, 1-POLE OVERCURRENT DEVICE UNLESS NOTED OTHERWISE. COMBINED NEUTRALS ARE NOT PERMITTED.

GENERAL:

- WITHIN 30 DAYS AFTER THE DATE OF SYSTEM ACCEPTANCE THE ELECTRICAL CONTRACTOR SHALL PROVIDE TO THE BUILDING OWNER RECORD DRAWINGS OF THE ACTUAL INSTALLATION INCLUDING:
1. A SINGLE-LINE DIAGRAM OF THE BUILDING ELECTRICAL DISTRIBUTION SYSTEM AND 2. FLOOR PLANS INDICATING LOCATION AND AREA SERVED FOR ALL DISTRIBUTION.
- THE ELECTRICAL CONTRACTOR SHALL PROVIDE THE BUILDING OWNER AN OPERATING MANUAL AND MAINTENANCE MANUAL AS REQUIRED BY THE FLORIDA BUILDING CODE. THE MANUALS SHALL INCLUDE, AT A MINIMUM, THE FOLLOWING: 1. SUBMITTAL DATE STATING EQUIPMENT RATING AND SELECTED OPTIONS FOR EACH PIECE OF EQUIPMENT REQUIRING MAINTENANCE. 2. OPERATION MANUALS AND MAINTENANCE MANUALS FOR EACH PIECE OF EQUIPMENT REQUIRING MAINTENANCE. REQUIRED ROUTINE MAINTENANCE ACTIONS SHALL BE CLEARLY IDENTIFIED. 3. NAMES AND ADDRESSES OF AT LEAST ONE QUALIFIED SERVICE AGENCY.
- THE ELECTRICAL CONTRACTOR SHALL PROVIDE THE REQUIRED FUNCTIONAL TESTING OF THE LIGHTING SYSTEM TO ENSURE THAT THE CONTROL HARDWARE AND SOFTWARE ARE CALIBRATED, ADJUSTED, PROGRAMMED AND IN PROPER WORKING CONDITION IN ACCORDANCE WITH THE CONSTRUCTION DOCUMENTS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS, WHERE REQUIRED BY THE CODE OFFICIAL. AN APPROVED PARTY INDEPENDENT FROM THE DESIGN OR CONSTRUCTION OF THE PROJECT SHALL BE RESPONSIBLE FOR THE FUNCTIONAL TESTING AND SHALL PROVIDE DOCUMENTATION TO THE CODE OFFICIAL CERTIFYING THAT THE INSTALLED LIGHTING CONTROLS MEET THE PROVISIONS OF FECC SECTION C405. WHERE OCCUPANT SENSORS, TIME SWITCHES, PROGRAMMABLE SCHEDULE CONTROLS, PHOTOSENSORS OR DAYLIGHTING CONTROLS ARE INSTALLED, THE FOLLOWING PROCEDURES SHALL BE PERFORMED: 1. CONFIRM THAT THE PLACEMENT, SENSITIVITY AND TIME-OUT ADJUSTMENTS FOR THE OCCUPANT SENSORS YIELD ACCEPTABLE PERFORMANCE.

ELECTRICAL SYMBOL LEGEND

WIRING AND POWER

- WALL OUTLET BOX AND SINGLE RECEPTACLE
- WALL OUTLET BOX AND DUPLEX RECEPTACLE
- TWO GANG WALL OUTLET BOX AND (2) DUPLEX RECEPTACLES
- WALL OUTLET BOX AND DUPLEX RECEPTACLE MOUNTED ABOVE COUNTER
- WALL OUTLET BOX AND DUPLEX RECEPTACLE WITH TOP HALF SWITCHED
- WALL OUTLET BOX AND DUPLEX RECEPTACLE CONNECTED TO EMERGENCY SYSTEM
- CEILING OUTLET BOX AND SINGLE RECEPTACLE
- CEILING OUTLET BOX AND DUPLEX RECEPTACLE
- WALL OUTLET BOX AND GFCI DUPLEX RECEPTACLE
- WALL OUTLET BOX AND GFCI DUPLEX RECEPTACLE MOUNTED ABOVE COUNTER
- WALL OUTLET BOX AND DUPLEX SAFETY RECEPTACLE
- WALL OUTLET BOX AND DUPLEX TWIST-LOCK RECEPTACLE
- WALL OUTLET BOX AND GFCI DUPLEX RECEPTACLE WITH WEATHERPROOF COVER
- WALL OUTLET BOX AND SPECIAL PURPOSE OUTLET AS NOTED ON PLANS
- FLUSH FLOOR OUTLET BOX WITH DUPLEX RECEPTACLE
- FLUSH FLOOR OUTLET BOX WITH (2) DUPLEX RECEPTACLES
- FLUSH FLOOR OUTLET BOX WITH DUPLEX RECEPTACLE AND TELECOMMUNICATIONS OUTLET
- FLUSH WALL JUNCTION BOX AND BLANK PLATE
- JUNCTION BOX AND BLANK PLATE ABOVE CEILING
- SURFACE MOUNTED JUNCTION BOX AND BLANK PLATE
- SURFACE MOUNTED WEATHERPROOF JUNCTION BOX AND COVER
- FLUSH GRADE FIBER COMPOSITE PULL BOX AS NOTED
- MOTOR CONNECTION AS NOTED
- FLUSH SHUNT-TRIP BUTTON, MOUNTED 80" TO TOP
- CONTROL AND/OR POWER EQUIPMENT CONNECTION
- TIME CLOCK
- PHOTO CELL
- DISCONNECT SWITCH, SIZE AS NOTED
- 120/208V BRANCH CIRCUIT PANELBOARD, SURFACE MOUNTED
- 120/208V BRANCH CIRCUIT PANELBOARD, FLUSH MOUNTED
- 277/480V BRANCH CIRCUIT PANELBOARD
- TRANSFORMER
- AUTOMATIC TRANSFER SWITCH
- BRANCH CIRCUIT HOMERUN WITH PANEL NAME AND CIRCUIT NUMBER. QUANTITY OF ARROWHEADS DENOTES QUANTITY OF BRANCH CIRCUITS
- BRANCH CIRCUIT WIRING, PROVIDE QUANTITY OF CONDUCTORS REQUIRED FOR CIRCUITING AND SWITCHING INDICATED ON PLANS
- POWER LEG ONLY (NO SWITCH LEG BETWEEN ROOMS)
- CONDUIT CAPPED OFF
- CONDUIT CONTINUED
- CONDUIT RUN UP
- CONDUIT RUN DOWN
- GROUND OR GROUND ROD AS NOTED

NOTE:
SYMBOLS SHOWN ARE FOR
REFERENCE PURPOSES ONLY.
ALL OF THESE SYMBOLS MAY
NOT BE USED FOR THIS
PROJECT.

FIRE ALARM SYSTEM LEGEND

- MANUAL PULL STATION
- WALL MOUNTED HORN WITH STROBE (cd=CANDELA RATING)
- WALL MOUNTED HORN WITH STROBE IN WEATHERPROOF ENCLOSURE
- CEILING MOUNTED HORN WITH STROBE
- WALL MOUNTED MINI HORN
- WALL MOUNTED MINI HORN WITH STROBE
- WALL MOUNTED VOICE EVACUATION SPEAKER WITH STROBE
- CEILING MOUNTED VOICE EVACUATION SPEAKER WITH STROBE
- WALL MOUNTED STROBE
- SMOKE DETECTOR
- DUCT MOUNTED SMOKE DETECTOR
- HEAT DETECTOR
- REMOTE DUCT DETECTOR INDICATOR LIGHT AND TEST SWITCH (NUMBER INDICATES QUANTITY)
- FAN SHUT-DOWN RELAY
- ELECTROMAGNETIC DOOR RELEASE DEVICE
- SMOKE DAMPER (PROVIDE BY MECHANICAL, CONNECTED BY ELECTRICAL)
- FIREMAN'S PHONE JACK
- SPRINKLER SYSTEM SUPERVISORY SWITCH CONNECTION
- SPRINKLER SYSTEM FLOW SWITCH CONNECTION
- CONTROL MODULE
- MONITOR MODULE
- LOCK BOX
- FIRE ALARM CONTROL PANEL
- FIRE ALARM TERMINAL CABINET
- FIRE ALARM ANNUNCIATOR PANEL
- DIGITAL ALARM COMMUNICATOR TRANSMITTER

TELECOMMUNICATION SYSTEM LEGEND

- COMBINATION TELECOMMUNICATIONS/DATA WALL OUTLET BOX AND BLANK PLATE WITH MIN. 3/4" C. TO ACCESSIBLE CEILING SPACE. COORDINATE OUTLET REQUIREMENTS WITH OWNER.
- TELECOMMUNICATIONS WALL OUTLET BOX AND BLANK PLATE FOR WALL MOUNTED TELEPHONE WITH MIN. 3/4" C. TO ACCESSIBLE CEILING SPACE. COORDINATE OUTLET REQUIREMENTS WITH OWNER.
- DATA WALL OUTLET BOX AND BLANK PLATE WITH MIN. 3/4" C. TO ACCESSIBLE CEILING SPACE. COORDINATE OUTLET REQUIREMENTS WITH OWNER.
- FLUSH FLOOR OUTLET BOX WITH POWER DEVICE AND TELECOMMUNICATIONS OUTLET WITH MIN. 3/4" C. TO ACCESSIBLE CEILING SPACE.
- CEILING OUTLET BOX AND BLANK PLATE WITH MIN. 3/4" C. TO TTB FOR WIRELESS ACCESS POINT. COORDINATE OUTLET REQUIREMENTS WITH OWNER.
- COMBINATION TELECOMMUNICATIONS/TELEVISION WALL OUTLET BOX AND BLANK PLATE. COORDINATE OUTLET AND CABLING REQUIREMENTS WITH OWNER.
- 3/4" PLYWOOD TELEPHONE TERMINAL BOARD, SIZE AS SHOWN ON PLANS.
- TELEPHONE TERMINAL CABINET, SIZE AS NOTED ON PLAN.

Consulting Engineers
180 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLC&C.COM
CA NO. 28730
JLC 21.0042.00


Blake L. Suddeth
Professional Engineer
State of Florida
License No. 15419
Exp. 03/24
15-41-09-0907

HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAINLAND AVENUE, SUITE 500, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.3757 FAX 407.647.2862

TOWNEPLACE
SUITES[®]
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION
JOB NO.
DATE
SHEET
E0.1
OF



- REFERENCE NOTES: (X)
- 1 ALL EXTERIOR SITE LIGHTING SHALL BE CONTROLLED BY LIGHTING CONTACTOR ASSOCIATED WITH THAT BUILDING'S HOUSE PANEL. REFER TO POWER RISER DIAGRAM FOR ADDITIONAL INFORMATION. MINIMUM 2#10 CU. AND 1#10 CU. GND. IN 3/4" FOR ENTIRE LENGTH OF CIRCUIT.
 - 2 PROPOSED LOCATION FOR NATURAL GAS GENSET. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN. SEE POWER RISER DIAGRAM FOR ADDITIONAL INFORMATION.
 - 3 COORDINATE ALL REQUIREMENTS WITH LOCAL UTILITY COMPANY PRIOR TO ROUGH-IN.
 - 4 WEATHERPROOF JUNCTION BOX FOR CONNECTION OF MONUMENT SIGNAGE. COORDINATE EXACT LOCATION AND REQUIREMENTS PRIOR TO ROUGH-IN.

- GENERAL NOTES:
- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
 - B. ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
 - C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
 - D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH-IN.

1 SITE PLAN - ELECTRICAL
SCALE: 3/32" = 1'-0"

Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLC&C.COM
CA NO. 28730

JLC 21.0042.00

STATE OF FLORIDA
PROFESSIONAL ENGINEER

HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MATILDA AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.847.5757 FAX 407.847.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION
JOB NO.
DATE
SHEET
E1.1
OF

5 Fixture Type 'SLA2'

2 Fixture Type 'SLA3'


3 Fixture Type 'SLA3HS'

4 Fixture Type 'SLA4HS'

5 Fixture Type 'SLA2'

6 Fixture Type 'WLA3'





1 FIRST FLOOR PLAN - POWER & SYSTEMS
SCALE: 1/8" = 1'-0"

REFERENCE NOTES: (X)

- 1 ELECTRICAL CONTRACTOR SHALL COORDINATE DISCONNECT AND FUSE REQUIREMENTS FOR MECHANICAL UNIT WITH MECHANICAL CONTRACTOR AND EQUIPMENT MANUFACTURER PRIOR TO ROUGH-IN AND PROVIDE AS REQUIRED.
- 2 PROVIDE 120V RECEPTACLE AND TELEVISION OUTLET FOR WALL MOUNTED TELEVISION. COORDINATE MOUNTING HEIGHT AND LOCATION WITH OWNER/EQUIPMENT INSTALLER PRIOR TO ROUGH-IN.
- 3 CONNECT 120V RECEPTACLE CIRCUIT IN OFFICE SPACE VIA WATTSTOPPER PLUG LOAD POWER PACK #87-200 (OR APPROVED SUBSTITUTION) FOR AUTOMATIC CONTROL OF RECEPTACLES. RECEPTACLES SHALL BE SPLIT WIRED SO THAT THE POWER PACK SHALL AUTOMATICALLY "TURN OFF" THE TOP OUTLET ON EACH RECEPTACLE IF SPACE IS UNOCCUPIED FOR 20 MINUTES AND THE BOTTOM OUTLET SHALL BE CONSTANT HOT. OUTLETS SHALL BE VISUALLY MARKED AS REQUIRED TO DIFFERENTIATE CONTROLLED OUTLETS FROM UNCONTROLLED OUTLETS. RECEPTACLE POWER PACKS SHALL BE CONTROLLED VIA LOW VOLTAGE VACANCY SENSORS AS SHOWN ON LIGHTING PLAN. PROVIDE ALL CONDUIT AND LOW VOLTAGE WIRING AS REQUIRED TO INTERCONNECT RECEPTACLE POWER PACKS AND LIGHTING POWER PACKS. INSTALLATION SHALL COMPLY WITH FLORIDA BUILDING CODE SECTION C405.7.1, 2014 EDITION AND ASHRAE STANDARD 90.1.
- 4 LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).
- 5 PROVIDE FLOOR BOX WITH 120V DUPLEX RECEPTACLE ON DEDICATED CIRCUIT FOR CONNECTION OF FITNESS EQUIPMENT. COORDINATE EXACT LOCATION AND CONNECTION REQUIREMENTS WITH FITNESS EQUIPMENT INSTALLER PRIOR TO ROUGH-IN. PROVIDE ALL DEVICES, DIVIDERS, COVERPLATES, ETC. FOR A COMPLETE INSTALLATION.
- 6 120VOLT CONNECTION TO FIRE/SMOKE DAMPER, COORDINATE EXACT LOCATION AND REQUIREMENTS WITH DIVISION 15.
- 7 CONNECT 120V FRACTIONAL HORSEPOWER EXHAUST FAN TO LOCAL LIGHTING CIRCUIT. FAN TO OPERATE SIMULTANEOUSLY WITH ROOM LIGHTS.
- 8 PROVIDE TWO-WAY COMMUNICATION SYSTEM AND CABLE TO FACP AS REQUIRED BY 2017 6TH EDITION FBC, 2017 NFPA, AND 2015 NFPA 101 LIFE SAFETY CODE. COORDINATE LOCATION WITH OWNER AND AUTHORITY HAVING JURISDICTION PRIOR TO ROUGH-IN.
- 9 PROVIDE 120V CONNECTION FOR AUTOMATIC DOOR OPENING MOTOR. PROVIDE CONDUIT AND WIRING FOR ASSOCIATED PUSHBUTTON. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- 10 2#12, 1#12GND, IN 3/4" C. TO RESPECTIVE OUTDOOR MINI-SPLIT UNIT (MCU), COORDINATE EXACT REQUIREMENTS WITH DIVISION 15 AS REQUIRED.
- 11 PROVIDE 120V CONNECTION FOR GAS GRILL. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- 12 PROVIDE 120V CONNECTION FOR GAS FIREPIT. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- 13 CARD READER FOR OWNER SELECTED ACCESS CONTROL SYSTEM. PROVIDE CONDUIT PATH/RUN (CONCEALED) WHERE REQUIRED TO ACCOMMODATE LOW VOLTAGE WIRING. COORDINATE EXACT REQUIREMENTS WITH OWNER/SYSTEM PROVIDER PRIOR TO ROUGH-IN.
- 14 COORDINATE EXACT LOCATION(S) OF EXTERIOR WEATHERPROOF HORN-STROBE WITH LOCAL FIRE DEPARTMENT AHA.


GENERAL NOTES:


- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRICAL CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.




- ① LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).
- ② 120VOLT CONNECTION TO FIRE/SMOKE DAMPER, COORDINATE EXACT LOCATION AND REQUIREMENTS WITH FIRE/SMOKE.
- ③ PROVIDE TWO-WAY COMMUNICATION SYSTEM AND CABLEING TO MAIN BASE STATION AS REQUIRED BY 2017 OTH EDITION, FEB. 2017 IFPC, AND 2015 NFPA 101 LIFE SAFETY CODE. COORDINATE LOCATION WITH OWNER AND AUTHORITY HAVING JURISDICTION PRIOR TOROUGH-IN.
- ④ LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).

- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.
- E. REFER TO ENLARGED TYPICAL UNIT PLANS FOR ALL ELECTRICAL UNITS.
- F. PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
- G. WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
- H. ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS. THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
- I. PROVIDE A DEDICATED NEUTRAL CONDUCTOR FOR EACH 120V BRANCH CIRCUIT.





2 ENLARGED PLAN - ELECTRICAL ROOM
SCALE: 1/4" = 1'-0"




3 ENLARGED PLAN - PBX ROOM
SCALE: 1/4" = 1'-0"

REFERENCE NOTES: (X)

- LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).
- 120VOLT CONNECTION TO FIRE/SMOKE DAMPER, COORDINATE EXACT LOCATION AND REQUIREMENTS WITH DIVISION 15.
- PROVIDE TWO-WAY COMMUNICATION SYSTEM AND CABLE TO MAIN BASE STATION AS REQUIRED BY 2017 6TH EDITION FBC, 2017 FFPC, AND 2015 NFPA 101 LIFE SAFETY CODE. COORDINATE LOCATION WITH OWNER AND AUTHORITY HAVING JURISDICTION PRIOR TO ROUGH-IN.
- LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).
- 2#10, 1#10GND, IN 3/4" C. TO RESPECTIVE OUTDOOR MINI-SPLIT UNIT (MCU), COORDINATE EXACT REQUIREMENTS WITH DIVISION 15 AS REQUIRED.


GENERAL NOTES:

- DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- ALL WORK SHALL COMPLY WITH THE 2014 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.
- REFER TO ENLARGED TYPICAL UNIT PLANS FOR ALL ELECTRICAL IN UNITS.
- PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
- WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
- ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS, THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
- PROVIDE A DEDICATED NEUTRAL CONDUCTOR FOR EACH 120V BRANCH CIRCUIT.



1 THIRD FLOOR PLAN - POWER & SYSTEMS
SCALE: 1/8" = 1'-0"

J&C
Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTA MONTE SPRINGS, FLORIDA 32714
TEL: 321.972.4466
WWW.JLCONG.COM
CA NO. 28730



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MATILDA AVE., SUITE 200, ALTA MONTE SPRINGS, FL 32701
PHONE 407.647.5757 FAX 407.647.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E2.3
OF

REFERENCE NOTES: ①

- ① LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).
- ② 120VOLT CONNECTION TO FIRE/SMOKE DAMPER, COORDINATE EXACT LOCATION AND REQUIREMENTS WITH DIVISION 15.
- ③ PROVIDE TWO-WAY COMMUNICATION SYSTEM AND CABLE TO MAIN BASE STATION AS REQUIRED BY 2017 6TH EDITION FBC, 2017 FFPC, AND 2015 NFPA 101 LIFE SAFETY CODE. COORDINATE LOCATION WITH OWNER AND AUTHORITY HAVING JURISDICTION PRIOR TO ROUGH-IN.
- ④ LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).


GENERAL NOTES:

- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE 2014 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.
- E. REFER TO ENLARGED TYPICAL UNIT PLANS FOR ALL ELECTRICAL IN UNITS.
- F. PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
- G. WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
- H. ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS, THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
- I. PROVIDE A DEDICATED NEUTRAL CONDUCTOR FOR EACH 120V BRANCH CIRCUIT.




2 ENLARGED PLAN - ELECTRICAL ROOM

SCALE: 1/4" = 1'-0"




1 FOURTH FLOOR PLAN - POWER & SYSTEMS

SCALE: 1/8" = 1'-0"



Consulting Engineers

1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLC&C.COM
CA NO. 28730



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MATILDA AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.5757 FAX 407.647.2802


TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E2.4
OF

- REFERENCE NOTES: ⓧ
- 1 LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).
 - 2 120VOLT CONNECTION TO FIRE/SMOKE DAMPER, COORDINATE EXACT LOCATION AND REQUIREMENTS WITH DIVISION 15.
 - 3 PROVIDE TWO-WAY COMMUNICATION SYSTEM AND CABLEING TO MAIN BASE STATION AS REQUIRED BY 2017 6TH EDITION FBC, 2017 FFPC, AND 2015 NFPA 101 LIFE SAFETY CODE. COORDINATE LOCATION WITH OWNER AND AUTHORITY HAVING JURISDICTION PRIOR TO ROUGH-IN.
 - 4 LOCATE HOUSE PHONES 12" FROM DOOR U.N.O., 56" AFF (TYPICAL).


- GENERAL NOTES:
- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
 - B. ALL WORK SHALL COMPLY WITH THE 2014 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
 - C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
 - D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.
 - E. REFER TO ENLARGED TYPICAL UNIT PLANS FOR ALL ELECTRICAL IN UNITS.
 - F. PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
 - G. WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
 - H. ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS, THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
 - I. PROVIDE A DEDICATED NEUTRAL CONDUCTOR FOR EACH 120V BRANCH CIRCUIT.




2 ENLARGED PLAN - ELECTRICAL ROOM
SCALE: 1/4" = 1'-0"



1 FIFTH FLOOR PLAN - POWER & SYSTEMS
SCALE: 1/8" = 1'-0"



Consulting Engineers
180 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLC&C.COM
CA NO. 28730



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MATILDA AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.5757 FAX 407.647.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E2.5
OF

GENERAL NOTES:

- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRICAL CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.


REFERENCE NOTES: ⓧ

- ① ELECTRICAL CONTRACTOR SHALL COORDINATE DISCONNECT AND FUSE REQUIREMENTS FOR MECHANICAL UNIT WITH MECHANICAL CONTRACTOR AND EQUIPMENT MANUFACTURER PRIOR TO ROUGH-IN AND PROVIDE AS REQUIRED.




1 ROOF PLAN - ELECTRICAL

SCALE: 1/8" = 1'-0"



Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCENG.COM
CA NO. 28730




HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAINTENANCE SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.847.7575 FAX 407.847.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION
JOB NO.
DATE
SHEET
E2.6
OF



1 FIRST FLOOR PLAN - LIGHTING
SCALE: 1/8" = 1'-0"

REFERENCE NOTES: (X)


1. CONNECT EXTERIOR LIGHTING TO LIGHTING CONTRACTOR "LC1" FOR TIME OF DAY LIGHTING CONTROL.
2. PROVIDE CEILING MOUNTED OCCUPANCY SENSOR TO OVERRIDE WALL SWITCH AND TURN OFF ROOM LIGHTS AND/OR CEILING FANS IN SPACE IF UNOCCUPIED FOR MORE THAN 30 MINUTES PER FBC. PROVIDE ADDITIONAL SENSORS, POWER PACKS, RELAYS, ETC. AS REQUIRED FOR COMPLETE COVERAGE OF SPACE AS RECOMMENDED BY MANUFACTURER.
3. PROVIDE WALL MOUNTED OCCUPANCY SENSOR (WITH VACANCY OPTION) TO TURN OFF ROOM LIGHTS AND/OR CEILING FANS IN SPACE IF UNOCCUPIED FOR MORE THAN 30 MINUTES PER FBC. SENSOR SHALL BE AUTOMATIC OFF, MANUAL ON.
4. COORDINATE EXACT LOCATION OF LED STRIP LIGHT WITH ARCHITECTURAL DRAWINGS PRIOR TO ROUGH-IN. COORDINATE EXACT INSTALLATION REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.

GENERAL NOTES:

- A. SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT FIXTURE LOCATIONS AND ORIENTATIONS.
- B. REFER TO ARCHITECTURAL ELEVATIONS AND SECTIONS FOR ADDITIONAL LIGHTING FIXTURE MOUNTING DETAILS AND INFORMATION.
- C. ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS SHALL BE CONNECTED "HOT" TO THE INDICATED LOCAL LIGHTING CIRCUIT.
- D. VERIFY ALL MOUNTING HEIGHTS AND PENDANT LENGTHS WITH ARCHITECT AND ENGINEER PRIOR TO ORDERING FIXTURES.
- E. EMERGENCY ILLUMINATION SHALL BE PROVIDED FOR A PERIOD OF 90 MINUTES IN THE EVENT OF FAILURE OF NORMAL LIGHTING. EMERGENCY LIGHTING FACILITIES SHALL BE ARRANGED TO PROVIDE INITIAL ILLUMINATION THAT IS AT LEAST AN AVERAGE OF 1 FOOTCANDLE (10 LUX) AND A MINIMUM AT ANY POINT OF 0.1 FOOTCANDLE (1 LUX) MEASURED ALONG THE PATH OF EGRESS AT FLOOR LEVEL. ILLUMINATION LEVELS SHALL BE PERMITTED TO DECLINE TO 0.6 FOOTCANDLE (6 LUX) AVERAGE AND A MINIMUM AT ANY POINT OF 0.06 FOOTCANDLE (0.6 LUX) AT THE END OF THE EMERGENCY LIGHTING TIME DURATION. A MAXIMUM-TO-MINIMUM ILLUMINATION UNIFORMITY RATIO OF 40:1 SHALL NOT BE EXCEEDED.



Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLC&C.COM
CA NO. 28730



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAULANA AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.457.7575 FAX 407.457.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E3.1
OF

REFERENCE NOTES: (X)

- (1) PROVIDE WALL MOUNTED OCCUPANCY SENSOR (WITH VACANCY OPTION) TO TURN OFF ROOM LIGHTS AND/OR CEILING FANS IN SPACE IF UNOCCUPIED FOR MORE THAN 30 MINUTES PER FDC. SENSOR SHALL BE AUTOMATIC OFF, MANUAL ON.


GENERAL NOTES:

- A. SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT FIXTURE LOCATIONS AND ORIENTATIONS.
- B. REFER TO ARCHITECTURAL ELEVATIONS AND SECTIONS FOR ADDITIONAL LIGHTING FIXTURE MOUNTING DETAILS AND INFORMATION.
- C. ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS SHALL BE CONNECTED "HOT" TO THE INDICATED LOCAL LIGHTING CIRCUIT.
- D. VERIFY ALL MOUNTING HEIGHTS AND PENDANT LENGTHS WITH ARCHITECT AND ENGINEER PRIOR TO ORDERING FIXTURES.
- E. EMERGENCY ILLUMINATION SHALL BE PROVIDED FOR A PERIOD OF 90 MINUTES IN THE EVENT OF FAILURE OF NORMAL LIGHTING. EMERGENCY LIGHTING FACILITIES SHALL BE ARRANGED TO PROVIDE INITIAL ILLUMINATION THAT IS AT LEAST AN AVERAGE OF 1 FOOTCANDLE (10 LUX) AND A MINIMUM AT ANY POINT OF 0.1 FOOTCANDLE (1 LUX) MEASURED ALONG THE PATH OF EGRESS AT FLOOR LEVEL. ILLUMINATION LEVELS SHALL BE PERMITTED TO DECLINE TO 0.6 FOOTCANDLE (6 LUX) AVERAGE AND A MINIMUM AT ANY POINT OF 0.06 FOOTCANDLE (0.6 LUX) AT THE END OF THE EMERGENCY LIGHTING TIME DURATION. A MAXIMUM-TO-MINIMUM ILLUMINATION UNIFORMITY RATIO OF 40:1 SHALL NOT BE EXCEEDED.




SECOND FLOOR PLAN - LIGHTING

SCALE: 1/8" = 1'-0"



Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTA MONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCONG.COM
CA NO. 28730



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAULDIN AVE., SUITE 200, ALTA MONTE SPRINGS, FL 32701
PHONE 407.457.5757 FAX 407.457.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION
JOB NO.
DATE
SHEET
E3.2
OF

REFERENCE NOTES: (X)

(1) PROVIDE WALL MOUNTED OCCUPANCY SENSOR (WITH VACANCY OPTION) TO TURN OFF ROOM LIGHTS AND/OR CEILING FANS IN SPACE IF UNOCCUPIED FOR MORE THAN 30 MINUTES PER FBC. SENSOR SHALL BE AUTOMATIC OFF, MANUAL ON.

GENERAL NOTES:


A. SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT FIXTURE LOCATIONS AND ORIENTATIONS.

B. REFER TO ARCHITECTURAL ELEVATIONS AND SECTIONS FOR ADDITIONAL LIGHTING FIXTURE MOUNTING DETAILS AND INFORMATION.

C. ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS SHALL BE CONNECTED "HOT" TO THE INDICATED LOCAL LIGHTING CIRCUIT.


D. VERIFY ALL MOUNTING HEIGHTS AND PENDANT LENGTHS WITH ARCHITECT AND ENGINEER PRIOR TO ORDERING FIXTURES.

E. EMERGENCY ILLUMINATION SHALL BE PROVIDED FOR A PERIOD OF 90 MINUTES IN THE EVENT OF FAILURE OF NORMAL LIGHTING. EMERGENCY LIGHTING FACILITIES SHALL BE ARRANGED TO PROVIDE INITIAL ILLUMINATION THAT IS AT LEAST AN AVERAGE OF 1 FOOTCANDLE (10 LUX) AND A MINIMUM AT ANY POINT OF 0.1 FOOTCANDLE (1 LUX) MEASURED ALONG THE PATH OF EGRESS AT FLOOR LEVEL. ILLUMINATION LEVELS SHALL BE PERMITTED TO DECLINE TO 0.6 FOOTCANDLE (6 LUX) AVERAGE AND A MINIMUM AT ANY POINT OF 0.06 FOOTCANDLE (0.6 LUX) AT THE END OF THE EMERGENCY LIGHTING TIME DURATION. A MAXIMUM-TO-MINIMUM ILLUMINATION UNIFORMITY RATIO OF 40:1 SHALL NOT BE EXCEEDED.




1 THIRD FLOOR PLAN - LIGHTING

SCALE: 1/8" = 1'-0"



Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCONG.COM
CA NO. 28730



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MATILDA AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.457.5757 FAX 407.457.2862

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCIAL DRIVE, LAKE CITY, FLORIDA

REVISION
JOB NO.
DATE
SHEET
E3.3
OF

1 PROVIDE WALL MOUNTED OCCUPANCY SENSOR (WITH VACANCY OPTION) TO TURN OFF ROOM LIGHTS AND/OR CEILING FANS IN SPACE IF UNOCCUPIED FOR MORE THAN 30 MINUTES PER FBC. SENSOR SHALL BE AUTOMATIC OFF, MANUAL ON.


- A. SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT FIXTURE LOCATIONS AND ORIENTATIONS.
- B. REFER TO ARCHITECTURAL ELEVATIONS AND SECTIONS FOR ADDITIONAL LIGHTING FIXTURE MOUNTING DETAILS AND INFORMATION.
- C. ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS SHALL BE CONNECTED "HOT" TO THE INDICATED LOCAL LIGHTING CIRCUIT.
- D. VERIFY ALL MOUNTING HEIGHTS AND PENDANT LENGTHS WITH ARCHITECT AND ENGINEER PRIOR TO ORDERING FIXTURES.
- E. EMERGENCY ILLUMINATION SHALL BE PROVIDED FOR A PERIOD OF 90 MINUTES IN THE EVENT OF A FAILURE OF NORMAL LIGHTING. EMERGENCY LIGHTING FACILITIES SHALL BE ARRANGED TO PROVIDE MINIMUM ILLUMINATION THAT IS AT LEAST AN AVERAGE OF 1 FOOTCANDLE (10 LUX) AND A MINIMUM AT ANY POINT OF 0.1 FOOTCANDLE (1 LUX) MEASURED ALONG THE PATH OF EGRESS AT FLOOR LEVEL. ILLUMINATION LEVELS SHALL BE PERMITTED TO DECLINE TO 0.6 FOOTCANDLE (6 LUX) AVERAGE AND A MINIMUM AT ANY POINT OF 0.06 FOOTCANDLE (0.6 LUX) AT THE END OF THE EMERGENCY LIGHTING TIME DURATION. A MAXIMUM-TO-MINIMUM ILLUMINATION UNIFORMITY RATIO OF 40:1 SHALL NOT BE EXCEEDED.

ARCHITECTS AND PLANNERS
377 MAITLAND AVE., SUITE 2010, ALTAMONTE SPRINGS, FL 32701
PHONE 407 647-5767 FAX 407 647-2062


SUITES
BY MARRIOTT

LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY,

OF



1 FOURTH
SCALE: 1/8" = 1'-0"



OF

REFERENCE NOTES: (X)

(1) PROVIDE WALL MOUNTED OCCUPANCY SENSOR (WITH VACANCY OPTION) TO TURN OFF ROOM LIGHTS AND/OR CEILING FANS IN SPACE IF UNOCCUPIED FOR MORE THAN 30 MINUTES PER FBC. SENSOR SHALL BE AUTOMATIC OFF, MANUAL ON.

GENERAL NOTES:


A. SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT FIXTURE LOCATIONS AND ORIENTATIONS.

B. REFER TO ARCHITECTURAL ELEVATIONS AND SECTIONS FOR ADDITIONAL LIGHTING FIXTURE MOUNTING DETAILS AND INFORMATION.

C. ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS SHALL BE CONNECTED "HOT" TO THE INDICATED LOCAL LIGHTING CIRCUIT.


D. VERIFY ALL MOUNTING HEIGHTS AND PENDANT LENGTHS WITH ARCHITECT AND ENGINEER PRIOR TO ORDERING FIXTURES.

E. EMERGENCY ILLUMINATION SHALL BE PROVIDED FOR A PERIOD OF 90 MINUTES IN THE EVENT OF FAILURE OF NORMAL LIGHTING. EMERGENCY LIGHTING FACILITIES SHALL BE ARRANGED TO PROVIDE INITIAL ILLUMINATION THAT IS AT LEAST AN AVERAGE OF 1 FOOTCANDLE (10 LUX) AND A MINIMUM AT ANY POINT OF 0.1 FOOTCANDLE (1 LUX) MEASURED ALONG THE PATH OF EGRESS AT FLOOR LEVEL. ILLUMINATION LEVELS SHALL BE PERMITTED TO DECLINE TO 0.6 FOOTCANDLE (6 LUX) AVERAGE AND A MINIMUM AT ANY POINT OF 0.06 FOOTCANDLE (0.6 LUX) AT THE END OF THE EMERGENCY LIGHTING TIME DURATION. A MAXIMUM-TO-MINIMUM ILLUMINATION UNIFORMITY RATIO OF 40:1 SHALL NOT BE EXCEEDED.




1 FIFTH FLOOR PLAN - LIGHTING

SCALE: 1/8" = 1'-0"



Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTA MONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCONG.COM
CA NO. 28730




HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAULDIN AVE., SUITE 200, ALTA MONTE SPRINGS, FL 32701
PHONE 407.457.5757 FAX 407.457.2802


TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E3.5
OF




1 TYPICAL KING STUDIO
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"



2 TYPICAL KING STUDIO WIDE
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"



4 TYPICAL SP-ACC-KING SUITE LOCKOUT
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"



3 TYPICAL KING STUDIO ADA TUB
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- DO NOT SCALE ELECTRICAL DRAWINGS FOR ANY DIMENSIONS.
- ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- ALL NON-LOCKING, 125V, 15A AND 20A RECEPTACLES INSTALLED IN GUESTROOM UNITS SHALL BE LISTED TAMPER-RESISTANT AS REQUIRED BY NEC 406.12.
- 120V, SINGLE PHASE, 15A AND 20A BRANCH CIRCUITS SUPPLYING OUTLETS INSTALLED IN GUESTROOM UNIT FAMILY ROOMS, DINING ROOMS, LIVING ROOMS, BEDROOMS, SUNROOMS, RECREATIONS ROOMS, CLOSETS, HALLWAYS OR SIMILAR ROOMS OR AREAS SHALL BE PROTECTED BY A LISTED ARC-FAULT CIRCUIT INTERRUPTER, INSTALLED TO PROVIDE PROTECTION OF THE BRANCH CIRCUIT AS REQUIRED BY NEC 210.12 AND LOCAL ORDINANCES.
- PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
- CONTRACTOR SHALL INSTALL RECEPTACLES SUCH THAT RECEPTACLES IN WALLS BETWEEN GUESTROOMS ARE OFFSET HORIZONTALLY BY A MINIMUM OF 6 INCHES.
- WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
- MULTIPLE GROUPINGS OF DEVICES SHALL BE GANGED UNDER THE SAME COVERPLATE. SEPARATE PLATES ARE UNACCEPTABLE EXCEPT IN CASES OF DIMMER SWITCHES ADJACENT TO OTHER LIGHT SWITCHES. IN THAT CASE, PLATES SHALL BE AS CLOSE TOGETHER AS POSSIBLE, PLUMB TRUE FOR A NEAT AND COMPACT ORGANIZED APPEARANCE.
- SEE ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS. THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
- SMOKE ALARMS IN DWELLING UNITS SHALL BE LOW-VOLTAGE, PHOTOELECTRIC SMOKE DETECTORS WITH SOUNDER BASES THAT ARE BOTH POWERED AND MONITORED BY THE FACP PER MARRIOTT'S MODULE 14. AND SHALL BE INSTALLED WITH CLEARANCES IN COMPLIANCE WITH NFPA 72.
- AUDIBLE FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE A SOUND LEVEL OF AT LEAST 85 dBA AT 10 FEET AND 75 dBA AT THE PILLOW AND BE OF A LOW FREQUENCY, SQUARE WAVE SIGNAL 520 HZ (+/-10%), IN ACCORDANCE WITH NFPA 72 SECTIONS 18.4.5.1-18.4.5.3.
- BUILDING FIRE ALARM SYSTEM NOTIFICATION SHALL INCLUDE BE LOW FREQUENCY HORNS IN STANDARD GUESTROOM UNITS AND LOW FREQUENCY HORN/STROBES IN HEARING IMPAIRED (H.I.) GUESTROOMS UNITS. COORDINATE H.I. LOCATIONS WITH ARCHITECTURAL PLANS.
- VISUAL FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE AN INTENSITY LEVEL OF:
 - *110 CD WHERE TOP OF LENS IS INSTALLED GREATER THAN OR EQUAL TO 24 INCHES FROM THE CEILING
 - *177 CD WHERE TOP OF LENS IS INSTALLED LESS THAN 24 INCHES FROM THE CEILING
 AND SHALL NOT BE FURTHER THAN 16 FEET FROM THE PILLOW, IN ACCORDANCE WITH NFPA 72 SECTIONS 18.5.5.7.1-18.5.5.7.3.


REFERENCE NOTES: (X)

- INSTALL JUNCTION BOX FOR LIT VANITY MIRROR AT A HEIGHT PER OWNER'S SPECIFICATIONS.
- PROVIDE FIRE ALARM VISUAL/AUDIBLE NOTIFICATION APPLIANCE IN PLACE OF AUDIBLE ONLY DEVICE AT HEARING-IMPAIRED GUEST ROOMS. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF HEARING-IMPAIRED ROOMS.
- VERIFY EXACT HEIGHT AND LOCATION WITH ARCHITECT ELEVATIONS FOR T.V.
- PROVIDE DOORBELL IN HEARING IMPAIRED ROOMS ONLY. REFER TO ARCHITECTURAL DRAWINGS. PROVIDE A SURFACE MOUNT LOW VOLTAGE ILLUMINATED DOOR BELL EQUAL TO EDWARDS #630L. COLOR SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 48" AFF.
- PROVIDE A 120V TO 24V TRANSFORMER FOR DOORBELL & HORN/STROBE. TRANSFORMER EQUAL TO EDWARDS #592. MOUNT ABOVE CORRIDOR CEILING WHERE ACCESSIBLE.
- PROVIDE A FLUSH MOUNTED HORN/STROBE FOR VISUAL AND AUDIBLE NOTIFICATION OF DOOR BELL. DEVICE TO BE EQUAL TO EDWARDS #67STR, 24 VOLT. STROBE COLOR (OTHER THAN RED), SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 90 INCHES AFF.
- PROVIDE DIGITAL THERMOSTAT WITH INTEGRAL OCCUPANCY SENSOR FOR LIGHTING CONTROLS AND PROPERTY MANAGEMENT SYSTEM INTEGRATION. COORDINATE WITH MARRIOTT MECHANICAL STANDARD 15A FOR EXACT REQUIREMENTS PRIOR TO ROUGH-IN. COORDINATE LOCATION WITH ARCHITECT/OWNER PRIOR TO ROUGH-IN.
- PROVIDE FLUSH MOUNTED STUDIO PANEL. REFER TO RISER DIAGRAM FOR ADDITIONAL INFORMATION.
- PROVIDE JUNCTION BOX FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- PROVIDE LIGHT FIXTURE AND ASSOCIATED HARDWARE FOR CLOSET LIGHT. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- PROVIDE JUNCTION BOX FOR WALL MOUNTED LIGHT FIXTURE. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- INSTALL DISCONNECT SWITCH FOR DOORBELL IN HEARING IMPAIRED AND ACCESSIBLE GUESTROOMS. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
- PROVIDE QUAD RECEPTACLE FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- INSTALL RECEPTACLE FOR PHONE CHARGING AREA. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT WITH OWNER PRIOR TO ROUGH-IN.
- PROVIDE JUNCTION BOX AND ALL NECESSARY WIRING/SWITCHING FOR MOTORIZED WINDOW SHEER AND SHADES. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- ALL SLEEPING ROOMS REQUIRE A SOUND LEVEL OF AT LEAST 75dBA AT THE PILLOW LEVEL, IN ADDITION TO THE LOW FREQUENCY SQUARE WAVE OR EQUIVALENT 520HZ +/- 10%. PROVIDE AND INSTALL AS REQUIRED PER NFPA 72 (2013) 18.4.5.1-18.4.5.3



Consulting Engineers

1850 HARWOOD AVE., SUITE 3000
ALTA MONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCENGINEERING.COM
CA NO. 28730




HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAULDIN AVE., SUITE 200, ALTA MONTE SPRINGS, FL 32701
PHONE 407.467.7575 FAX 407.467.2802


TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E4.1
OF



1
TYPICAL KING SUITE LOCKOUT
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"



2
TYPICAL KING SUITE LOCKOUT-ADA TUB
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"




3
TYPICAL KING SUITE LOCKOUT ADA-SHO
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- DO NOT SCALE ELECTRICAL DRAWINGS FOR ANY DIMENSIONS.
- ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- ALL NON-LOCKING, 125V, 15A AND 20A RECEPTACLES INSTALLED IN GUESTROOM UNITS SHALL BE LISTED TAMPER-RESISTANT AS REQUIRED BY NEC 406.12.
- 120V, SINGLE PHASE, 15A AND 20A BRANCH CIRCUITS SUPPLYING OUTLETS INSTALLED IN GUESTROOM UNIT FAMILY ROOMS, DINING ROOMS, LIVING ROOMS, BEDROOMS, SUNROOMS, RECREATIONS ROOMS, CLOSETS, HALLWAYS OR SIMILAR ROOMS OR AREAS SHALL BE PROTECTED BY A LISTED ARC-FAULT CIRCUIT INTERRUPTER, INSTALLED TO PROVIDE PROTECTION OF THE BRANCH CIRCUIT AS REQUIRED BY NEC 210.12 AND LOCAL ORDINANCES.
- PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
- CONTRACTOR SHALL INSTALL RECEPTACLES SUCH THAT RECEPTACLES IN WALLS BETWEEN GUESTROOMS ARE OFFSET HORIZONTALLY BY A MINIMUM OF 6 INCHES.
- WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
- MULTIPLE GROUPINGS OF DEVICES SHALL BE GANGED UNDER THE SAME COVERPLATE. SEPARATE PLATES ARE UNACCEPTABLE EXCEPT IN CASES OF DIMMER SWITCHES ADJACENT TO OTHER LIGHT SWITCHES. IN THAT CASE, PLATES SHALL BE AS CLOSE TOGETHER AS POSSIBLE, PLUMB TRUE FOR A NEAT AND COMPACT ORGANIZED APPEARANCE.
- SEE ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS. THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
- SMOKE ALARMS IN DWELLING UNITS SHALL BE SHALL BE LOW-VOLTAGE, PHOTOELECTRIC SMOKE DETECTORS WITH SOUNDER BASES THAT ARE BOTH POWERED AND MONITORED BY THE FACP PER MARRIOTT'S MODULE 14. AND SHALL BE INSTALLED WITH CLEARANCES IN COMPLIANCE WITH NFPA 72.
- AUDIBLE FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE A SOUND LEVEL OF AT LEAST 85 dBA AT 10 FEET AND 75 dBA AT THE PILLOW AND BE OF A LOW FREQUENCY, SQUARE WAVE SIGNAL 520 HZ (+/-10%), IN ACCORDANCE WITH NFPA 72 SECTIONS 18.4.5.1-18.4.5.3.
- BUILDING FIRE ALARM SYSTEM NOTIFICATION SHALL INCLUDE BE LOW FREQUENCY HORNS IN STANDARD GUESTROOM UNITS AND LOW FREQUENCY HORN/STROBES IN HEARING IMPAIRED (H.I.) GUESTROOMS UNITS. COORDINATE H.I. LOCATIONS WITH ARCHITECTURAL PLANS.
- VISUAL FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE AN INTENSITY LEVEL OF:
 - 110 CD WHERE TOP OF LENS IS INSTALLED GREATER THAN OR EQUAL TO 24 INCHES FROM THE CEILING
 - 177 CD WHERE TOP OF LENS IS INSTALLED LESS THAN 24 INCHES FROM THE CEILINGAND SHALL NOT BE FURTHER THAN 16 FEET FROM THE PILLOW, IN ACCORDANCE WITH NFPA 72 SECTIONS 18.5.5.7.1-18.5.5.7.3.

REFERENCE NOTES: (X)

- INSTALL JUNCTION BOX FOR LIT VANITY MIRROR AT A HEIGHT PER OWNER'S SPECIFICATIONS.
- PROVIDE FIRE ALARM VISUAL/AUDIBLE NOTIFICATION APPLIANCE IN PLACE OF AUDIBLE ONLY DEVICE AT HEARING-IMPAIRED GUEST ROOMS. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF HEARING-IMPAIRED ROOMS.
- VERIFY EXACT HEIGHT AND LOCATION WITH ARCHITECT ELEVATIONS FOR T.V.
- PROVIDE DOORBELL IN HEARING IMPAIRED ROOMS ONLY. REFER TO ARCHITECTURAL DRAWINGS. PROVIDE A SURFACE MOUNT LOW VOLTAGE ILLUMINATED DOOR BELL EQUAL TO EDWARDS #630L. COLOR SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 48" AFF.
- PROVIDE A 120V TO 24V TRANSFORMER FOR DOORBELL & HORN/STROBE. TRANSFORMER EQUAL TO EDWARDS #592. MOUNT ABOVE CORRIDOR CEILING WHERE ACCESSIBLE.
- PROVIDE A FLUSH MOUNTED HORN/STROBE FOR VISUAL AND AUDIBLE NOTIFICATION OF DOOR BELL. DEVICE TO BE EQUAL TO EDWARDS #667STR, 24 VOLT. STROBE COLOR (OTHER THAN RED), SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 90 INCHES AFF.
- PROVIDE DIGITAL THERMOSTAT WITH INTEGRAL OCCUPANCY SENSOR FOR LIGHTING CONTROLS AND PROPERTY MANAGEMENT SYSTEM INTEGRATION. COORDINATE WITH MARRIOTT MECHANICAL STANDARD 15.A FOR EXACT REQUIREMENTS PRIOR TO ROUGH-IN. COORDINATE LOCATION WITH ARCHITECT/OWNER PRIOR TO ROUGH-IN.
- PROVIDE FLUSH MOUNTED STUDIO PANEL. REFER TO RISER DIAGRAM FOR ADDITIONAL INFORMATION.
- PROVIDE JUNCTION BOX FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- PROVIDE LIGHT FIXTURE AND ASSOCIATED HARDWARE FOR CLOSET LIGHT. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- INSTALL RECEPTACLE FOR PHONE CHARGING AREA. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT WITH OWNER PRIOR TO ROUGH-IN.
- INSTALL DISCONNECT SWITCH FOR DOORBELL IN HEARING IMPAIRED AND ACCESSIBLE GUESTROOMS. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
- PROVIDE QUAD RECEPTACLE FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- PROVIDE JUNCTION BOX AND ALL NECESSARY WIRING/SWITCHING FOR MOTORIZED WINDOW SHEER AND SHADES. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- ALL SLEEPING ROOMS REQUIRE A SOUND LEVEL OF AT LEAST 75dBA AT THE PILLOW LEVEL. IN ADDITION TO THE LOW FREQUENCY SQUARE WAVE OR EQUIVALENT 520HZ +/-10%. PROVIDE AND INSTALL AS REQUIRED PER NFPA 72 (2013) 18.4.5.1-18.4.5.3




HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAINTLAND AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.5757 FAX 407.647.2802


TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E4.2
OF




1 TYPICAL QQ STUDIO CENTER
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"



2 TYPICAL QQ STUDIO WIDE
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"



3 TYPICAL QQ STUDIO ADA
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"



4 TYPICAL QQ STUDIO END
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- DO NOT SCALE ELECTRICAL DRAWINGS FOR ANY DIMENSIONS.
- ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- ALL NON-LOCKING, 125V, 15A AND 20A RECEPTACLES INSTALLED IN GUESTROOM UNITS SHALL BE LISTED TAMPER-RESISTANT AS REQUIRED BY NEC 406.1.2.
- 120V, SINGLE PHASE, 15A AND 20A BRANCH CIRCUITS SUPPLYING OUTLETS INSTALLED IN GUESTROOM UNIT FAMILY ROOMS, DINING ROOMS, LIVING ROOMS, BEDROOMS, SUNROOMS, RECREATIONS ROOMS, CLOSETS, HALLWAYS OR SIMILAR ROOMS OR AREAS SHALL BE PROTECTED BY A LISTED ARC-FAULT CIRCUIT INTERRUPTER, INSTALLED TO PROVIDE PROTECTION OF THE BRANCH CIRCUIT AS REQUIRED BY NEC 210.12 AND LOCAL ORDINANCES.
- PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
- CONTRACTOR SHALL INSTALL RECEPTACLES SUCH THAT RECEPTACLES IN WALLS BETWEEN GUESTROOMS ARE OFFSET HORIZONTALLY BY A MINIMUM OF 6 INCHES.
- WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
- MULTIPLE GROUPINGS OF DEVICES SHALL BE GANGED UNDER THE SAME COVERPLATE. SEPARATE PLATES ARE UNACCEPTABLE EXCEPT IN CASES OF DIMMER SWITCHES ADJACENT TO OTHER LIGHT SWITCHES. IN THAT CASE, PLATES SHALL BE AS CLOSE TOGETHER AS POSSIBLE, PLUMB TRUE FOR A NEAT AND COMPACT ORGANIZED APPEARANCE.
- SEE ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS. THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
- SMOKE ALARMS IN DWELLING UNITS SHALL BE SHALL BE LOW-VOLTAGE, PHOTOELECTRIC SMOKE DETECTORS WITH SOUNDER BASES THAT ARE BOTH POWERED AND MONITORED BY THE FACP PER MARRIOTT'S MODULE 14. AND SHALL BE INSTALLED WITH CLEARANCES IN COMPLIANCE WITH NFPA 72.
- AUDIBLE FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE A SOUND LEVEL OF AT LEAST 85 dBA AT 10 FEET AND 75 dBA AT THE PILLOW AND BE OF A LOW FREQUENCY, SQUARE WAVE SIGNAL 520 HZ (+/-10%), IN ACCORDANCE WITH NFPA 72 SECTIONS 18.4.5.1-18.4.5.3.
- BUILDING FIRE ALARM SYSTEM NOTIFICATION SHALL INCLUDE BE LOW FREQUENCY HORNS IN STANDARD GUESTROOM UNITS AND LOW FREQUENCY HORN/STROBES IN HEARING IMPAIRED (H.I.) GUESTROOMS UNITS. COORDINATE H.I. LOCATIONS WITH ARCHITECTURAL PLANS.
- VISUAL FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE AN INTENSITY LEVEL OF:
 - *110 CD WHERE TOP OF LENS IS INSTALLED GREATER THAN OR EQUAL TO 24 INCHES FROM THE CEILING
 - *177 CD WHERE TOP OF LENS IS INSTALLED LESS THAN 24 INCHES FROM THE CEILINGAND SHALL NOT BE FURTHER THAN 16 FEET FROM THE PILLOW, IN ACCORDANCE WITH NFPA 72 SECTIONS 18.5.5.7.1-18.5.5.7.3.

REFERENCE NOTES: (X)


- INSTALL JUNCTION BOX FOR LIT VANITY MIRROR AT A HEIGHT PER OWNER'S SPECIFICATIONS.
- PROVIDE FIRE ALARM VISUAL/AUDIBLE NOTIFICATION APPLIANCE IN PLACE OF AUDIBLE ONLY DEVICE AT HEARING-IMPAIRED GUEST ROOMS. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF HEARING-IMPAIRED ROOMS.
- VERIFY EXACT HEIGHT AND LOCATION WITH ARCHITECT ELEVATIONS FOR T.V.
- PROVIDE DOORBELL IN HEARING IMPAIRED ROOMS ONLY. REFER TO ARCHITECTURAL DRAWINGS. PROVIDE A SURFACE MOUNT LOW VOLTAGE ILLUMINATED DOOR BELL EQUAL TO EDWARDS #630L. COLOR SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 48" AFF.
- PROVIDE A 120V TO 24V TRANSFORMER FOR DOORBELL & HORN/STROBE. TRANSFORMER EQUAL TO EDWARDS #592. MOUNT ABOVE CORRIDOR CEILING WHERE ACCESSIBLE.
- PROVIDE A FLUSH MOUNTED HORN/STROBE FOR VISUAL AND AUDIBLE NOTIFICATION OF DOOR BELL. DEVICE TO BE EQUAL TO EDWARDS #667STR, 24 VOLT. STROBE COLOR (OTHER THAN RED), SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 90 INCHES AFF.
- PROVIDE DIGITAL THERMOSTAT WITH INTEGRAL OCCUPANCY SENSOR FOR LIGHTING CONTROLS AND PROPERTY MANAGEMENT SYSTEM INTEGRATION. COORDINATE WITH MARRIOTT MECHANICAL STANDARD 15.A FOR EXACT REQUIREMENTS PRIOR TO ROUGH-IN. COORDINATE LOCATION WITH ARCHITECT/OWNER PRIOR TO ROUGH-IN.
- PROVIDE FLUSH MOUNTED STUDIO PANEL. REFER TO RISER DIAGRAM FOR ADDITIONAL INFORMATION.
- PROVIDE JUNCTION BOX FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- PROVIDE LIGHT FIXTURE AND ASSOCIATED HARDWARE FOR CLOSET LIGHT. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- PROVIDE JUNCTION BOX FOR WALL MOUNTED LIGHT FIXTURE. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- INSTALL DISCONNECT SWITCH FOR DOORBELL IN HEARING IMPAIRED AND ACCESSIBLE GUESTROOMS. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
- PROVIDE QUAD RECEPTACLE FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- INSTALL RECEPTACLE FOR PHONE CHARGING AREA. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT WITH OWNER PRIOR TO ROUGH-IN.
- PROVIDE JUNCTION BOX AND ALL NECESSARY WIRING/SWITCHING FOR MOTORIZED WINDOW SHEER AND SHADES. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- ALL SLEEPING ROOMS REQUIRE A SOUND LEVEL OF AT LEAST 75dBA AT THE PILLOW LEVEL, IN ADDITION TO THE LOW FREQUENCY SQUARE WAVE OR EQUIVALENT 520HZ +/- 10%. PROVIDE AND INSTALL AS REQUIRED PER NFPA 72 (2013) 18.4.5.1-18.4.5.3



Consulting Engineers

1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JL&C.COM
CA NO. 28730

JLC 21.0042.00



AA C000606

HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAINTENANCE SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.3750 FAX 407.647.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION


JOB NO.

DATE

SHEET

E4.3

OF




1 TYPICAL QUEEN SUITE LOCKOUT - ADA-TUB
ENLARGED UNIT FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- DO NOT SCALE ELECTRICAL DRAWINGS FOR ANY DIMENSIONS.
- ALL WORK SHALL COMPLY WITH THE 2014 NATIONAL ELECTRIC CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- ALL NON-LOCKING, 125V, 15A AND 20A RECEPTACLES INSTALLED IN GUESTROOM UNITS SHALL BE LISTED TAMPER-RESISTANT AS REQUIRED BY NEC 406.12.
- 120V, SINGLE PHASE, 15A AND 20A BRANCH CIRCUITS SUPPLYING OUTLETS INSTALLED IN GUESTROOM UNIT FAMILY ROOMS, DINING ROOMS, LIVING ROOMS, BEDROOMS, SUNROOMS, RECREATIONS ROOMS, CLOSETS, HALLWAYS OR SIMILAR ROOMS OR AREAS SHALL BE PROTECTED BY A LISTED ARC-FAULT CIRCUIT INTERRUPTER, INSTALLED TO PROVIDE PROTECTION OF THE BRANCH CIRCUIT AS REQUIRED BY NEC 210.12 AND LOCAL ORDINANCES.
- PROVIDE A GREEN EQUIPMENT GROUND WIRE IN BRANCH CIRCUIT AND FEEDER CONDUITS.
- CONTRACTOR SHALL INSTALL RECEPTACLES SUCH THAT RECEPTACLES IN WALLS BETWEEN GUESTROOMS ARE OFFSET HORIZONTALLY BY A MINIMUM OF 6 INCHES.
- WIRING SHALL BE PROVIDED TO DEVICES SHOWN, UNLESS OTHERWISE INDICATED. MINIMUM WIRING SIZE SHALL BE #12 AWG. AMPACITY, DERATING AND CONDUIT FILL SHALL BE AS REQUIRED BY THE NEC.
- MULTIPLE GROUPINGS OF DEVICES SHALL BE GANGED UNDER THE SAME COVERPLATE. SEPARATE PLATES ARE UNACCEPTABLE EXCEPT IN CASES OF DIMMER SWITCHES ADJACENT TO OTHER LIGHT SWITCHES. IN THAT CASE, PLATES SHALL BE AS CLOSE TOGETHER AS POSSIBLE, PLUMB TRUE FOR A NEAT AND COMPACT ORGANIZED APPEARANCE.
- SEE ARCHITECTURAL ELEVATIONS AND DETAILS FOR EXACT LOCATIONS OF ELECTRICAL ITEMS. THESE SHALL TAKE PRECEDENCE OVER ANY INDICATIONS IN ELECTRICAL CONSTRUCTION DOCUMENTS.
- SMOKE ALARMS IN DWELLING UNITS SHALL BE SHALL BE LOW-VOLTAGE, PHOTOELECTRIC SMOKE DETECTORS WITH SOUNDER BASES THAT ARE BOTH POWERED AND MONITORED BY THE FACP PER MARRIOTT'S MODULE 14. AND SHALL BE INSTALLED WITH CLEARANCES IN COMPLIANCE WITH NFPA 72.
- AUDIBLE FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE A SOUND LEVEL OF AT LEAST 85 dBA AT 10 FEET AND 75 dBA AT THE PILLOW AND BE OF A LOW FREQUENCY, SQUARE WAVE SIGNAL 520 HZ (+/-10%), IN ACCORDANCE WITH NFPA 72 SECTIONS 18.4.5.1-18.4.5.3.
- BUILDING FIRE ALARM SYSTEM NOTIFICATION SHALL INCLUDE BE LOW FREQUENCY HORNS IN STANDARD GUESTROOM UNITS AND LOW FREQUENCY HORN/STROBES IN HEARING IMPAIRED (H.I.) GUESTROOMS UNITS. COORDINATE H.I. LOCATIONS WITH ARCHITECTURAL PLANS.
- VISUAL FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE AN INTENSITY LEVEL OF:
 - 110 CD WHERE TOP OF LENS IS INSTALLED GREATER THAN OR EQUAL TO 24 INCHES FROM THE CEILING
 - 177 CD WHERE TOP OF LENS IS INSTALLED LESS THAN 24 INCHES FROM THE CEILINGAND SHALL NOT BE FURTHER THAN 16 FEET FROM THE PILLOW, IN ACCORDANCE WITH NFPA 72 SECTIONS 18.5.5.7.1-18.5.5.7.3.


REFERENCE NOTES: (X)

- INSTALL JUNCTION BOX FOR LIT VANITY MIRROR AT A HEIGHT PER OWNER'S SPECIFICATIONS.
- PROVIDE FIRE ALARM VISUAL/AUDIBLE NOTIFICATION APPLIANCE IN PLACE OF AUDIBLE ONLY DEVICE AT HEARING-IMPAIRED GUEST ROOMS. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF HEARING-IMPAIRED ROOMS.
- VERIFY EXACT HEIGHT AND LOCATION WITH ARCHITECT ELEVATIONS FOR T.V.
- PROVIDE DOORBELL IN HEARING IMPAIRED ROOMS ONLY. REFER TO ARCHITECTUAL DRAWINGS. PROVIDE A SURFACE MOUNT LOW VOLTAGE ILLUMINATED DOOR BELL EQUAL TO EDWARDS #630L. COLOR SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 48" AFF.
- PROVIDE A 120V TO 24V TRANSFORMER FOR DOORBELL & HORN/STROBE. TRANSFORMER EQUAL TO EDWARDS #592. MOUNT ABOVE CORRIDOR CEILING WHERE ACCESSIBLE.
- PROVIDE A FLUSH MOUNTED HORN/STROBE FOR VISUAL AND AUDIBLE NOTIFICATION OF DOOR BELL. DEVICE TO BE EQUAL TO EDWARDS #667STR, 24 VOLT. STROBE COLOR (OTHER THAN RED), SHALL BE SPECIFIED BY ARCHITECT. MOUNT AT 90 INCHES AFF.
- PROVIDE DIGITAL THERMOSTAT WITH INTEGRAL OCCUPANCY SENSOR FOR LIGHTING CONTROLS AND PROPERTY MANAGEMENT SYSTEM INTEGRATION. COORDINATE WITH MARRIOTT MECHANICAL STANDARD 15.A FOR EXACT REQUIREMENTS PRIOR TO ROUGH-IN. COORDINATE LOCATION WITH ARCHITECT/OWNER PRIOR TO ROUGH-IN.
- PROVIDE FLUSH MOUNTED STUDIO PANEL. REFER TO RISER DIAGRAM FOR ADDITIONAL INFORMATION.
- PROVIDE JUNCTION BOX FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- PROVIDE LIGHT FIXTURE AND ASSOCIATED HARDWARE FOR CLOSET LIGHT. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- PROVIDE JUNCTION BOX FOR WALL MOUNTED LIGHT FIXTURE. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- INSTALL DISCONNECT SWITCH FOR DOORBELL IN HEARING IMPAIRED AND ACCESSIBLE GUESTROOMS. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
- PROVIDE QUAD RECEPTACLE FOR MILLWORK LIGHTING. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH MILLWORK PROVIDER PRIOR TO ROUGH-IN.
- INSTALL RECEPTACLE FOR PHONE CHARGING AREA. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT WITH OWNER PRIOR TO ROUGH-IN.
- PROVIDE JUNCTION BOX AND ALL NECESSARY WIRING/SWITCHING FOR MOTORIZED WINDOW SHEER AND SHADES. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER AND EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- ALL SLEEPING ROOMS REQUIRE A SOUND LEVEL OF AT LEAST 75dBA AT THE PILLOW LEVEL, IN ADDITION TO THE LOW FREQUENCY SQUARE WAVE OR EQUIVALENT 520HZ +/- 10%. PROVIDE AND INSTALL AS REQUIRED PER NFPA 72 (2013) 18.4.5.1-18.4.5.3



Consulting Engineers

1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JL&C.COM
CA NO. 28730



AA C000606

HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
577 MAULDIN AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.7575 FAX 407.647.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION


JOB NO.

DATE


SHEET

E4.4

OF



1 ENLARGED PLAN - MECH/PBX
SCALE: 1/4" = 1'-0"



2 ENLARGED PLAN - ELECTRICAL ROOM
SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRICAL CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.

REFERENCE NOTES: (X)

- (1) ELECTRICAL CONTRACTOR SHALL COORDINATE DISCONNECT AND FUSE REQUIREMENTS FOR MECHANICAL UNIT WITH MECHANICAL CONTRACTOR AND EQUIPMENT MANUFACTURER PRIOR TO ROUGH-IN AND PROVIDE AS REQUIRED.
- (2) 2#10, 1#10GND, IN 1/2" C. TO RESPECTIVE EXTERIOR CONDENSER UNIT. COORDINATE EXACT REQUIREMENTS WITH DIVISION 15. PRIOR TO ROUGH-IN.
- (3) ELECTRICAL CONTRACTOR SHALL PROVIDE (1) 8"X8" JUNCTION BOX WITH COVERPLATE ON EACH FLOOR OF BUILDING FOR FUTURE DAS SYSTEM IF REQUIRED. PROVIDE 2" C. (EMPTY W/ PULLSTRING) BETWEEN ALL JUNCTION BOXES FOR FUTURE DAS SYSTEM WIRING. COORDINATE LOCATION OF JUNCTION BOXES WITH OWNER AND FIRE ALARM CONTRACTOR PRIOR TO ROUGH-IN. LABEL ALL JUNCTION BOXES, COVERPLATE AND CONDUIT AS REQUIRED FOR FUTURE IDENTIFICATION.

AA C000606

HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MAINTENANCE SUITE 200, LAKE CITY, FLORIDA, FL 32701
PHONE 407.647.5757 FAX 407.647.2802

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION


JOB NO.

DATE

SHEET

E5.1


OF




Consulting Engineers

1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JL&C.COM
CA NO. 28730

JLC 21.0042.00





1 ENLARGED PLAN - FOOD PREP/BUFFET
SCALE: 1/4" = 1'-0"

EQUIPMENT SCHEDULE – FOODSERVICE

MARK	QTY.	DESCRIPTION	COMMENTS	LOCATION
023	3	Shelving – Dry Storage		Kitchen
033	1	Spray Rinse		Kitchen
038	1	Dishwasher – Undercounter		Kitchen
041	1	Pot Rack with Shelf		Kitchen
046	1	Pot Sink		Kitchen
050	1	Freezer – Two–Door Reach–In		Kitchen
052	1	Refrigerator – Two–Door Reach–In		Kitchen
053	1	Freezer – Single–Door Reach–In		Kitchen
059	1	Refrigerator – Compact		Kitchen
063	1	Table – Prep with Backsplash		Kitchen
093	1	Dry Cereal Display	By Operator, NIKEC	Buffet
094	1	Oatmeal Cooker		Buffet
099	2	Induction Warmers		Buffet
100	1	Plate Unit	Not Shown	Buffet
105	1	Coffee Airpot Brewer	By Operator, NIKEC	Kitchen
105A	Lot	Coffee Airpots	By Operator, NIKEC	On Us
111	1	Microwave Oven		Kitchen
112	1	Microwave Shelf		Kitchen
114	2	Waffle Irons	By Vendor, NIKEC; For Weekends	Buffet
117	1	Toaster	Alternate to Item 148; Not Shown	Buffet
118	1	Juice Chiller	By Vendor, NIKEC	Buffet
119	Lot	Garbage Cans	By Operator, NIKEC	Buffet
119	Lot	Garbage Cans	By Operator, NIKEC	Kitchen
122	2	Waffle Irons	By Vendor, NIKEC; Alt. to 114	Buffet
123	1	Hand Lavatory	With Eyewash	Kitchen
140	2	Bread Display	By Operator, NIKEC	Buffet
143	1	Counter Refrigerator		Buffet
148	1	Slot Toaster		Buffet
151	Lot	Buffet – Counter	Architectural Woodwork	Buffet
155	Lot	Buffet – Waste Chute		Buffet
551	1	Ice Maker/Dispenser – Vending	Not Shown	Vending

NIKEC – Not in Kitchen Equipment Contract

GENERAL NOTES:


- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRICAL CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- C. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- D. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.

GENERAL KITCHEN NOTES:

- A. REFER TO "KITCHEN EQUIPMENT SCHEDULE" FOR DESCRIPTION AND POWER REQUIREMENTS OF EACH DEVICE IN KITCHEN. COORDINATE EXACT LOCATION OF ALL JUNCTION BOXES, RECEPTACLES, ETC. WITH KITCHEN EQUIPMENT VENDOR PRIOR TO ROUGH-IN.
- B. ALL 15AMP & 20AMP RECEPTACLES IN KITCHEN AND BAR AREA SHALL BE GFCI PROTECTED PER NEC 210.8(B)2.
- C. DIVISION 16 CONTRACTOR SHALL MAKE ALL FINAL CONNECTIONS TO KITCHEN EQUIPMENT, FURNISH AND INSTALL ALL JUNCTION BOXES, RECEPTACLES, COVER PLATES, PULL BOXES, CONDUIT AND WIRING AS REQUIRED. COORDINATE WITH FOOD SERVICE DRAWINGS AND MANUFACTURER'S INSTRUCTIONS FOR LOCATION OF ALL EQUIPMENT CONNECTION LOCATIONS AND REQUIREMENTS.
- D. DIVISION 16 CONTRACTOR SHALL PULL ALL LOW VOLTAGE WIRING FOR POS SYSTEM, PHONE, AND SECURITY CAMERAS. COORDINATE WITH OWNER'S VENDOR
- E. FLEXIBLE CONDUIT INSTALLED IN KITCHEN FOR FINAL EQUIPMENT CONNECTION SHALL BE LIQUID TIGHT CONDUIT WITH NEOPRENE JACKET.
- F. INTERCONNECT DEFROST TIMERS ON WALK-IN EVAPORATOR COILS TO REMOTE COMPRESSORS PER MANUFACTURER'S INSTRUCTIONS.
- G. ENCLOSURES FOR ALL ELECTRICAL PANELS, CIRCUIT BREAKER ENCLOSURES, DISCONNECT SWITCHES, WALL SWITCHES, CONTACTOR ENCLOSURES, PUSHBUTTONS, ETC WITHIN KITCHEN AREA SHALL BE FOOD GRADE, RECESSED MOUNTED, UNLESS OTHERWISE NOTED.

REFERENCE NOTES: (X)

- (1) ELECTRICAL CONTRACTOR SHALL COORDINATE DISCONNECT AND FUSE REQUIREMENTS FOR MECHANICAL UNIT WITH MECHANICAL CONTRACTOR AND EQUIPMENT MANUFACTURER PRIOR TO ROUGH-IN AND PROVIDE AS REQUIRED.
- (2) LOCATE HOUSE PHONES 12" FROM DOOR U.O.D., 56" AFF (TYPICAL).



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MATLAIN AVE., SUITE 200, ALTA MONTE SPRINGS, FL 32701
PHONE 407.447.5757 FAX 407.447.2862

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION


JOB NO.

DATE


SHEET

E5.2


OF



4 ENLARGED PLAN - FIFTH FLOOR ELECTRICAL ROOM
SCALE: 1/2" = 1'-0"



2 ENLARGED PLAN - FIFTH FLOOR ELEVATOR
SCALE: 1/2" = 1'-0"




3 ENLARGED PLAN - FIRST FLOOR ELEVATOR
SCALE: 1/2" = 1'-0"

GENERAL NOTES:


- DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRICAL CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH IN.

REFERENCE NOTES: (X)

- REFER TO ELEVATOR SHOP DRAWINGS FOR EXACT LOCATIONS OF ELECTRICAL WORK IN ELEVATOR PIT AND MACHINE ROOM. PROVIDE CONNECTION SWITCHES, LIGHTS AND RECEPTACLES AS PER NEC 620.23 AND 24. CONNECT FIRE ALARM AND TELEPHONE DEVICES IN ELEVATOR SHAFT LOBBY AND EQUIPMENT ROOM PER STATE FIRE MARSHALL REQUIREMENTS.
- PROVIDE LOCKABLE RK5 DISCONNECT SWITCH WITH 20A AUXILIARY CONTACTS. REJECTION CLIPS AND RK5 FUSES AS REQUIRED BY ELEVATOR INSTALLER. CONNECT ELEVATOR CONTROLLER. REFER TO PANEL SCHEDULES FOR ADDITIONAL INFORMATION.
- 30A, 120V LOCKABLE DISCONNECT SWITCH WITH REJECTION CLIPS AND 20A RK5 FUSE. LABEL "ELEVATOR CAB LIGHTS". CONNECT ELEVATOR CONTROLLERS: (2)#12 AND (1)#12 GND. IN 1/2"C.
- ELEVATOR CAB TELEPHONE. COORDINATE WITH ELEVATOR CONTRACTOR PRIOR TO ROUGH-IN.
- COORDINATE DISCONNECT SIZE, BREAKER SIZE, AND CONDUIT/CONDUCTOR SIZING WITH APPROVED ELEVATOR SHOP DRAWINGS AND PROVIDE AS REQUIRED.
- MOUNT HEAT DETECTOR WITHIN 18" OF FIRE PROTECTION SPRINKLER HEAD. FIELD COORDINATE PRIOR TO ROUGH-IN.
- CONNECT ELEVATOR SHAFT LIGHTING ON TOP FLOOR TO ELEVATOR PIT LIGHTING ON FIRST FLOOR. FIXTURES TO BE CONTROLLED BY 3-WAY SWITCH AS SHOWN ON PLANS.
- ELEVATOR RECALL CONTROL MODULES. COORDINATE WITH ELEVATOR CONTRACTOR PRIOR TO ROUGH-IN.
- ELEVATOR POWER SHUTDOWN CONTROL MODULE.
- ELEVATOR POWER SHUTDOWN CONTROL CIRCUIT SUPERVISORY MONITOR MODULE.
- ELEVATOR PHASE 1 EMERGENCY RECALL VISUAL SIGNAL CONTROL MODULE. COORDINATE TERMINATION REQUIREMENTS WITH ELEVATOR CONTROLLER.
- PROVIDE AREA OF REFUGE TWO-WAY COMMUNICATION SYSTEM AND CABLING TO MAIN BASE STATION AS REQUIRED BY 2015 IBC AND LIFE SAFETY CODE. COORDINATE LOCATION WITH OWNER AND AUTHORITY HAVING JURISDICTION PRIOR TO ROUGH-IN.
- ELECTRICAL CONTRACTOR TO PROVIDE JUNCTION BOX AND ROUGH-IN FOR SOUND SYSTEM SPEAKER. SPEAKER TO BE MOUNTED IN ELEVATOR CAB. COORDINATE LOCATION AND REQUIREMENTS WITH ELEVATOR PROVIDER AND SPEAKER SYSTEM INSTALLER PRIOR TO ROUGH-IN.



Consulting Engineers
1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.J&CENG.COM
CA NO. 28730



HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
577 MATLAND AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.5757 FAX 407.647.2862

TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E5.3
OF

GENERAL NOTES:

- A. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE LATEST ADOPTED VERSION OF THE NATIONAL ELECTRICAL CODE AS WELL AS NATIONAL, STATE, AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- C. COORDINATE ALL WORK WITH LOCAL UTILITY COMPANY PRIOR TO ROUGH-IN.
- D. SEE SINGLE LINE DIAGRAM FOR FEEDER WIRE AND CONDUIT SIZE. ALL CIRCUITS NOT SIZED ON DRAWING SHALL BE INSTALLED TO MEET MINIMUM SIZE REQUIRED BY NEC. ALL CONDUCTORS SHALL HAVE AN EQUIPMENT GROUND WIRE SIZED PER NEC.
- E. FIELD VERIFY EXACT LOCATION OF ALL DEVICES AND EQUIPMENT PRIOR TO ROUGH-IN.
- F. PER (FEC C405.6.3 2017ed); ALL CONDUCTORS FOR FEEDERS AND BRANCH CIRCUITS ARE DESIGNED FOR A MAXIMUM OF 5% VOLTAGE DROP TOTAL.
- G. FOR ALL EXISTING EQUIPMENT BEING RECONNECTED TO NEW PANELS AND EXISTING EQUIPMENT TO REMAIN, E.C. SHALL CONFIRM THAT BREAKER AND FEEDER SIZES ARE CORRECTLY MATCHED UP TO THE EQUIPMENT LOADS SHOWN ON THE EQUIPMENT NAMEPLATE.
- H. CONTRACTOR SHALL PROVIDE "ARC FLASH/SHOCK HAZARD" SIGNAGE FOR ALL PANELBOARDS AS REQUIRED PER ANSI, NEC, OSHA AND NFPA. INCLUDE ALL INFORMATION PER LATEST REQUIREMENTS INCLUDING REQUIRED LEVEL OF PPE, AVAILABLE FAULT CURRENT, APPROACH BOUNDARIES, ETC.
- I. PER NEC 110.24 SERVICE EQUIPMENT IN OTHER THAN DWELLING UNITS SHALL BE LEGIBLY MARKED IN THE FIELD WITH THE MAXIMUM AVAILABLE FAULT CURRENT. THE FIELD MARKING(S) SHALL INCLUDE THE DATE THE FAULT CURRENT CALCULATION WAS PERFORMED AND BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED. WHEN MODIFICATIONS TO THE ELECTRICAL INSTALLATION OCCUR THAT AFFECT THE MAXIMUM AVAILABLE FAULT CURRENT AT THE SERVICE, THE MAXIMUM AVAILABLE FAULT CURRENT SHALL BE VERIFIED OR RECALCULATED AS NECESSARY TO ENSURE THE SERVICE EQUIPMENT RATINGS ARE SUFFICIENT FOR THE MAXIMUM AVAILABLE FAULT CURRENT AT THE LINE TERMINALS OF THE EQUIPMENT. THE REQUIRED FIELD MARKING(S) IN 110.24(A) SHALL BE ADJUSTED TO REFLECT THE NEW LEVEL OF MAXIMUM AVAILABLE FAULT CURRENT.


REFERENCE NOTES: (X)

- (1) PROVIDE SURGE PROTECTIVE DEVICE OF SAME MANUFACTURER AS SWITCHBOARD.
- (2) PROVIDE 4" CONCRETE HOUSEKEEPING PAD.
- (3) BREAK GLASS TYPE SHUNT TRIP MOUNTED ON BUILDING EXTERIOR. REFER TO FLOOR PLANS FOR EXACT LOCATION. PROVIDE CONDUIT AND CONTROL WIRING AS REQUIRED TO SHUNT BOTH MAIN DISTRIBUTION PANEL WITH SINGLE BUTTON.
- (4) COORDINATE METER BASE AND POST REQUIREMENTS WITH LOCAL UTILITY COMPANY.
- (5) COORDINATE UTILITY TRANSFORMER AND ASSOCIATED CONCRETE PAD REQUIREMENTS WITH LOCAL UTILITY COMPANY.
- (6) #3/0 AWG CU. GROUND WIRE TO SYSTEM GROUND BUS BAR LOCATED IN ENGINEERING/COMMUNICATIONS ROOM.
- (7) PROVIDE NEMA 3R RATED, 120/208VOLT, 3A, 4W, 100AMP, PANEL (MINIMUM 22KAC) FOR CONNECTION OF POOL EQUIPMENT. COORDINATE EXACT REQUIREMENTS WITH POOL EQUIPMENT SUPPLIER PRIOR TO ORDERING/ROUGH-IN.



Power Riser Diagram
No Scale

CONDUCTOR SIZES



UNIT FEEDER SCHEDULE

208V/1PH RESIDENTIAL LOAD CENTERS		
UNIT LOAD CENTER	MAXIMUM DISTANCE (FEET)	MINIMUM FEEDER SIZE (ALUMINUM SER CABLE)
125A	135	(3) #2/0 AWG AL & (1) #1 AWG AL GRD
	170	(3) #3/0 AWG AL & (1) #1/0 AWG AL GRD
	215	(3) #4/0 AWG AL & (1) #2/0 AWG AL GRD

NOTES:
1. FEEDER SIZES BASED ON NEC TABLE 310.15(B)(16) 75°C COLUMN.
2. FEEDER SIZES BASED ON 5% VOLTAGE DROP.
3. BASIS OF DESIGN: SOUTHWEST SERVICE ENTRANCE CABLE - TYPE SER THREE CONDUCTOR WITH BARE GROUND.

AA C000606

HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
577 MATLAND AVE., SUITE 300, LAKE CITY, FLORIDA, 32701
PHONE 407.647.3797 FAX 407.647.2602

TOWNEPLACE
SUITES
BY MARIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCIAL DRIVE, LAKE CITY, FLORIDA

REVISION


JOB NO.

DATE

SHEET


E6.1

OF



Consulting Engineers
1850 HAWWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCENG.COM
C.A. NO. 28730

JLC 21.0042.00



F.A.C. 61G15-32.008 DESIGN OF FIRE ALARMS & DETECTION SYSTEMS

61G15-32.008 DESIGN OF FIRE ALARM AND DETECTION SYSTEM COMPLIANCE NOTES FOR APARTMENTS AND CLUBHOUSE:

APPLICABLE CODES: FBC FLORIDA BUILDING CODE (2020) 7TH EDITION
FFPC FLORIDA FIRE PREVENTION CODE (2018) 7TH EDITION
• NFPA 1 FIRE CODE (2019) FLORIDA EDITION
• NFPA 101 LIFE SAFETY CODE (2018) FLORIDA EDITION
NFPA 70 NATIONAL ELECTRICAL CODE (2017)
NFPA 72 NATIONAL FIRE ALARM & SIGNALING CODE (2016)
AHJ - LAKE CITY, FLORIDA - LOCAL CODES & AMENDMENTS

(4) ENSURE MINIMUM DESIGN QUALITY OF FIRE ALARM SYSTEM AS FOLLOWS

A. DESIGN INTENT

1. SYSTEM TYPE: MASTER FIRE ALARM CONTROL PANEL LOCATED IN CLUBHOUSE SHALL BE AN ADDRESSABLE PANEL BY EDWARDS, HONEYWELL, NOTIFIER, SILENT KNIGHT, OR APPROVED EQUIVALENT. SUB-PANEL FACP'S IN EACH APARTMENT BUILDING SHALL BE ADDRESSABLE TYPES.
2. SEE SYMBOL LEGEND ON THIS SHEET.
3. SEE FIRE ALARM RISER DIAGRAM(S) THIS SHEET.
4. CABLING REQUIREMENTS:
 - a. WIRING METHOD: THE SYSTEM WILL BE FREE WIRED USING APPROPRIATE STRAPS, TIES, FITTINGS, ETC. TO PREVENT DAMAGE TO THE WIRING.
 - b. INITIATION CIRCUITS (LOOP): INITIATION LOOP CONDUCTORS SHALL BE WEST PENN #8991 FOR 3000'0" IN LENGTH AND LESS. WEST PENN #8995 SHALL BE USED FOR CIRCUITS OVER 3000'0" IN LENGTH. BELOW GRADE, WET OR DAMP LOCATION INSTALLED CABLE, INCLUDING CABLE INSTALLED ON THE TOP OF EXTERIOR WALKWAYS, SHALL BE WEST PENN AQUASEAL MULTI-CONDUCTOR (14 GAUGE), UNLESS NOTED OTHERWISE, SHALL BE INSTALLED IN CONDUIT.
 - c. SIGNAL CIRCUITS: SIGNAL CIRCUITS SHALL BE #14 AWG THWN 19 STRAND COPPER (USE #12 AWG IF VOLTAGE DROP EXCEEDS MANUFACTURER'S SPECIFICATIONS).
 - d. ANNUNCIATOR CIRCUITS: #14 AWG THWN 19 STRAND COPPER (USE #12 AWG IF VOLTAGE DROP EXCEEDS MANUFACTURER'S SPECIFICATIONS).
5. EACH AND EVERY WIRE SHALL BE LABELED AT EACH END WITH SLC #, CHANNEL # OR SIGNAL #. EACH SEPARATE CIRCUIT, INITIATION, SIGNAL AND AUXILIARY SHALL HAVE A SPECIFIC NUMBER. LABEL EACH CONDUCTOR BY THIS CIRCUIT NUMBER AT THE CONTROL CONNECTIONS AND AT EACH TERMINAL CONNECTION IN THE TERMINAL CABINETS.
5. FIRE RATINGS REQUIRED FOR SURVIVABILITY: UNLESS NOTED OTHERWISE, PATHWAY SURVIVABILITY SHALL BE LEVEL 0 OR 1.
6. GENERAL OCCUPANCY OF PROTECTED PROPERTY: R-1, R-2, R-3, R-4, BUSINESS (XX PERSONS), FITNESS (XX PERSONS).

B. DEVICE LOCATIONS AND RELATED SYSTEMS

1. ALL INITIATION AND NOTIFICATION DEVICES ARE SHOWN ON ELECTRICAL POWER AND SYSTEMS PLANS WITHIN THIS ELECTRICAL DRAWING SET.
2. CONNECTIONS TO OTHER SYSTEMS: PROVIDE RELAYS FOR OTHER LOCAL CONTROL SUCH AS HVAC SHUTDOWN AND FIRE/SMOKE DAMPER RELEASE. RELAYS SHALL BE 10 AMP RATED RELAYS. UPON ACTIVATION OF THE FIRE ALARM SYSTEM, THE RELAY SHALL ACTIVATE AND SHUTDOWN THE CONTROLLED EQUIPMENT. LOCATE ALL RELAYS WITHIN 36" OF EQUIPMENT CONTROLLED. PROVIDE WEATHERPROOF UNITS WHERE INDICATED OR INSTALL IN WEATHERPROOF BOXES.

C. STROBE INTENSITY AND SPEAKER OUTPUT RATINGS

1. PER NFPA 72 SECTION 18.4.3 AUDIBLE SIGNALS SHALL BE AT LEAST 15dB ABOVE AVERAGE AMBIENT SOUND LEVEL OR 5dB ABOVE MAXIMUM SOUND LEVEL, WHICHEVER IS GREATER.
 2. ALL VISUAL NOTIFICATION DEVICES SHALL HAVE CANDELA RATINGS AS INDICATED ON PLAN SHEET(S). PER NFPA 72 SECTION 18.5.5.4.
 3. AUDIBLE APPLIANCES FOR SLEEPING AREAS SHALL PREVIOUSLY A LOW FREQUENCY ALARM SIGNAL THAT COMPLIES WITH NFPA SECTION 18.4.5.3.
 4. VISUAL FIRE ALARM NOTIFICATION APPLIANCES LOCATED IN SLEEPING AREAS SHALL HAVE AN INTENSITY LEVEL OF:
 - 110 CD WHERE TOP OF LENS IS INSTALLED GREATER THAN OR EQUAL TO 24 INCHES FROM THE CEILING
 - 177 CD WHERE TOP OF LENS IS INSTALLED LESS THAN 24 INCHES FROM THE CEILING
- AND SHALL NOT BE FURTHER THAN 16 FEET FROM THE PILLOW, IN ACCORDANCE WITH NFPA 72 SECTIONS 18.5.5.7.1-18.5.5.7.3.

D. CIRCUIT CLASSES

INITIATING DEVICE CIRCUITS - CLASS B. SIGNALING LINE CIRCUITS - CLASS B. NOTIFICATION APPLIANCE CIRCUIT - CLASS B.

E. FUNCTIONS - SEE FIRE ALARM MATRIX OF OPERATIONS THIS SHEET.

F. FIRE ALARM TYPE AND ZONING

1. FIRE ALARM SYSTEM IS AN ADDRESSABLE TYPE. SUB-PANELS ARE ADDRESSABLE TYPE.
2. INITIATING DEVICES SHALL BE ZONED BY BUILDING/FLOOR.
3. EVACUATION SIGNALS SHALL BE ZONED BY BUILDING.

G. SURGE PROTECTION

DITEX SURGE PROTECTION DEVICES DEVICES SHALL BE PROVIDED AT EACH CONNECTION TO MAIN POWER AND WHERE A CIRCUIT ENTERS/EXITS THE BUILDING. ALL SURGE/TRANSIENT SUPPRESSORS MUST BE CONNECTED TO APPROVED BUILDING GROUND.

H. ENVIRONMENTAL FACTORS

NO SPECIAL ENVIRONMENTAL FACTORS APPLY. FIRE ALARM DEVICES AND EQUIPMENT TO BE INSTALLED OUTDOORS IN EXTERIOR LOCATIONS SHALL BE SPECIFICALLY DESIGNED AND U.L. LISTED AS WEATHERPROOF AND WATERPROOF.

I. SITE PLAN

AN ELECTRICAL SITE PLAN HAS BEEN PROVIDED ON SHEET E1.01 INDICATING THE LOCATIONS OF MASTER FACP IN CLUBHOUSE AND SUB PANEL FACP'S IN APARTMENT BUILDINGS.

J. AREA SMOKE DETECTION

1. WHERE SMOKE DETECTORS ARE USED TO PROVIDE AREA COVERAGE, THEY SHALL BE LOCATED IN ACCORDANCE WITH NFPA 72 SECTION 17.7.3 "LOCATION AND SPACING" AND NFPA SECTION 29.8.4 "SPECIFIC LOCATION REQUIREMENTS" FOR THE APPLICABLE CONDITIONS.
2. SMOKE ALARMS AND SMOKE DETECTORS SHALL NOT BE LOCATED WHERE AMBIENT CONDITIONS, INCLUDING HUMIDITY AND TEMPERATURE, ARE OUTSIDE THE LIMITS SPECIFIED BY THE MANUFACTURER'S PUBLISHED INSTRUCTIONS.
3. SMOKE ALARMS AND SMOKE DETECTORS SHALL NOT BE LOCATED WITHIN UNFINISHED ATTICS OR GARAGES OR IN OTHER SPACES WHERE TEMPERATURES CAN FALL BELOW 40°F OR EXCEED 100°F.
4. SMOKE ALARMS AND SMOKE DETECTORS SHALL NOT BE INSTALLED WITHIN 10 FT FROM A STATIONARY OR FIXED COOKING APPLIANCE, UNLESS LISTED FOR INSTALLATION IN CLOSE PROXIMITY TO COOKING APPLIANCES OR MEETING THE ADDITIONAL CRITERIA LIST IN SECTION 29.8.3.4(4).
5. SMOKE ALARMS AND SMOKE DETECTORS SHALL NOT BE INSTALLED WITHIN 3 FT FROM THE FOLLOWING: A DOOR TO A BATHROOM CONTAINING A SHOWER OR TUB, SUPPLY AIR REGISTERS, AND/OR THE TIP OF THE BLADE OF A CEILING PADDLE FAN.

K. SMOKE STRATIFICATION - SMOKE STRATIFICATION IS NOT EXPECTED TO OCCUR IN THIS/THESE INTERIOR BUILDING(S).

L. PERFORMANCE BASED DESIGN (PBD) - THE DESIGN IS DERIVED FROM A PRESCRIPTIVE DESIGN BASIS.

M. EVACUATION SIGNAL - EVACUATION SIGNAL IS A GENERAL SIGNAL ☐ BY FLOOR ☒ BY BUILDING.

N. WIRING REQUIREMENTS

1. WIRING SHALL BE IN ACCORDANCE WITH NFPA 72 AND NFPA 70 ARTICLES 300, 760, 770, AND 800, AS APPLICABLE, UNLESS OTHERWISE NOTED.
2. PROTECTION AGAINST DAMAGE: INSTALL WIRING IN METAL RACEWAY, CONCEAL RACEWAY EXCEPT IN UNFINISHED SPACES AND AS INDICATED.
3. FIRE ALARM DEVICES AND EQUIPMENT TO BE INSTALLED OUTDOORS IN EXTERIOR LOCATIONS SHALL BE SPECIFICALLY DESIGNED AND U.L. LISTED AS WEATHERPROOF AND WATERPROOF. PROVIDE WEATHERPROOF NEOPRENE GASKETS BETWEEN WALL MOUNTING SURFACE AND FIRE ALARM DEVICE FOR ALL DEVICES MOUNTED OUTDOORS.

O. OPERATIONS AND MAINTENANCE PROCEDURES

1. PROVIDE THE SERVICES OF A FACTORY-AUTHORIZED SERVICE REPRESENTATIVE TO DEMONSTRATE THE SYSTEM AND TRAIN OWNER'S MAINTENANCE PERSONNEL AS SPECIFIED BELOW:
 - a. TRAIN OWNER'S MAINTENANCE PERSONNEL IN THE LOCATION OF DEVICES, BOXES, PROCEDURES AND SCHEDULES INVOLVED IN OPERATING, TROUBLESHOOTING, SERVICING, AND PREVENTIVE MAINTAINING OF THE SYSTEM. PROVIDE A MINIMUM OF 4 HOURS' TRAINING. TRAINING SHALL INCLUDE A COMPLETE PROJECT WALKDOWN WITH OWNER'S AUTHORIZED REPRESENTATIVE TO IDENTIFY DEVICE LOCATIONS, JUNCTION BOX LOCATIONS AND SURGE SUPPRESSION MODULE LOCATIONS.
 - b. SCHEDULE TRAINING WITH THE OWNER AT LEAST SEVEN WORKING DAYS IN ADVANCE.


(5) BATTERY CALCULATIONS AND VOLTAGE DROP CALCULATIONS

FIRE ALARM CONTRACTOR SHALL SUBMITTALS AND SHOP DRAWINGS WITH BATTERY CALCULATIONS AND VOLTAGE DROP (CIRCUIT ANALYSIS) CALCULATIONS BASED ON THE SPECIFIC EQUIPMENT INCLUDED IN THOSE SUBMITTALS AND SHOP DRAWINGS. CALCULATIONS SHALL BE COMPLETED USING THE EQUIPMENT MANUFACTURE'S DATA AND APPLICABLE NFPA 72 PROCEDURES.

(6) SYSTEM TEST AND DOCUMENTATION REQUIREMENTS

FIRE ALARM CONTRACTOR SHALL PERFORM THE TESTING LISTED BELOW AND PREPARE RECORDS PER NFPA 72 SECTION 14.6.

- ☒ INITIAL ACCEPTANCE TESTING SHALL BE IN ACCORDANCE WITH NFPA 72 SECTION 14.4.1 FOR ALL NEW APPLIANCE AND CIRCUITS.
- ☐ RE-ACCEPTANCE TESTING IN ACCORDANCE WITH NFPA 72 14.4.2 FOR MODIFICATIONS OF EXISTING CIRCUITS.
- ☒ AFTER INITIAL ACCEPTANCE TESTING, FIRE ALARM SYSTEM TESTING SHALL BE PERFORMED AND DOCUMENTED IN COMPLIANCE WITH THE PERIODIC FREQUENCIES AND METHODS AS SHOWN IN NFPA 72 TABLE 14.3.1.



FIRE ALARM SYSTEM RISER DIAGRAM

NO SCALE

FIRE ALARM RISER - GENERAL NOTES:

- A. FIRE ALARM SYSTEM RISER DIAGRAM IS DIAGRAMMATICAL. SEE FLOOR PLANS FOR EXACT QUANTITIES OF DEVICES. WIRING SHALL BE AS RECOMMENDED BY SYSTEMS MANUFACTURER.
- B. DO NOT SCALE ELECTRICAL DRAWING FOR ANY DIMENSIONS.
- C. ALL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRICAL CODE, NATIONAL, STATE AND LOCAL CODES. PROVIDE GROUNDING AND BONDING PER NEC 250.
- D. PROVIDE 120VAC SURGE SUPPRESSION AND LOW VOLTAGE FIRE ALARM CIRCUIT SURGE SUPPRESSION.
- E. PROVIDE NOTIFICATION APPLIANCE CIRCUITS AND POWER SUPPLIES AS REQUIRED.
- F. REFER TO POWER AND SYSTEMS FLOOR PLANS FOR FIRE ALARM EQUIPMENT COUNT.
- G. PROVIDE 1" CONDUIT FROM FACP TO TTB.
- H. ALL FIRE ALARM CIRCUITS SHALL BE IN CONDUIT WHERE REQUIRED BY CODE OR AHJ. PROVIDE ALL REQUIRED MONITORING AND CONTROL OF MECHANICAL UNITS AS REQUIRED BY AUTHORITY HAVING JURISDICTION.
- I. VERIFY FIRE PROTECTION FLOW AND TAMPER SWITCH LOCATION WITH FIRE PROTECTION DRAWINGS. PROVIDE ALL REQUIRED MONITORING OF FIRE PROTECTION SYSTEM.
- J. PER FFPC 6TH EDITION NFPA 1 SECTION 11:10 TWO-WAY RADIO COMMUNICATION ENHANCEMENT SYSTEMS: IN ALL NEW AND EXISTING BUILDINGS, MINIMUM RADIO SIGNAL STRENGTH FOR THE FIRE DEPARTMENT COMMUNICATIONS SHALL BE SHALL BE MAINTAINED AT A LEVEL DETERMINED BY THE AHJ.
- K. CARBON MONOXIDE DETECTION SHALL BE PROVIDED NEAR GAS APPLIANCES AND WITHIN 10' OF SLEEPING AREAS IN BUILDINGS WITH FUEL BURNING APPLIANCES OR ATTACHED GARAGES, PER FLORIDA STATE STATUTE (2018) #509.211(4) AND #553.885.


FIRE ALARM SYSTEM LEGEND

- ☐ MANUAL PULL STATION
- ☒ cd WALL MOUNTED HORN WITH STROBE (cd=CANDELA RATING)
- ☒ WP WALL MOUNTED HORN WITH STROBE IN WEATHERPROOF ENCLOSURE
- ☒ C ceiling MOUNTED HORN WITH STROBE
- ☒ M WALL MOUNTED MINI HORN
- ☒ M WALL MOUNTED MINI HORN WITH STROBE
- ☒ V WALL MOUNTED VOICE EVACUATION SPEAKER WITH STROBE
- ☒ C ceiling MOUNTED VOICE EVACUATION SPEAKER WITH STROBE
- ☒ WALL MOUNTED STROBE
- ☒ FIRE ALARM BELL
- ☒ SMOKE DETECTOR
- ☒ CO SMOKE AND CARBON MONOXIDE COMBINATION DETECTOR
- ☒ DUCT MOUNTED SMOKE DETECTOR
- ☒ HEAT DETECTOR
- ☒ KX REMOTE DUCT DETECTOR INDICATOR LIGHT AND TEST SWITCH
- ☒ FAN SHUT-DOWN RELAY
- ☒ ELECTROMAGNETIC DOOR RELEASE DEVICE
- ☒ SMOKE DAMPER (PROVIDE BY MECHANICAL, CONNECTED BY ELECTRICAL)
- ☒ FIREMAN'S PHONE JACK
- ☒ SPRINKLER SYSTEM SUPERVISORY TAMPER SWITCH CONNECTION
- ☒ SPRINKLER SYSTEM FLOW SWITCH CONNECTION
- ☒ CONTROL MODULE
- ☒ MONITOR MODULE
- ☒ LOCK BOX
- ☒ FACP FIRE ALARM CONTROL PANEL
- ☒ FACB FIRE ALARM TERMINAL CABINET
- ☒ FAAP FIRE ALARM ANNUNCIATOR PANEL
- ☒ FACD DIGITAL ALARM COMMUNICATOR TRANSMITTER

	CONTROL UNIT ANNUNCIATION						NOTIFICATION	FIRE SAFETY CONTROL													
	ACTIVATE COMMON ALARM SIGNAL INDICATOR	ACTIVATE AUDIBLE ALARM SIGNAL	ACTIVATE COMMON SUPERVISORY SIGNAL INDICATOR	ACTIVATE AUDIBLE SUPERVISORY SIGNAL	ACTIVATE COMMON TROUBLE SIGNAL INDICATOR	ACTIVATE COMMON TROUBLE SIGNAL	ACTIVATE ALARM INDICATOR	ACTIVATE EVACUATION SIGNAL	DISPLAY/PRINT CHANGE OF STATUS	TRANSMIT FIRE ALARM SIGNAL TO SUPERVISING STATION	TRANSMIT SUPERVISORY SIGNAL TO SUPERVISING STATION	TRANSMIT TROUBLE SIGNAL TO SUPERVISING STATION	RELEASE MAGNETICALLY HELD SMOKE DOORS	RECALL ELEVATORS TO PRIMARY FLOOR	RECALL ELEVATORS TO ALTERNATE FLOOR	CLOSE SMOKE/FIRE DAMPERS IN RATED WALLS	SHUTDOWN AFFECTED ELEVATOR POWER	SHUTDOWN AFFECTED AIR HANDLING UNITS(S)	UNLOCK SECURED EGRESS EXITS		
SYSTEM INPUTS	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S		
1 MANUAL FIRE ALARM BOXES	●	●					●	●	●	●			●						●		
2 AREA SMOKE DETECTORS	●	●							●	●											
3 IN-DUCT SMOKE DETECTORS			●	●					●	●	●										
4 HEAT DETECTOR IN ELEVATOR SHAFT/PIT		●	●						●	●											
5 ELEVATOR LOBBY SMOKE DETECTORS - FIRST FLOOR	●	●							●	●											
6 ELEVATOR LOBBY SMOKE DETECTORS - UPPER FLOORS	●	●							●	●											
7 WATER FLOW		●					●														
8 SPRINKLER CONTROL VALVE			●	●					●	●	●										
9 OPEN CIRCUIT					●	●															
10 GROUND FAULT					●	●															
11 NOTIFICATION APPLIANCE CIRCUIT SHORT					●	●							●								

FIRE ALARM MATRIX OF OPERATIONS


NO SCALE



Consulting Engineers

1850 HAWWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCENGINE.COM
CA NO. 28730

JLC 21.0042.00



AA C00066

HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
577 MAULDIN AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.5797 FAX 407.647.2802

TOWNEPLACE
SUITES
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA

REVISION

JOB NO.

DATE

SHEET

E6.2

OF

PANEL 'DBA'																			
LOCATION: 2ND FLOOR ELECTRICAL ROOM TYPE: SQUARE-D FED FROM: METER CENTER 'MC'						VOLTAGE: 208Y/120V 3ø 4W MAINS: 600A □ MLO □ MCB LUOS: □ SUB-FEED □ FEED-THRU						MIN. AIC RATINGS: 42K A/C MOUNTING: SURFACE				NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS			
#	CIRCUIT DESCRIPTION	120 V Ø	Ø	NEUTR	GND COND	BKR	LOAD KVA	PHASE Ø		LOAD KVA	BKR	Ø	NEUTR	GND COND	120 V Ø	CIRCUIT DESCRIPTION	#		
								#	NEUTR									GND COND	#
1	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21 A	9.23	125/2	-	-	-	-	-	1	UNIT PANEL - KING STUDIO	2		
3	-	1	-	-	-	-	9.21 B	9.23	-	-	-	-	-	-	-	-	4		
5	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21 C	9.23	125/2	-	-	-	-	-	1	UNIT PANEL - KING STUDIO	6		
7	-	1	-	-	-	-	9.21 A	9.23	-	-	-	-	-	-	-	-	8		
9	UNIT PANEL - KING SUITE	1	-	-	-	125/2	9.29 B	9.21	125/2	-	-	-	-	-	1	UNIT PANEL - QQ STUDIO	10		
11	-	1	-	-	-	-	9.29 C	9.21	-	-	-	-	-	-	-	-	12		
13	UNIT PANEL - KING SUITE	1	-	-	-	125/2	9.29 A	9.23	125/2	-	-	-	-	-	1	UNIT PANEL - KING STUDIO	14		
15	-	1	-	-	-	-	9.29 B	9.23	-	-	-	-	-	-	-	-	16		
17	UNIT PANEL - KING STUDIO	1	-	-	-	125/2	9.23 C	9.23	125/2	-	-	-	-	-	1	UNIT PANEL - KING STUDIO	18		
19	-	1	-	-	-	-	9.23 A	9.23	-	-	-	-	-	-	-	-	20		
21	UNIT PANEL - KING STUDIO	1	-	-	-	125/2	9.23 B	9.23	125/2	-	-	-	-	-	1	UNIT PANEL - KING STUDIO	22		
23	-	1	-	-	-	-	9.23 C	9.23	-	-	-	-	-	-	-	-	24		
25	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21 A	9.23	125/2	-	-	-	-	-	1	UNIT PANEL - KING STUDIO	26		
27	-	1	-	-	-	-	9.21 B	9.23	-	-	-	-	-	-	-	-	28		
29	UNIT PANEL - KING STUDIO	1	-	-	-	125/2	9.23 C	9.29	125/2	-	-	-	-	-	1	UNIT PANEL - KING SUITE	30		
31	-	1	-	-	-	-	9.23 A	9.29	-	-	-	-	-	-	-	-	32		
33	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21 B	9.29	125/2	-	-	-	-	-	1	UNIT PANEL - KING SUITE	34		
35	-	1	-	-	-	-	9.21 C	9.29	-	-	-	-	-	-	-	-	36		
37	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21 A	9.21	125/2	-	-	-	-	-	1	UNIT PANEL - QQ STUDIO	38		
39	-	1	-	-	-	-	9.21 B	9.21	-	-	-	-	-	-	-	-	40		
41	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21 C	9.21	125/2	-	-	-	-	-	1	UNIT PANEL - QQ STUDIO	42		
43	-	1	-	-	-	-	9.21 A	9.21	-	-	-	-	-	-	-	-	44		
45	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21 B	B	-	-	-	-	-	-	-	-	46		
47	-	1	-	-	-	-	9.21 C	C	-	-	-	-	-	-	-	-	48		
49	SPACE ONLY		-	-	-	-	A	-	-	-	-	-	-	-	-	-	50		
51	SPACE ONLY		-	-	-	-	B	-	-	-	-	-	-	-	-	-	52		
53	SPACE ONLY		-	-	-	-	C	-	-	-	-	-	-	-	-	-	54		
EQUIPMENT SERVED						CONN. LOAD		L.F.	D.F.	DEMAND LOAD									
PANELS (PER HOTEL/RESIDENTIAL LOAD SUMMARY)						424.61 KVA			36%	152.86 KVA									
NOTES: 1)REFER TO DISTRIBUTION FEEDER CALCULATIONS & POWER RISK DIAGRAM FOR FEEDER SIZES.												TOTAL DEMAND LOAD: 152.86 KVA TOTAL DEMAND AMPS: 424.80 AMPS							

PANEL 'DBC'

LOCATION: 2ND FLOOR ELECTRICAL ROOM

TYPE: SQUARE-D

FED FROM: METER CENTER 'MC'

VOLTAGE: 208Y/120V

MAGNS: 600A

LUGS:

3Ø 4W

3Ø MLO

SUB-FEED

FEED-THRU

MIN. AIC RATING: 42K AIC

150.21G SURFACE

ENCLOSURE: NEMA 1

NOTES:
PROVIDE TYPED WRITTEN DIRECTORY
PROVIDE GROUND & NEUTRAL BUS

CIRCUIT DESCRIPTION	CIRCUIT #	Ø 2	Ø 1	BRANCH CIRCUIT				PHASE				CIRCUIT DESCRIPTION	CIRCUIT #		
				Ø 2	Ø 1	Ø 0	Ø 3	Ø 2	Ø 1	Ø 0	Ø 3				
1 UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	A	9.23	125/2	-	1	UNIT PANEL - KING STUDIO	2
3	-	-	-	-	-	-	-	9.21	B	9.23	-	-	-	-	4
5 UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	C	9.23	125/2	-	1	UNIT PANEL - KING STUDIO	6
7	-	-	-	-	-	-	-	9.21	A	9.23	-	-	-	-	8
9 UNIT PANEL - KING SUITE	1	-	-	-	-	-	125/2	9.29	B	9.21	125/2	-	1	UNIT PANEL - QQ STUDIO	10
11	-	-	-	-	-	-	-	9.29	C	9.21	-	-	-	-	12
13 UNIT PANEL - KING SUITE	1	-	-	-	-	-	125/2	9.29	A	9.23	125/2	-	1	UNIT PANEL - KING STUDIO	14
15	-	-	-	-	-	-	-	9.29	B	9.23	-	-	-	-	16
17 UNIT PANEL - KING STUDIO	1	-	-	-	-	-	125/2	9.23	C	9.23	125/2	-	1	UNIT PANEL - KING STUDIO	18
19	-	-	-	-	-	-	-	9.23	A	9.23	-	-	-	-	20
21 UNIT PANEL - KING STUDIO	1	-	-	-	-	-	125/2	9.23	B	9.23	125/2	-	1	UNIT PANEL - KING STUDIO	22
23	-	-	-	-	-	-	-	9.23	C	9.23	-	-	-	-	24
25 UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	A	9.23	125/2	-	1	UNIT PANEL - KING STUDIO	26
27	-	-	-	-	-	-	-	9.21	B	9.23	-	-	-	-	28
29 UNIT PANEL - KING STUDIO	1	-	-	-	-	-	125/2	9.23	C	9.22	125/2	-	1	UNIT PANEL - QUEEN SUITE	30
31	-	-	-	-	-	-	-	9.23	A	9.22	-	-	-	-	32
33 UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	B	9.29	125/2	-	1	UNIT PANEL - KING SUITE	34
35	-	-	-	-	-	-	-	9.21	C	9.29	-	-	-	-	36
37 UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	A	9.21	125/2	-	1	UNIT PANEL - QQ STUDIO	38
39	-	-	-	-	-	-	-	9.21	B	9.21	-	-	-	-	40
41 UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	C	9.21	125/2	-	1	UNIT PANEL - QQ STUDIO	42
43	-	-	-	-	-	-	-	9.21	A	9.21	-	-	-	-	44
45 UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	B	-	-	-	-	-	46
47	-	-	-	-	-	-	-	9.21	C	-	-	-	-	-	48
49 SPACE ONLY	-	-	-	-	-	-	-	-	A	-	-	-	-	-	50
51 SPACE ONLY	-	-	-	-	-	-	-	-	B	-	-	-	-	-	52
53 SPACE ONLY	-	-	-	-	-	-	-	-	C	-	-	-	-	-	54

EQUIPMENT SERVED

PANELS (PER FLOOR/RESIDENTIAL LOAD SUMMARY)

CONN. LOAD

424.48 KVA

L.F.

D.F.

DEMAND LOAD

36%

150.21G KVA

NOTES:
1) REFERENCE TO DISTRIBUTION FEEDER CALCULATIONS & LOAD RISK DIAGRAM FOR FEEDER SIZES

TOTAL DEMAND LOAD: 150.21 KVA
TOTAL DEMAND AMPS: 424.66 AMPS

HOTEL/RESIDENTIAL CALCULATION LOAD				
SUMMARY - PANEL 'DBD'				
UNIT PANELS - KING STUDIO	18.460	VA x	9 =	166,140 VA
UNIT PANELS - KING SUITE	18.580	VA x	4 =	74,320 VA
UNIT PANELS - QO STUDIO	18.415	VA x	10 =	184,150 VA
UNIT PANELS - Q SUITE	18.445	VA x	0 =	0 VA
TOTAL CONNECTED UNIT LOAD	=	434,610 VA		
TOTAL UNIT DEMAND LOAD	=	152,860 VA (PER NEC 220.84)		
TOTAL DEMAND AMPS	=	424.80 AMPS 800A @ 208V/3PH, 4W SERVICE		

PANEL 'DBB'

LOCATION: 2ND FLOOR ELECTRICAL ROOM

TYPE: SQUARE-D

FED FROM: METER CENTER 'MC'

VOLTAGE: 208Y/120V 3ø 4W

MAINS: 600A □ MLO □ MCB

LUGS: □ SUB-FEED □ FEED-THRU

MIN. AIC RATING: 42K A/C

SURFACE

ENCLOSURE: NEMA 1

NOTES:

PROVIDE TYPED WRITTEN DIRECTORY

PROVIDE GROUND & NEUTRAL BUS

NO	CIRCUIT DESCRIPTION	NO	NO	BRANCH CIRCUIT				PHASE				BRANCH CIRCUIT				CIRCUIT DESCRIPTION	NO		
				Ø	NEUT	GND	COND	KVA	Ø	NEUT	GND	COND	KVA	Ø	NEUT			GND	COND
1	UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	A	9.23	125/2	-	-	-	-	1	UNIT PANEL - KING STUDIO	2
3	-	-	-	-	-	-	-	-	9.21	B	9.23	-	-	-	-	-	-	-	4
5	UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	C	9.23	125/2	-	-	-	-	1	UNIT PANEL - KING STUDIO	6
7	-	-	-	-	-	-	-	-	9.21	A	9.23	-	-	-	-	-	-	-	8
9	UNIT PANEL - KING SUITE	1	-	-	-	-	-	125/2	9.29	B	9.21	125/2	-	-	-	-	1	UNIT PANEL - QQ STUDIO	10
11	-	-	-	-	-	-	-	-	9.29	C	9.21	-	-	-	-	-	-	-	12
13	UNIT PANEL - KING SUITE	1	-	-	-	-	-	125/2	9.29	B	9.23	125/2	-	-	-	-	1	UNIT PANEL - KING STUDIO	14
15	-	-	-	-	-	-	-	-	9.29	B	9.23	-	-	-	-	-	-	-	16
17	UNIT PANEL - KING STUDIO	1	-	-	-	-	-	125/2	9.23	C	9.23	125/2	-	-	-	-	1	UNIT PANEL - KING STUDIO	18
19	-	-	-	-	-	-	-	-	9.23	A	9.23	-	-	-	-	-	-	-	20
21	UNIT PANEL - KING STUDIO	1	-	-	-	-	-	125/2	9.23	B	9.23	125/2	-	-	-	-	1	UNIT PANEL - KING STUDIO	22
23	-	-	-	-	-	-	-	-	9.23	C	9.23	-	-	-	-	-	-	-	24
25	UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	A	9.23	125/2	-	-	-	-	1	UNIT PANEL - KING STUDIO	26
27	-	-	-	-	-	-	-	-	9.21	B	9.23	-	-	-	-	-	-	-	28
29	UNIT PANEL - KING STUDIO	1	-	-	-	-	-	125/2	9.23	C	9.29	125/2	-	-	-	-	1	UNIT PANEL - KING SUITE	30
31	-	-	-	-	-	-	-	-	9.23	A	9.29	-	-	-	-	-	-	-	32
33	UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	B	9.29	125/2	-	-	-	-	1	UNIT PANEL - KING SUITE	34
35	-	-	-	-	-	-	-	-	9.21	C	9.29	-	-	-	-	-	-	-	36
37	UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	A	9.21	125/2	-	-	-	-	1	UNIT PANEL - QQ STUDIO	38
39	-	-	-	-	-	-	-	-	9.21	B	9.21	-	-	-	-	-	-	-	40
41	UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	C	9.21	125/2	-	-	-	-	1	UNIT PANEL - QQ STUDIO	42
43	-	-	-	-	-	-	-	-	9.21	A	9.21	-	-	-	-	-	-	-	44
45	UNIT PANEL - QQ STUDIO	1	-	-	-	-	-	125/2	9.21	B	-	-	-	-	-	-	-	SPACE ONLY	46
47	-	-	-	-	-	-	-	-	9.21	C	-	-	-	-	-	-	-	SPACE ONLY	48
49	SPACE ONLY	-	-	-	-	-	-	-	-	A	-	-	-	-	-	-	-	SPACE ONLY	50
51	SPACE ONLY	-	-	-	-	-	-	-	-	B	-	-	-	-	-	-	-	SPACE ONLY	52
53	SPACE ONLY	-	-	-	-	-	-	-	-	C	-	-	-	-	-	-	-	SPACE ONLY	54

EQUIPMENT SERVED

PANELS (PER HOTEL/RESIDENTIAL LOAD SUMMARY)

CONN. LOAD

164.41 KVA

L.F.

36%

D.F.

152.86 KVA

TOTAL DEMAND LOAD

152.86 KVA

TOTAL DEMAND AMPS:

424.80 AMPS

NOTES:

1)REFER TO DISTRIBUTION FEEDER CALCULATIONS & LOAD RISK DIAGRAM FOR FEEDER SIZE

PANEL 'DBD'															
LOCATION: 2ND FLOOR ELECTRICAL ROOM			VOLTAGE: 208Y/120V 3ø 4W			MIN. AIC RATING: 42K AIC			NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS						
TYPE: SQUARE-D			MAINS: 600A 42MLO ☐ MCB			MOUNTING: SURFACE									
FED FROM: METER CENTER 'MC'			LUGS: ☐ SUB-FEED ☐ FEED-THRU			ENCLOSURE: NEMA 1									
NO	CIRCUIT DESCRIPTION	Ø 2	BRANCH CIRCUIT		BKR	LOAD KVA		PHASE Ø	BKR	BRANCH CIRCUIT		Ø 2	CIRCUIT DESCRIPTION	NO	
			#	NEUTR COND		#	NEUTR COND			#	NEUTR COND				
1	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21	A	9.23	125/2	-	-	1	UNIT PANEL - KING STUDIO	21
3	-	-	-	-	-	-	9.21	B	9.23	-	-	-	-	-	4
5	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21	C	9.23	125/2	-	-	1	UNIT PANEL - KING STUDIO	6
7	-	-	-	-	-	-	9.21	A	9.23	-	-	-	-	-	8
9	UNIT PANEL - KING SUITE	1	-	-	-	125/2	9.29	B	9.21	125/2	-	-	1	UNIT PANEL - QQ STUDIO	10
11	-	-	-	-	-	-	9.29	C	9.21	-	-	-	-	-	12
13	UNIT PANEL - KING SUITE	1	-	-	-	125/2	9.29	A	9.23	125/2	-	-	1	UNIT PANEL - KING STUDIO	14
15	-	-	-	-	-	-	9.29	B	9.23	-	-	-	-	-	16
17	UNIT PANEL - KING STUDIO	1	-	-	-	125/2	9.23	C	9.23	125/2	-	-	1	UNIT PANEL - KING STUDIO	18
19	-	-	-	-	-	-	9.23	A	9.23	-	-	-	-	-	20
21	UNIT PANEL - KING STUDIO	1	-	-	-	125/2	9.23	B	9.23	125/2	-	-	1	UNIT PANEL - KING STUDIO	22
23	-	-	-	-	-	-	9.23	C	9.23	-	-	-	-	-	24
25	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21	A	9.23	125/2	-	-	1	UNIT PANEL - KING STUDIO	26
27	-	-	-	-	-	-	9.21	B	9.23	-	-	-	-	-	28
29	UNIT PANEL - KING STUDIO	1	-	-	-	125/2	9.23	C	9.29	125/2	-	-	1	UNIT PANEL - KING SUITE	30
31	-	-	-	-	-	-	9.23	A	9.29	-	-	-	-	-	32
33	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21	B	9.29	125/2	-	-	1	UNIT PANEL - KING SUITE	34
35	-	-	-	-	-	-	9.21	C	9.29	-	-	-	-	-	36
37	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21	A	9.21	125/2	-	-	1	UNIT PANEL - QQ STUDIO	38
39	-	-	-	-	-	-	9.21	B	9.21	-	-	-	-	-	40
41	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21	C	9.21	125/2	-	-	1	UNIT PANEL - QQ STUDIO	42
43	-	-	-	-	-	-	9.21	A	9.21	-	-	-	-	-	44
45	UNIT PANEL - QQ STUDIO	1	-	-	-	125/2	9.21	B	-	-	-	-	-	-	46
47	-	-	-	-	-	-	9.21	C	-	-	-	-	-	-	48
49	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	50
51	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	52
53	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	54
EQUIPMENT SERVED						CONN. LOAD	L.F.	D.F.	DEMAND LOAD						
PANELS (PER HOTEL/RESIDENTIAL LOAD SUMMARY)						424.61 KVA		36%	152.86 KVA						
NOTES: 1) REFER TO DISTRIBUTION FEEDER CALCULATIONS & POWER BRANCH DIAGRAM FOR FEEDING										TOTAL DEMAND LOAD: 152.86 KVA TOTAL DEMAND AMPS: 424.80 AMPS					

HOTEL/RESIDENTIAL CALCULATION LOAD SUMMARY - PANEL 'DBC'				
UNIT PANELS - KING STUDIO	18,450	VA	x	9 = 166,140 VA
UNIT PANELS - KING SUITE	18,580	VA	x	3 = 55,740 VA
UNIT PANELS - QD STUDIO	18,415	VA	x	10 = 184,150 VA
UNIT PANELS - Q SUITE	18,445	VA	x	1 = 18,445 VA
TOTAL CONNECTED UNIT LOAD	= 424,475 VA			
TOTAL UNIT DEMAND LOAD	= 152,811 VA (PER NEC 220.84)			
TOTAL DEMAND AMPS	= 424.66 AMPS 600A @ 208V/3PH, 4W SERVICE			

PANEL 'MDP'																	
LOCATION: MAIN ELECTRICAL ROOM				VOLTAGE: 208Y/120V 3Ø 4W				MIN. AIC RATING: 65K AIC				NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS					
TYPE: SQUARE-D QED SWITCHBOARD				MAINS: 3000A □ MLO □ MCB				MOUNTING: FREE STANDING									
FED FROM: UTILITY TRANSFORMER				LUGS: □ SUB-FEED □ FEED-THRU				ENCLOSURE: NEMA 1									
L S	CIRCUIT DESCRIPTION	Ø S	Ø NEUT	BRANCH CIRCUIT Ø NEUT COND	COND	BKR	LOAD KVA	Ø S	Ø NEUT	BRANCH CIRCUIT Ø NEUT COND	COND	Ø S	Ø NEUT	Ø COND	CIRCUIT DESCRIPTION	L S	
1	PANEL 'DBA'	1	-	-	-	600/3	50.95	A	50.95	600/3	-	-	-	-	1 PANEL 'DBB'	2	
3	-	-	-	-	-	-	50.95	B	50.95	-	-	-	-	-	-	3	
5	-	-	-	-	-	-	50.95	C	50.95	-	-	-	-	-	-	4	
7	PANEL 'DBC'	1	-	-	-	600/3	50.95	A	50.95	600/3	-	-	-	-	1 PANEL 'DBD'	8	
9	-	-	-	-	-	-	50.95	B	50.95	-	-	-	-	-	-	10	
11	-	-	-	-	-	-	50.95	C	50.95	-	-	-	-	-	-	12	
13	PANEL 'DBF'	1	-	-	-	400/3	26.51	A	10.89	200/3	-	-	-	-	1 PANEL 'LS1' VIA ATS-1	14	
15	-	-	-	-	-	-	26.51	B	10.89	-	-	-	-	-	-	16	
17	-	-	-	-	-	-	26.51	C	10.89	-	-	-	-	-	-	18	
19	PANEL 'LA'	1	-	-	-	400/3	16.56	A	20.56	200/3	-	-	-	-	1 PANEL 'EM' VIA ATS-2	20	
21	-	-	-	-	-	-	16.56	B	20.56	-	-	-	-	-	-	22	
23	-	-	-	-	-	-	16.56	C	20.56	-	-	-	-	-	-	24	
25	PANEL 'PA'	1	-	-	-	300/3	11.75	A	2.41	100/3	-	-	-	-	PANEL 'LB1'	26	
27	-	-	-	-	-	-	11.75	B	2.41	-	-	-	-	-	-	28	
29	-	-	-	-	-	-	11.75	C	2.41	-	-	-	-	-	-	30	
31	PANEL 'PA'	1	-	-	-	200/3	8.83	A	13.56	200/3	-	-	-	-	1 PANEL 'LB2'	32	
33	-	-	-	-	-	-	8.83	B	13.56	-	-	-	-	-	-	34	
35	-	-	-	-	-	-	8.83	C	13.56	-	-	-	-	-	-	36	
37	OU-1	1/0	1/0	6	2"	150/3	10.20	A	-	-	-	-	-	-	1 SPACE	38	
39	-	1/0	-	-	-	-	10.20	B	-	-	-	-	-	-	-	40	
41	-	1/0	-	-	-	-	10.20	C	-	-	-	-	-	-	-	42	
43	OU-2	2	2	8	1.25"	80/3	5.46	A	7.20	100/3	-	-	-	-	1 PANEL 'PE' (POOL)	44	
45	-	2	-	-	-	-	5.46	B	7.20	-	-	-	-	-	-	46	
47	-	2	-	-	-	-	5.46	C	7.20	-	-	-	-	-	-	48	
49	SPACE	-	-	-	-	-	-	A	-	-	-	-	-	-	2 SPACE	50	
51	-	-	-	-	-	-	-	B	-	-	-	-	-	-	-	52	
53	-	-	-	-	-	-	-	C	-	-	-	-	-	-	-	54	
55	SPACE	-	-	-	-	-	A	-	60/3	4	4	10	1.25"	-	SURGE PROTECTIVE DEVICE (SPD)	56	
57	-	-	-	-	-	-	-	B	-	-	-	-	-	-	-	58	
59	-	-	-	-	-	-	-	C	-	-	-	-	-	-	-	60	
EQUIPMENT SERVED							CONN. LOAD		L.F.		D.F.		DEMAND LOAD				
PANELS							275.28 KVA		100%		275.28 KVA						
HVAC							46.98 KVA		100%		46.98 KVA						
GUESTROOM DISTRIBUTION PANELS							1883.24 KVA		23%		433.14 KVA						
NOTES:														TOTAL DEMAND LOAD: 755.40 KVA			
1) PREFER TO RISER DIAGRAM FOR FEEDER SIZES														TOTAL DEMAND AMPS: 2,098.33 AMPS			
2) PROVIDE SHUNT TRIP C/B FOR ELEVATORS																	

HOTEL/RESIDENTIAL CALCULATION LOAD SUMMARY - MDP				
UNIT PANELS - KING STUDIO	18,450	VA	x 38	= 701,480 VA
UNIT PANELS - KING SUITE	18,580	VA	x 19	= 353,020 VA
UNIT PANELS - QO STUDIO	18,415	VA	x 43	= 791,845 VA
UNIT PANELS - Q SUITE	18,445	VA	x 2	= 36,890 VA
TOTAL CONNECTED UNIT LOAD =				1,885,235 VA
TOTAL UNIT DEMAND LOAD =				433,144 VA (PER NEC 220.84)
TOTAL DEMAND AMPS =				1,203.71 AMPS 3000A @ 208V/3PH, 4W/SERVICE

HOTEL/RESIDENTIAL CALCULATION LOAD				
SUMMARY - PANEL 'DBA'				
UNIT PANELS - KING STUDIO	18,450	VA	x	9 = 166,140 VA
UNIT PANELS - KING SUITE	18,580	VA	x	4 = 74,320 VA
UNIT PANELS - QQ STUDIO	18,415	VA	x	10 = 184,150 VA
UNIT PANELS - Q SUITE	18,445	VA	x	0 = 0 VA
TOTAL CONNECTED UNIT LOAD			=	424,610 VA
TOTAL UNIT DEMAND LOAD			=	152,860 VA (PER NEC 220.84)
TOTAL DEMAND AMPS			=	424.80 AMPS 600A @ 208V/3PH, 4W SERVICE

HOTEL/RESIDENTIAL CALCULATION LOAD SUMMARY - PANEL 'DBB'				
UNIT PANELS - KING STUDIO	18,460	VA x 8 =	166,140	VA
UNIT PANELS - KING SUITE	18,580	VA x 4 =	74,320	VA
UNIT PANELS - QG STUDIO	18,415	VA x 10 =	184,150	VA
UNIT PANELS - Q SUITE	18,445	VA x 0 =	0	VA
TOTAL CONNECTED UNIT LOAD			=	424,610 VA
TOTAL UNIT DEMAND LOAD			=	152,860 VA (PER NEC 220.84)
TOTAL DEMAND AMPS			=	424.80 AMPS 600A @ 208V/3PH, 4W SERVICE

PANEL 'EM1'																			
LOCATION: 5TH FLOOR HOUSEKEEPING				VOLTAGE: 208Y/120V 3ø 4W				MIN. AIC RATING: 42K AIC				NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS							
TYPE: SQUARE-D				MAINS: 200A ☒ MLO ☐ MCB				MOUNTING: SURFACE											
FED FROM: ATS				LUGS: ☐ SUB-FEED ☐ FEED-THRU				ENCLOSURE: NEMA 1											
DIS	CIRCUIT DESCRIPTION	NOTES	BRANCH CIRCUIT			BKR	LOAD KVA	PHASE	LOAD KVA	BKR	BRANCH CIRCUIT			DIS	CIRCUIT DESCRIPTION	NOTES			
			#	NEUT	COND						#	NEUT	COND						
1	ELEVATOR #1		4	4	8	1.25	60/3	5.76	A	5.76	60/3	4	4	8	1.25	ELEVATOR #1	2		
3	-		4	-	-	-	-	5.76	B	5.76	-	4	-	-	-	-	4		
5	-		4	-	-	-	-	5.76	C	5.76	-	4	-	-	-	-	6		
7	SHUNT TRIP		-	-	-	////	////	A	////	////	-	-	-	-	-	SHUNT TRIP	8		
9	ELEVATOR LIGHTING CIRCUIT 1		12	12	12	1/2"	20/1	1.00	B	1.00	20/1	12	12	12	1/2"	ELEVATOR LIGHTING CIRCUIT 2	10		
11	DRYER		12	12	12	1/2"	20/1	0.50	C	-	-	-	-	-	-	SPACE ONLY	12		
13	WASHER		10	10	10	3/4"	30/3	2.40	A	-	-	-	-	-	-	SPACE ONLY	14		
15	-		10	-	-	-	-	2.40	B	-	-	-	-	-	-	SPACE ONLY	16		
17	-		10	-	-	-	-	2.40	C	-	-	-	-	-	-	SPACE ONLY	18		
19	RECEPS - FRONT DESK		-	-	-	-	20/1	0.54	A	-	20/1	-	-	-	-	SPARE	20		
21	SPARE		-	-	-	-	-	-	B	-	20/1	-	-	-	-	SPARE	22		
23	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	24		
25	SPACE ONLY		-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	26		
27	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	28		
29	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	30		
31	SPACE ONLY		-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	32		
33	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	34		
35	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	36		
37	SPACE ONLY		-	-	-	-	-	-	A	5.46	100/3	-	-	-	-	PANEL 'EM2'	38		
39	SPACE ONLY		-	-	-	-	-	-	B	5.46	-	-	-	-	-	-	40		
41	SPACE ONLY		-	-	-	-	-	-	C	5.46	-	-	-	-	-	-	42		
EQUIPMENT SERVED				CONN. LOAD				L.F. D.F. DEMAND LOAD											
EQUIPMENT				42.80 KVA				100% 42.80 KVA											
LIGHTING				2.00 KVA				125% 2.50 KVA											
SUB PANEL				16.37 KVA				100% 16.37 KVA											
NOTES:																			
												TOTAL DEMAND LOAD: 61.67 KVA							
												TOTAL DEMAND AMPS: 171.31 AMPS							

PANEL 'EM2'																			
LOCATION: PANTRY #114				VOLTAGE: 208Y/120V 3Ø 4W						MIN. AIC RATING: 10K AIC						NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS			
TYPE: SQUARE-D				MAINS: 100A ☒ MLO ☐ MCB						MOUNTING: SURFACE									
FED FROM: PANEL 'EM1'				LUGS: ☐ SUB-FEED ☐ FEED-THRU						ENCLOSURE: NEMA 4X									
DIS	CIRCUIT DESCRIPTION	NOTES	BRANCH CIRCUIT		BKR	LOAD KVA	PHASE	LOAD KVA	BKR	BRANCH CIRCUIT		DIS	CIRCUIT DESCRIPTION	DIS					
			# NEUT	COND						# NEUT	COND								
1	OATMEAL COOKER (94)		12	12	12	1/2"	20/1	1.20	A	1.58	20/1	12	12	12	1/2"	TWO DOOR FREEZER (50)	2		
3	COUNTER REFRIGERATOR (143)		12	12	12	1/2"	20/1	0.30	B	1.09	20/1	12	12	12	1/2"	TWO DOOR REFRIGERATOR (52)	4		
5	JUICE CHILLER (118)		12	12	12	1/2"	20/1	0.54	C	0.86	20/1	12	12	12	1/2"	SINGLE DOOR FREEZER (54)	6		
7	INDUCTION WARMER (99)		12	12	12	1/2"	20/1	0.65	A	0.55	20/1	12	12	12	1/2"	COMPACT REFRIGERATOR (59)	8		
9	INDUCTION WARMER (99)		12	12	12	1/2"	20/1	0.65	B	1.70	20/1	12	12	12	1/2"	COFFEE BREWER (105)	10		
11	WAFFLE IRON (114)		12	12	12	1/2"	20/1	1.50	C	3.66	40/3	8	8	10	3/4"	DISHWASHER	12		
13	WAFFLE IRON (114)		12	12	12	1/2"	20/1	1.50	A	3.66	-	8	-	-	-	-	14		
15	SLOT TOASTER (148)		12	12	12	1/2"	20/1	1.80	B	3.66	-	8	-	-	-	-	16		
17	SPARE		-	-	-	-	20/1	-	C	0.18	20/1	12	12	12	1/2"	RECEP - GENERAL	18		
19	SPARE		-	-	-	-	20/1	-	A	-	20/1	-	-	-	-	SPARE	20		
21	SPARE		-	-	-	-	20/1	-	B	-	20/1	-	-	-	-	SPARE	22		
23	SPARE		-	-	-	-	20/1	-	C	-	20/1	-	-	-	-	SPARE	24		
25	SPARE		-	-	-	-	20/1	-	A	-	20/1	-	-	-	-	SPARE	26		
27	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	28		
29	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	30		
31	SPACE ONLY		-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	32		
33	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	34		
35	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	36		
37	SPACE ONLY		-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	38		
39	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	40		
41	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	42		
EQUIPMENT SERVED				CONN. LOAD				L.F. D.F. DEMAND LOAD											
RECEPTACLES - GENERAL				0.18 KVA				100% 0.18 KVA											
KITCHEN EQUIPMENT				24.90 KVA				65% 16.19 KVA				PER NEC 220.56							
NOTES:																			
												TOTAL DEMAND LOAD: 16.37 KVA							
												TOTAL DEMAND AMPS: 45.47 AMPS							

PANEL 'LS1'																			
LOCATION: MECHANICAL ROOM 026				VOLTAGE: 208Y/120V 3Ø 4W				MIN. AIC RATING: 42K AIC				NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS							
TYPE: SQUARE-D				MAINS: 200A ☒ MLD ☐ MCB				MOUNTING: SURFACE											
FED FROM: MDP				LUGS: ☐ SUB-FEED ☐ FEED-THRU				ENCLOSURE: NEMA 1											
DIS	CIRCUIT DESCRIPTION	NOTES	BRANCH CIRCUIT			BKR	LOAD KVA	PHASE	LOAD KVA	BKR	BRANCH CIRCUIT			DIS	CIRCUIT DESCRIPTION	DIS			
			#	NEUT	COND						#	NEUT	COND						
1	LIGHTING - ELEC/LAUNDRY/BREAK		12	12	12	1/2"	20/1	1.06	A	0.30	20/1	10	10	10	1/2"	LIGHTING - 2ND FLOOR CORRIDOR	2		
3	LIGHTING - CORRIDOR/ELEVATOR LOBBY		12	12	12	1/2"	20/1	0.59	B	0.46	20/1	10	10	10	1/2"	LIGHTING - 2ND FLOOR CORRIDOR	4		
5	LIGHTING - OFFICES		12	12	12	1/2"	20/1	0.42	C	0.25	20/1	10	10	10	1/2"	LIGHTING - STAIRWELL	6		
7	LIGHTING - WELCOME DESK/HUB/VEST		12	12	12	1/2"	20/1	0.57	A	0.25	20/1	10	10	10	1/2"	LIGHTING - STAIRWELL	8		
9	LIGHTING - WELCOME DESK PENDANT		12	12	12	1/2"	20/1	0.10	B	0.16	20/1	10	10	10	1/2"	LIGHTING - ELEVATOR SHAFT	10		
11	LIGHTING - EXTERIOR		12	12	12	1/2"	20/1	0.21	C	-	20/1	-	-	-	-	SPARE	12		
13	LIGHTING - EXTERIOR		10	10	10	1/2"	20/1	0.06	A	-	20/1	-	-	-	-	SPARE	14		
15	LIGHTING - EXTERIOR		10	10	10	1/2"	20/1	0.33	B	-	20/1	-	-	-	-	SPARE	16		
17	SPACE ONLY		-	-	-	-	-	-	C	-	20/1	-	-	-	-	SPARE	18		
19	SPACE ONLY		-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	20		
21	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	22		
23	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	24		
25	SPACE ONLY		-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	26		
27	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	28		
29	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	30		
31	SPACE ONLY		-	-	-	-	-	-	A	-	60/3	-	-	-	-	SURGE PROTECTION DEVICE (SPD)	32		
33	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	-	34		
35	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	-	36		
37	PANEL 'LS2'		-	-	-	-	60/3	2.05	A	6.86	80/3	-	-	-	-	PANEL 'LS3'	38		
39			-	-	-	-	-	2.05	B	6.86	-	-	-	-	-	-	40		
41			-	-	-	-	-	2.05	C	6.86	-	-	-	-	-	-	42		
EQUIPMENT SERVED			CONN. LOAD			L.F.	D.F.			DEMAND LOAD									
LIGHTING			4.76 KVA				125%			5.95 KVA									
EQUIPMENT			- KVA				100%			- KVA									
SUB PANELS			26.73 KVA				100%			26.73 KVA									
NOTES:													TOTAL DEMAND LOAD: 32.68 KVA						
													TOTAL DEMAND AMPS: 90.78 AMPS						

PANEL 'LA'

LOCATION: MAINTENANCE ROOM 109				VOLTAGE: 208Y/120V 3Ø 4W				MIN. A/C RATING: 65K A/C				NOTES:					
TYPE: SQUARE-D				MAINS: 400A 8Ø MLO ☐ MCB				SURFACE				PROVIDE TYPED WRITTEN DIRECTORY					
FED FROM: MDP				LUGS: ☐ SUB-FEED ☐ FEED-THRU				ENCLOSURE: NEMA 1				PROVIDE GROUND & NEUTRAL BUS					
L	NO	CIRCUIT DESCRIPTION	NOTES	BRANCH CIRCUIT		BKR	LOAD KVA	PHASE #	LOAD KVA	BKR	BRANCH CIRCUIT		LUG	CIRCUIT DESCRIPTION	L		
				#	NEUT/ GND/ COND						#	NEUT/ GND/ COND					
1	RECEP - ELEC ROOM	12	12	12	1/2"	20/1	0.18	A	4.48	60/2	4	4	10	1.25"	21		
3	RECEP - MENS RESTROOM	12	12	12	1/2"	20/1	0.18	B	4.48	-	4	-	-	-	4		
5	RECEP - WOMENS RESTROOM	12	12	12	1/2"	20/1	0.18	C	4.48	60/2	4	4	10	1.25"	6		
7	REFRIGERATOR - BREAKROOM	12	12	12	1/2"	20/1	0.70	A	4.48	-	4	-	-	-	8		
9	RECEP - BREAKROOM	12	12	12	1/2"	20/1	0.18	B	2.40	30/3	10	10	10	3/4"	10		
11	RECEP - BREAKROOM	12	12	12	1/2"	20/1	0.18	C	2.40	-	10	-	-	-	12		
13	RECEP - BREAKROOM RESTROOM	12	12	12	1/2"	20/1	0.18	A	2.40	-	10	-	-	-	14		
15	RECEPS - LAUNDRY	12	12	12	1/2"	20/1	0.36	B	0.13	20/1	12	12	12	1/2"	16		
17	RECEPS - CORRIDOR	12	12	12	1/2"	20/1	0.72	C	0.08	20/1	12	12	12	1/2"	18		
19	RECEPS - OFFICES	12	12	12	1/2"	20/1	0.54	A	0.08	20/1	12	12	12	1/2"	20		
21	RECEPS - OFFICES	12	12	12	1/2"	20/1	0.90	B	0.08	20/1	12	12	12	1/2"	22		
23	RECEP - VESTIBULE	12	12	12	1/2"	20/1	0.18	C	0.13	20/1	12	12	12	1/2"	24		
25	RECEPS - EXTERIOR	10	10	10	10	20/1	0.72	A	1.00	20/1	12	12	12	1/2"	26		
27	RECEP - ELEVATOR PIT	12	12	12	1/2"	20/1	0.18	B	1.00	20/1	12	12	12	1/2"	28		
29	RECEP - ELEVATOR PIT	12	12	12	1/2"	20/1	0.18	C	1.00	20/1	12	12	12	1/2"	30		
31	SITE LIGHTING	-	-	-	-	20/2	0.64	A	1.00	20/1	12	12	12	1/2"	32		
33	-	-	-	-	-	0.64	B	1.00	20/1	12	12	12	1/2"	34			
35	SITE LIGHTING	-	-	-	-	20/2	0.64	C	1.66	20/1	12	12	12	1/2"	36		
37	-	-	-	-	-	0.64	A	1.66	20/1	12	12	12	1/2"	38			
39	POOL LIGHTING	12	12	12	3/4"	20/2	0.10	B	0.50	20/1	12	12	12	1/2"	40		
41	-	12	-	-	-	0.10	C	-	20/1	-	-	-	-	-	42		
43	CAR CHARGING STATION	6	6	10	1"	40/2	3.12	A	-	20/1	-	-	-	-	44		
45	-	6	-	-	-	3.12	B	-	20/1	-	-	-	-	-	46		
47	SPARE	-	-	-	-	20/1	-	C	-	20/1	-	-	-	-	48		
49	SPARE	-	-	-	-	20/1	-	A	-	20/1	-	-	-	-	50		
51	SPARE	-	-	-	-	20/1	-	B	-	20/1	-	-	-	-	52		
53	SPARE	-	-	-	-	20/1	-	C	-	20/1	-	-	-	-	54		
55	SPARE	-	-	-	-	20/1	-	A	-	20/1	-	-	-	-	56		
57	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	58		
59	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	60		
61	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	62		
63	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	64		
65	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	66		
67	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	68		
69	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	70		
71	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	72		
EQUIPMENT SERVED				CONN. LOAD				L.F.	D.F.	DEMAND LOAD							
LIGHTING				2.76 KVA					125%	3.45 KVA							
RECEPTACLES - GENERAL				4.86 KVA					**	4.86 KVA							
EQUIPMENT				41.38 KVA					100%	41.38 KVA							
NOTES:																	
*SPUIT & CONDENSING UNIT NOT INCLUDED IN LOAD CALC																	
FOR NEI 233.44																	
TOTAL DEMAND LOAD: 49.69 KVA																	
TOTAL DEMAND AMPS: 138.03 AMPS																	

PANEL 'PA'																				
LOCATION: MAINTENANCE ROOM 109				VOLTAGE: 208Y/120V 3ø 4W				MIN. AIC RATING: 22K AIC				NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS								
TYPE: SQUARE-D				MAINS: 300A 3Ø MLO □ MCB				MOUNTING: SURFACE												
FED FROM: MDP				LUGS: □ SUB-FEED □ FEED-THRU				ENCLOSURE: NEMA 1												
NO	CIRCUIT DESCRIPTION	NO/23	BRANCH CIRCUIT # NEUT/ GND COND	BKR	LOAD KVA	PHASE #	LOAD KVA	BKR	BRANCH CIRCUIT # NEUT/ GND COND	NO/23	CIRCUIT DESCRIPTION	NO/23	BRANCH CIRCUIT # NEUT/ GND COND	BKR	LOAD KVA	PHASE #	LOAD KVA	BKR	CIRCUIT DESCRIPTION	NO/23
1	TBT	12	12 12 1/2"	20/1	0.36	A	1.50	20/1	12 12 12 1/2"		TREADMILL	2								2
3	TBT	12	12 12 1/2"	20/1	0.36	B	1.50	20/1	12 12 12 1/2"		TREADMILL	3								3
5	TBT	12	12 12 1/2"	20/1	0.36	C	1.50	20/1	12 12 12 1/2"		TREADMILL	5								5
7	TBT	12	12 12 1/2"	20/1	0.36	A	1.50	20/1	12 12 12 1/2"		TREADMILL	7								7
9	RECEP - PBX ROOM	12	12 12 1/2"	20/1	0.36	B	1.00	20/1	12 12 12 1/2"		FITNESS EQUIPMENT	9								9
11	RECEP - PBX ROOM	12	12 12 1/2"	20/1	0.18	C	1.00	20/1	12 12 12 1/2"		FITNESS EQUIPMENT	11								11
13	RECEP - PBX ROOM	12	12 12 1/2"	20/1	0.18	A	1.00	20/1	12 12 12 1/2"		FITNESS EQUIPMENT	13								13
15	GUEST WASHER	12	12 12 1/2"	20/1	1.50	B	1.00	20/1	12 12 12 1/2"		FITNESS EQUIPMENT	15								15
17	GUEST WASHER	12	12 12 1/2"	20/1	1.50	C	0.54	20/1	12 12 12 1/2"		RECEPS - FITNESS	17								17
19	GUEST DRYER	10	10 3/4"	30/2	2.50	A	0.18	20/1	12 12 12 1/2"		RECEPS - FITNESS	19								19
21	-	10	-	-	2.50	B	0.18	20/1	12 12 12 1/2"		RECEPS - FITNESS	21								21
23	GUEST DRYER	10	10 3/4"	30/2	2.50	C	0.18	20/1	12 12 12 1/2"		RECEPS - FITNESS	23								23
25	-	10	-	-	2.50	A	0.18	20/1	12 12 12 1/2"		RECEPS - FITNESS	25								25
27	RECEPS - CORRIDOR	12	12 12 1/2"	20/1	0.54	B	0.36	20/1	12 12 12 1/2"		RECEPS - FITNESS	27								27
29	ICE MACHINE	12	12 12 1/2"	20/1	1.00	C	0.72	20/1	12 12 12 1/2"		RECEPS - FLEX	29								29
31	ICE MACHINE	12	12 12 1/2"	20/1	1.00	A	0.90	20/1	12 12 12 1/2"		RECEPS - COMMUNITY	31								31
33	SPARE	-	-	-	20/1	-	B	0.90	20/1	12 12 12 1/2"	RECEPS - COMMUNITY	33								33
35	SPARE	-	-	-	20/1	-	C	0.90	20/1	12 12 12 1/2"	RECEPS - COMMUNITY	35								35
37	SPARE	-	-	-	20/1	-	A	0.90	20/1	12 12 12 1/2"	RECEPS - HUB	37								37
39	SPARE	-	-	-	20/1	-	B	0.72	20/1	12 12 12 1/2"	RECEPS - HUB	39								39
41	SPARE	-	-	-	20/1	-	C	0.54	20/1	10 10 1/2"	RECEPS - EXTERIOR	41								41
43	SPARE	-	-	-	20/1	-	A	0.18	20/1	12 12 12 1/2"	RECEPS - EXTERIOR	43								43
45	SPARE	-	-	-	20/1	-	B	0.18	20/1	12 12 12 1/2"	GAS GRILL	45								45
47	SPARE	-	-	-	20/1	-	C	0.18	20/1	12 12 12 1/2"	GAS GRILL	47								47
49	SPARE	-	-	-	20/1	-	A	0.18	20/1	12 12 12 1/2"	GAS FIREPIT	49								49
51	SPACE ONLY	-	-	-	20/1	-	B	-	-	-	SPACE ONLY	51								51
53	SPACE ONLY	-	-	-	20/1	-	C	-	-	-	SPACE ONLY	53								53
55	SPACE ONLY	-	-	-	20/1	-	A	-	-	-	SPACE ONLY	55								55
57	SPACE ONLY	-	-	-	20/1	-	B	-	-	-	SPACE ONLY	57								57
59	SPACE ONLY	-	-	-	20/1	-	C	-	-	-	SPACE ONLY	59								59
61	SPACE ONLY	-	-	-	20/1	-	A	-	-	-	SPACE ONLY	61								61
63	SPACE ONLY	-	-	-	20/1	-	B	-	-	-	SPACE ONLY	63								63
65	SPACE ONLY	-	-	-	20/1	-	C	-	-	-	SPACE ONLY	65								65
67	SPACE ONLY	-	-	-	20/1	-	A	-	-	-	SPACE ONLY	67								67
69	SPACE ONLY	-	-	-	20/1	-	B	-	-	-	SPACE ONLY	69								69
71	SPACE ONLY	-	-	-	20/1	-	C	-	-	-	SPACE ONLY	71								71
EQUIPMENT SERVED					CONN. LOAD		L.F.	D.F.	DEMAND LOAD											
LIGHTING					- KVA			125%	- KVA											
RECEPTACLES - GENERAL					8.64 KVA			**	8.64 KVA											
EQUIPMENT					26.62 KVA			100%	26.62 KVA											
NOTES: *SPUL A/C CONDENSING UNIT NOT INCLUDED IN LOAD CALC PER NEC 220.44											TOTAL DEMAND LOAD: 35.26 KVA									
											TOTAL DEMAND AMPS: 97.94 AMPS									


PANEL 'HA'																					
LOCATION: PBX ROOM				VOLTAGE: 208Y/120V 3ø 4w				MIN. A/C RATING: 22K A/C				NOTES:									
TYPE: SQUARE-D				MAINS: 200A 3Ø MLO ☐ MCB				MOUNTINGS: SURFACE				PROVIDE TYPED WRITTEN DIRECTORY									
FED FROM: MDP				LUGS: ☐ SUB-FEED ☐ FEED-THRU				ENCLOSURE: NEMA 1				PROVIDE GROUND & NEUTRAL BUS									
L	NO	CIRCUIT DESCRIPTION						NO	23	BRANCH CIRCUIT # NEUT/ GND CON/0	BKR	LOAD KVA	PHASE #	LOAD KVA	BKR	BRANCH CIRCUIT # NEUT/ GND CON/0	NO	23	CIRCUIT DESCRIPTION	L	NO
1	DWSP-1	12	12	12	3/4"	20/3	1.27	A	3.72	45/2	6	6	10	1"	AHU-1	2	2				
3	-	12	-	-	-	-	1.27	B	3.72	-	6	-	-	-		4	3				
5	-	12	-	-	-	-	1.27	C	2.36	30/2	10	10	10	3/4"	AHU-3	6	5				
7	DWH-1	12	12	12	1/2"	20/1	0.54	A	2.36	-	10	-	-	-		8	7				
9	WS-1	12	12	12	1/2"	20/1	0.36	B	3.72	45/2	6	6	10	1"	AHU-4	10	9				
11	HWCP-1	12	12	12	1/2"	20/1	0.48	C	3.72	-	6	-	-	-		12	11				
13	HWCP-2	12	12	12	1/2"	20/1	0.48	A	0.13	20/1	12	12	12	1/2"	EF-1.3	14	13				
15	RECEP - MECH	12	12	12	1/2"	20/1	0.18	B	0.07	20/1	12	12	12	1/2"	EF-1.4	16	15				
17	SPARE	-	-	-	-	20/1	-	C	0.13	20/1	12	12	12	1/2"	EF-1.8	18	17				
19	SPARE	-	-	-	-	20/1	-	A	0.70	20/1	12	12	12	1/2"	EWC	20	19				
21	SPARE	-	-	-	-	20/1	-	B	-	20/1	-	-	-	-	SPARE	22	21				
23	SPARE	-	-	-	-	20/1	-	C	-	20/1	-	-	-	-	SPARE	24	23				
25	SPARE	-	-	-	-	20/1	-	A	-	20/1	-	-	-	-	SPARE	26	25				
27	SPACE ONLY	-	-	-	-	-	-	B	-	20/1	-	-	-	-	SPARE	28	27				
29	SPACE ONLY	-	-	-	-	-	-	C	-	20/1	-	-	-	-	SPARE	30	29				
31	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	32	31				
33	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	34	33				
35	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	36	35				
37	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	38	37				
39	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	40	39				
41	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	42	41				
43	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	44	43				
45	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	46	45				
47	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	48	47				
49	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	50	49				
51	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	52	51				
53	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	54	53				
55	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	56	55				
57	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	58	57				
59	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	60	59				
61	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	62	61				
63	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	64	63				
65	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	66	65				
67	SPACE ONLY	-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	68	67				
69	SPACE ONLY	-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	70	69				
71	SPACE ONLY	-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	72	71				
EQUIPMENT SERVED								CONN. LOAD	L.F.	D.F.	DEMAND LOAD										
LIGHTING								- KVA		125%	- KVA										
RECEPTACLES - GENERAL								0.18 KVA		**	0.18 KVA										
EQUIPMENT								26.30 KVA		100%	26.30 KVA										
NOTES:														TOTAL DEMAND LOAD: 26.48 KVA							
*SPILT A/C CONDENSING UNIT NOT INCLUDED IN LOAD CALC														TOTAL DEMAND AMPS: 73.56 AMPS							
** PER NEC 220.44																					

PANEL 'LB1'																	
LOCATION: 3RD FLOOR HOUSEKEEPING				VOLTAGE: 208Y/120V 3W 4W				MIN. AIR RATING: 22K AIC				NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS					
TYPE: SQUARE-D				MAINS: 100A ☒ MLO ☐ MCB				MOUNTING: SURFACE									
FED FROM: MDP				LUGS: ☐ SUB-FEED ☐ FEED-THRU				ENCLOSURE: NEMA 1									
%	CIRCUIT DESCRIPTION	NOTES	#	BRANCH CIRCUIT	GRND	COND	BKR	LOAD KVA	PHASE #	LOAD KVA	BKR	#	BRANCH CIRCUIT	GRND	COND	CIRCUIT DESCRIPTION	%
1	T1B		12	12	12	1/2"	20/1	0.36	A	0.90	20/1	10	10	10	1/2"	RECEP - 2ND FLOOR CORRIDOR	2
3	T1B		12	12	12	1/2"	20/1	0.36	B	0.18	20/1	12	12	12	1/2"	RECEP - 2ND FLOOR ELEVATOR LOBBY	4
5	T1B		12	12	12	1/2"	20/1	0.36	C	1.00	20/1	12	12	12	1/2"	2ND FLOOR ICE MACHINE	6
7	SPACE ONLY		-	-	-	-	-	-	A	1.00	20/1	12	12	12	1/2"	2ND FLOOR ICE MACHINE	8
9	SPARE		-	-	-	-	20/1	-	B	0.90	20/1	12	12	12	1/2"	RECEP - 3RD FLOOR CORRIDOR	10
11	SPARE		-	-	-	-	20/1	-	C	0.18	20/1	12	12	12	1/2"	RECEP - 3RD FLOOR ELEVATOR LOBBY	12
13	SPARE		-	-	-	-	20/1	-	A	1.00	20/1	12	12	12	1/2"	3RD FLOOR ICE MACHINE	14
15	SPARE		-	-	-	-	20/1	-	B	1.00	20/1	12	12	12	1/2"	3RD FLOOR ICE MACHINE	16
17	SPARE		-	-	-	-	20/1	-	C	1.00	20/1	12	12	12	1/2"	NAC PANEL	18
19	SPARE		-	-	-	-	20/1	-	A	20/1	-	-	-	-	-	SPARE	20
21	SPARE		-	-	-	-	20/1	-	B	20/1	-	-	-	-	-	SPARE	22
23	SPARE		-	-	-	-	20/1	-	C	20/1	-	-	-	-	-	SPARE	24
25	SPARE		-	-	-	-	20/1	-	A	20/1	-	-	-	-	-	SPARE	26
27	SPARE		-	-	-	-	20/1	-	B	20/1	-	-	-	-	-	SPARE	28
29	SPARE		-	-	-	-	20/1	-	C	20/1	-	-	-	-	-	SPARE	30
31	SPARE		-	-	-	-	20/1	-	A	20/1	-	-	-	-	-	SPARE	32
33	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	34
35	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	36
37	SPACE ONLY		-	-	-	-	-	-	A	-	-	-	-	-	-	SPACE ONLY	38
39	SPACE ONLY		-	-	-	-	-	-	B	-	-	-	-	-	-	SPACE ONLY	40
41	SPACE ONLY		-	-	-	-	-	-	C	-	-	-	-	-	-	SPACE ONLY	42
EQUIPMENT SERVED							CONN. LOAD	L.F.	D.F.	DEMAND LOAD							
LIGHTING							- KVA		125%	- KVA							
RECEPTACLES - GENERAL							2.16 KVA		100%	2.16 KVA							
EQUIPMENT							6.08 KVA		100%	6.08 KVA							
NOTES:																	

PANEL 'LB2'														
LOCATION: 5TH FLOOR HOUSEKEEPING				VOLTAGE: 208Y/120V 3Ø 4W				MIN. AIC RATING: 22K AIC				NOTES: PROVIDE TYPED WRITTEN DIRECTORY PROVIDE GROUND & NEUTRAL BUS		
TYPE: SQUARE-D				MAINS: 200A 3Ø WLO				MOUNTING: SURFACE						
FED FROM: MDP				LUGS: SUB-FEED				FEED-THRU						
CIRCUIT DESCRIPTION	NOTES	BRANCH CIRCUIT		BKR	LOAD KVA	PHASE	ENCLOSURE		BKR	BRANCH CIRCUIT		NOTES	CIRCUIT DESCRIPTION	
		#	NEUTR GND COND				#	NEUTR GND COND						
1 RECEPT - ROOF		12	12 1/2"	20/1	0.18	A	0.90	20/1	10	10 1/2"	RECEPT - 4TH FLOOR CORRIDOR		2	
3 RECEPT - ROOF		12	12 1/2"	20/1	0.18	B	1.18	20/1	12	12 1/2"	RECEPT - 4TH FLOOR ELEVATOR LOBBY		4	
5 RECEPT - ROOF		12	12 1/2"	20/1	0.18	C	0.18	20/1	12	12 1/2"	4TH FLOOR ICE MACHINE		6	
7 RECEPT - ELEVATOR SHAFT		12	12 1/2"	20/1	0.18	A	0.18	20/1	12	12 1/2"	4TH FLOOR ICE MACHINE		8	
9 RECEPT - ELEVATOR SHAFT		12	12 1/2"	20/1	0.18	B	0.90	20/1	12	12 1/2"	RECEPT - 5TH FLOOR CORRIDOR		10	
11 SPARE		-	-	20/1	-	C	0.18	20/1	12	12 1/2"	RECEPT - 5TH FLOOR ELEVATOR LOBBY		12	
13 LIGHTING - ROOF BEACON		10	10 3/4"	20/1	0.50	A	1.00	20/1	12	12 1/2"	5TH FLOOR ICE MACHINE		14	
15 LIGHTING - ROOF SIGN		10	10 3/4"	20/2	1.50	B	1.00	20/1	12	12 1/2"	5TH FLOOR ICE MACHINE		16	
17 -		10	-	-	1.50	C	1.00	20/1	12	12 1/2"	NAC PANEL		18	
19 SPARE		-	-	20/1	-	A	-	-	-	-	SPACE ONLY		20	
21 SPARE		-	-	20/1	-	B	-	-	-	-	SPACE ONLY		22	
23 CU-1.1		-	-	35/2	1.73	C	2.29	40/2	-	-	CU-1.2		24	
25 -		-	-	-	1.73	A	2.29	-	-	-	-		26	
27 CU-1.3		-	-	25/2	1.40	B	1.86	35/2	-	-	CU-1.4		28	
29 -		-	-	-	1.40	C	1.86	-	-	-	-		30	
31 CU-1.5		-	-	40/2	2.29	A	-	20/1	-	-	SPARE		32	
33 -		-	-	-	2.29	B	-	20/1	-	-	SPARE		34	
35 MCU-1.1		-	-	20/2	1.08	C	1.08	20/2	-	-	MCU-1.2		36	
37 -		-	-	-	1.08	A	1.08	-	-	-	-		38	
39 MCU-1.3		-	-	40/2	2.08	B	1.08	20/2	-	-	MCU-3.1		40	
41 -		-	-	-	2.08	C	1.08	-	-	-	-		42	
EQUIPMENT SERVED				CONN. LOAD		L.F.	D.F.		DEMAND LOAD					
LIGHTING				3.50 KVA			125%		4.38 KVA					
RECEPTACLES - GENERAL				2.52 KVA			100%		2.52 KVA					
EQUIPMENT				34.78 KVA			100%		34.78 KVA					
NOTES:											TOTAL DEMAND LOAD: 41.68 KVA			
											TOTAL DEMAND AMPS: 115.78 AMPS			

GUEST ROOM LIGHTING FIXTURE SCHEDULE									
MARK	DESCRIPTION	MANUFACTURER	MODEL	VOLTS	LAMP QTY	LAMP WATTS	LAMP MODEL	FIXTURE WATTS	
G1	SURFACE LED LIGHT IN ENTRY, AS SELECTED BY OWNER	OWNER SELECTED	OWNER SELECTED	120V	–	30	LED	30	
G2	6" ROUND LED DOWNLIGHT IN BATHROOM, AS SELECTED BY OWNER	OWNER SELECTED	OWNER SELECTED	120V	–	30	LED	30	
G3	LED SURFACE FIXTURE, WET RATED, AS SELECTED BY OWNER	OWNER SELECTED	OWNER SELECTED	120V	–	30	LED	30	
NOTES: 1. ALL FIXTURES AND FINISHES SHALL BE APPROVED BY ARCHITECT/OWNER PRIOR TO ORDERING. 2. ALL FIXTURES SHALL INCLUDE LAMPS.									


BUILDING LIGHTING FIXTURE SCHEDULE									
MARK	DESCRIPTION	MANUFACTURER	MODEL	VOLTS	LAMP QTY	LAMP WATTS	LAMP MODEL	FIXTURE WATTS	
A	2'X4' LED TROFFER	TBD	TBD	120V	–	52	LED	52	
B	4' SUSPENDED LED FIXTURE	TBD	TBD	120V	–	30	LED	30	
C	2'X2' LED TROFFER	TBD	TBD	120V	–	40	LED	40	
D1	6" ROUND LED DOWNLIGHT	TBD	TBD	120V	–	20	LED	20	
D2	ROUND LED DOWNLIGHT	TBD	TBD	120V	–	30	LED	30	
F	LED SURFACE WRAPAROUND WITH FROSTED ACRYLIC LENS, WHITE ACRYLIC MATTE HIGH REFLECTANCE PAINT FINISH	PHILLIPS	FSWEZ440L835–UNV	120V	–	32	LED	32	
G	LED WALL WASH	TBD	TBD	120V	–	15	LED	15	
H	DECORATIVE LED WALL FIXTURE, AS SELECTED BY OWNER	OWNER SELECTED	OWNER SELECTED	120V	–	35	LED	35	
J	4' WALL SURFACE MOUNT WITH WRAP AROUND LENS, EMERGENCY BATTERY BACK–UP, AND OCCUPANCY SENSORS FOR AUTOMATIC STEP DOWN LIGHTING	TBD	TBD	120V	–	50	LED	50	
P1	DECORATIVE PENDANT, LARGE (DIMMABLE)	OWNER SELECTED	OWNER SELECTED	120V	–	100	LED	100	
P2	DECORATIVE PENDANT, SMALL (DIMMABLE)	OWNER SELECTED	OWNER SELECTED	120V	–	50	LED	50	
P3	DECORATIVE PENDANT, SMALL (DIMMABLE)	OWNER SELECTED	OWNER SELECTED	120V	–	50	LED	50	
T	SURFACE VAPORTITE	H.E. WILLIAMS	97–4–L95/835–FR–DRV–UNV	120V	–	81	LED	81	
V	EXTERIOR LED DOWNLIGHT	TBD	TBD	120V	–	25	LED	25	
W1	DECORATIVE EXTERIOR LED WALL SCONCE	TBD	TBD	120V	–	30	LED	30	
WE	EXTERIOR LED WALL PACK	TBD	TBD	120V	–	30	LED	30	
WP	EXTERIOR LED WALL SCONCE AT POOL	TBD	TBD	120V	–	30	LED	30	
Z17	EXTERIOR POLE MOUNTED LED FIXTURE AT POOL	TBD	TBD	120V	–	150	LED	150	
Z50	EXTERIOR BOLLARD FIXTURE	TBD	TBD	120V	–	32	LED	32	
Z65	EXTERIOR POLE MOUNTED LED FIXTURE AT ENTRY	TBD	TBD	120V	–	20	LED	20	
Z96	EXTERIOR LED STRIP LIGHT	PHILLIPS	FSS430L840UNVDM	120V	–	17	LED	17	
Z97	EXTERIOR LED STRIP LIGHT	EATON	LM–10L–940–120–00–UNV–S–SM–S T–D	120V	–	20	LED	20	
Z	BACK OF HOUSE 2–HEAD EMERGENCY	DUAL LITE	EV2	120V	–	17	LED	–	
X1	ARCHITECTURAL EDGE LIT EXIT – SINGLE SIDED, GREEN LETTERS	DUAL LITE	LE SERIES EDGE LIT EXITS	120V	–	–	LED	–	
X2	ARCHITECTURAL EDGE LIT EXIT – DOUBLE SIDED, GREEN LETTERS	DUAL LITE	LE SERIES EDGE LIT EXITS	120V	–	–	LED	–	
X3	BACK OF HOUSE COMBINATION EXIT/EM FIXTURE, GREEN LETTERS	DUAL LITE	HCX SERIES	120V	–	–	LED	–	
NOTES: 1. ALL FIXTURES AND FINISHES SHALL BE APPROVED BY ARCHITECT/OWNER PRIOR TO ORDERING. 2. ALL FIXTURES SHALL INCLUDE LAMPS.									



Consulting Engineers

1850 HARWOOD AVE., SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLC&C.COM
CA NO. 28730

JLC 21.0042.00




HARTER - ADAMS P.A.
ARCHITECTS AND PLANNERS
377 MATILAN AVE., SUITE 200, ALTAMONTE SPRINGS, FL 32701
PHONE 407.647.5757 FAX 407.647.2802


TOWNEPLACE
SUITES®
BY MARRIOTT

TOWNEPLACE SUITES HOTEL
LAKE CITY HOTELS, INC.
NW COMMERCE DRIVE, LAKE CITY, FLORIDA


REVISION
JOB NO.
DATE
SHEET
E7.5
OF




4 COMMUNICATION RISER DIAGRAM
NTS




5 CONTACTOR 'LC1' SCHEMATIC -
PHOTOCELL & TIMECLOCK CONTROLLED
NTS




6 STANDARD MOUNTING HEIGHT DETAIL
NTS



1 ROOF PENETRATION
WEATHERPROOF DETAIL
NTS



2 UL FIRE RATED DETAIL (W-J-1020)
NTS



3 UL FIRE RATED DETAIL (W-L-1175)
NTS

