


GABLE END GYPSUM DIAPHRAGM HOLDOWN CONNECTOR

SCALE: NONE




END WALL BRACING FOR CEILING DIAPHRAGM

1 2'-0" MIN.

SCALE: 1/2" = 1'-0"


(ALTERNATIVE TO BALLOON FRAMING)

NOTE: ALL WOOD TO BE NUMBER 2 GRADE SOUTHERN YELLOW PINE



NAILING SHEATHING FASTENER


ROOF SHEATHING FASTENINGS




SPACING


ROOF SHEATHING NAILING ZONES ROOF SHEATHING NAILING ZONES (GABLE ROOF) (HIP ROOF)

Roof Nail Pattern DET.






Garage SIDE Wall DETAILS




SCALE: NONE


WALL CORNER WALL INTERSECTION



TYPICAL WINDOW HEADER





NON-BEARING WALL HEADER



BEARING WALL HEADER








Girder Truss Column DET.

SCALE: 1/2" = 1'-0"




TYP, PERMANENT TRUSS BRACING DIA.

NOTE: ALL WOOD TO BE NUMBER 2 GRADE SOUTHERN YELLOW PINE

Truss Bracing DETAILS

SCALE: AS NOTED



SHEARWALL NOTES: 1. ALL SHEARWALLS SHALL BE TYPE 2 SHEARWALLS

D

- 2. THE WALL SHALL BE ENTIRELY SHEATHED WITH 7/16" WINDSTORM BD INCLUDING AREAS ABOVE AND BELOW
- 3. ALL SHEATHING SHALL BE ATTACHED TO FRAMING ALONG ALL FOUR EDGES WITH JOINTS FOR ADJACENT PANELS OCCURING OVER COMMON FRAMING MEMBERS
- 4. NAIL SPACING SHALL BE 6" O.C. EDGES AND 12" O.C. IN THE FIELD.


OR ALONG BLOCKING.


5. TYPE 2 SHEARWALLS ARE DESIGNED FOR THE OPENING IT CONTAINS, MAXIMUM HEIGHT OF OPENING SHALL BE 5/6 TIMES THE WALL HEIGHT, THE MINIMUM DISTANCE BETWEEN OPENINGS SHALL BE THE WALL HEIGHT/3.5 FOR 8'-0" WALLS (2'-3"),


| OPENING WIDTH | SILL Plates | 16d TOE NAILS EACH END |
|----------------|--------------------|---------------------------|
| "0-'0 OT PU | (1) 2x4 OR (1) 2x6 | 1 |
| > 6' TO 9'-0" | (3) 2x4 OR (1) 2x6 | 2 |
| > 9' TO 12'-0" | (5) 2x4 OR (2) 2x6 | 3 |




SCALE: NONE











SHEET NUMBER OF 4 SHEETS

Digitally signed by: N. P. GEISLER DN: CN = N. P. GEISLER C = US O = AR00 7005 OU = ARCHITE¢T Date: 2021.07.06 16:52:10 -05'00'