

28 FEBRUARY 2020

TROY CREWS, BUILDING OFFICIAL
COLUMBIA COUNTY, BUILDING DEPT.
COLUMBIA COUNTY COURTHOUSE ANNEX
LAKE CITY, FLORIDA 32055

RE: 126 SW WHITE ASH GLEN, LAKE CITY, FL
PERMIT Nr.: 38910


DEAR SIR:

PLEASE BE ADVISED OF THE FOLLOWING CHANGES TO THE CONSTRUCTION DOCUMENTS FOR THE ABOVE REFERENCED PROJECT.

1. IN LIEU OF WIRE CHAIRS FOR SUPPORT OF THE FOUNDATION REINFORCING, IT IS PERMISSIBLE TO EMPLOY PLASTIC CHAIRS FOR SUCH PURPOSE.
2. IN AREAS WHERE POCKETS OF CLAY SUBSOIL ARE ENCOUNTERED, STACK AN ADDITIONAL LAYER OF PLASTIC CHAIRS OVER THE BOTTOM REINFORCING CHAIRS AND ADD 2 #5 REBAR X MIN. 10'-0" LONG, CENTERED OVER THE CLAY POCKET AND EXTENDING AT LEAST 36" TO EACH SIDE OF THE CLAY POCKET ALONG THE TOP OF THE FOOTING.

SHOULD YOU HAVE ANY FURTHER QUESTIONS WITH THIS, PLEASE CALL FOR ASSISTANCE.

YOURS TRULY,
NICHOLAS PAUL GEISLER, ARCHITECT AR0007005



Digitally signed by: N. P. GEISLER
DN: CN = N. P. GEISLER C = US
O = AR0007005 OU = ARCHITECT
Date: 2020.02.28 14:45:38 -05'00'