

Columbia County, FL. New Residential Construction Permit #000048837 Issued December 12, 2023



* Request inspections by calling 386-719-2023 or visiting https://www.columbiacountyfla.com/PermitSearch/InspectionCalendar.aspx

OWNER: GATOR LAND DEVELOPMENT, PHOI

PLUMBING CONTRACTOR

PHONE: 386-365-5671

ADDRESS: 234 SW CHERRY BLOSSOM WAY LAKE CITY,

FL 32024

PARCEL: 15-4S-16-03011-124

ZONING: RESIDENTIAL - LOW PRD

CODY BARRS

FLOOD ZONE: X

LOT: 24 BLK: PHASE: UNIT: ACRES: 0.48

Coords: 30.14,-82.70

SUBDIVISION: ROSE POINTE

NAME: JOSEPH C PEURRUNG

CONTRACTORS

ADDRESS: 7585 216TH ST

PHONE: 386.362.9223

BUSINESS: BENCHMARK BUILDERS LLC

O'BRIEN, FL 32071 **LICENSE**: CBC1259347 -

BARRS PLUMBING INC

License	License Title	Contractor	Business
CCC1330509	CERT. ROOFING	BENJAMIN T KEELER	KEELER ROOFING, LLC
EC13005459	ELECTRICAL CONTRACTOR	MARCUS MATTHEWS	MATTHEWS ELECTRIC LLC
CAC1816766	CLASS "B" A/C	ROBERT JARVIS	JARVIS HEAT AND AIR LLC

PROJECT DETAILS

CFC1427145

MFE= 105' PER PLAT - SURVEYOR LETTER NEEDED BY NAILING INSPECTION TO CONFIRM

THIS IS THE CONSTRUCTION OF A:	Single Family Dwelling
HEATED AREA (SQFT):	1596
TOTAL AREA (SQFT):	2225
STORIES:	1
BUILDING HEIGHT:	12
BUILDING CODE CONSTRUCTION TYPE:	V
BUILDING CODE ELEMENT:	В
BUILDING CODE OCCUPANCY TYPES:	Residential
OCCUPANCY USE TITLE:	single family dwelling
SETBACKS FRONT:	25'
SETBACK SIDE 1:	10'
SETBACK SIDE 2:	10'
SETBACKS REAR:	15'
SEPTIC# (00-0000) OR (X00-000):	23-0805
(/ //-	

NOTICE: Addition to the requirements of this permit, there may be restrictions applicable to this property that may be found in the public records of this county and there may be additional permits required from other governmental entities such as water management districts, state or federal agencies.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. A NOTICE OF COMMENCEMENT MUST BE POSTED ON THE JOB SITE BEFORE THE FIRST INSPECTION. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

NOTICE: All work is to be completed in accordance with the permitted plans and applicable codes of Columbia County, Florida. In order to maintain a valid permit the work authorized must commence within 180 days of issuance and have an approved inspection within every 180 days thereafter.

MUST POST ON THE JOBSITE: Copies of the Permit and Recorded Notice of Commencement for inspection.

BUILDING CODE EDITION: ELEVATION REGULATION SUDdivision REQUIREMENT: FINISHED FLOOR REQUIREMENT: FINISHED FLOOR REQUIREMENT: FOR EQUIREMENT NEEDED: SUBJECT OF THE EDED IS: SURVEYOR FERDED IS: SURVEYOR FERDE	ELEVATION REGULATION FINISHED FLOOR REQUIREMENT: REQUIREMENT NEEDED: DOCUMENT NEEDED IS: DOCUMENT RECEIEVED: DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire		
FINISHED FLOOR REQUIREMENT: REQUIREMENT NEEDED: DOCUMENT NEEDED IS: DOCUMENT RECEIEVED: DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 % - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	FINISHED FLOOR REQUIREMENT: REQUIREMENT NEEDED: DOCUMENT NEEDED IS: DOCUMENT RECEIEVED: DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 % - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	BUILDING CODE EDITION:	2020 Florida Building Code 7th Edition and 2017 National Electrical Code
FINISHED FLOOR REQUIREMENT: REQUIREMENT NEEDED: DOCUMENT NEEDED IS: DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	FINISHED FLOOR REQUIREMENT: REQUIREMENT NEEDED: DOCUMENT NEEDED IS: DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	ELEVATION REGULATION	Subdivision Plat
REQUIREMENT NEEDED: DOCUMENT NEEDED IS: DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	REQUIREMENT NEEDED: DOCUMENT NEEDED IS: a Surveyor letter giving the Finished Floor Elevation DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	FINISHED FLOOR REQUIREMENT:	105'
DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	DOCUMENT RECEIEVED: FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): A minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ½ - inch wide strip of selfadhering flexible flashing tape complying with AATM 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	REQUIREMENT NEEDED:	By Nailing Inspection
FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 % - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ½ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	DOCUMENT NEEDED IS:	
FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	FEMA MAP NUMBER: IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	DOCUMENT RECEIEVED :	No
IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾- inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	IN FLOODWAY: SEALED ROOF DECKING OPTIONS. (MUST SELECT ONE OPTION PER FBC 2020 7TH EDITION): a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	FEMA MAP NUMBER :	12023_0280_0
PER FBC 2020 7TH EDITION): with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	PER FBC 2020 7TH EDITION): with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire	IN FLOODWAY:	
			with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire
	i		

NOTICE: Addition to the requirements of this permit, there may be restrictions applicable to this property that may be found in the public records of this county and there may be additional permits required from other governmental entities such as water management districts, state or federal agencies.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. A NOTICE OF COMMENCEMENT MUST BE POSTED ON THE JOB SITE BEFORE THE FIRST INSPECTION. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

NOTICE: All work is to be completed in accordance with the permitted plans and applicable codes of Columbia County, Florida. In order to maintain a valid permit the work authorized must commence within 180 days of issuance and have an approved inspection within every 180 days thereafter.

MUST POST ON THE JOBSITE: Copies of the Permit and Recorded Notice of Commencement for inspection.