



**Project Summary**  
**Entire House**  
**Glenn I. Jones, Inc.**

Job  
Date April 11, 2013  
By

552 NW Hilton Ave, Lake City, FL 32055 Phone 386-752-5389 Fax 386-755-3401 Email byron@glijinc.com Web www.glennijonesinc.com

## Project Information

For Eric Norman  
203 SW Green Acres Way, Lake City, FL 32024  
Phone 386-867-0918

Notes.

## Design Information

Weather Gainesville, FL, US

### Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	37 °F

### Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	52 gr/lb

### Heating Summary

Structure	40345 Btuh
Ducts	10974 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	51318 Btuh

### Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

	Heating	Cooling
Area (ft²)	2784	2784
Volume (ft³)	23328	23328
Air changes/hour	0.46	0.21
Equiv. AVF (cfm)	179	82

### Heating Equipment Summary

Make	Carrier
Trade	Base Carrier
Model	25hbc548
AHRI ref	3646319

Efficiency	8.5 HSPF
Heating input	
Heating output	45500 Btuh @ 47°F
Temperature rise	26 °F
Actual air flow	1598 cfm
Air flow factor	0.031 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	

### Sensible Cooling Equipment Load Sizing

Structure	25478 Btuh
Ducts	13511 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	37819 Btuh

### Latent Cooling Equipment Load Sizing

Structure	4471 Btuh
Ducts	3134 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	7605 Btuh
Equipment total load	45424 Btuh
Req. total capacity at 0.84 SHR	3.8 ton

### Cooling Equipment Summary

Make	Carrier
Trade	Base Carrier
Cond	25hbc548
Coil	FX4DNF048T
AHRI ref	3646319
Efficiency	15 SEER
Sensible cooling	39900 Btuh
Latent cooling	7600 Btuh
Total cooling	47500 Btuh
Actual air flow	1598 cfm
Air flow factor	0.041 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0.84

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed



Right-Suite® Universal 2012 12 1 06 RSU01086

R:\Wrightsoft HVAC\Project\Norman Eric.rup Calc = MJ8 Front Door faces N

2013-Apr-11 10:41:41

Page 1



This combination qualifies for a Federal Energy Efficiency Tax Credit when placed in service between Feb 17, 2009 and Dec 31, 2013.

# Certificate of Product Ratings

AHRI Certified Reference Number: 3646319

Date: 4/11/2013

Product: Split System: Heat Pump with Remote Outdoor Unit-Air-Source

Outdoor Unit Model Number: 25HBC548A\*\*30

Indoor Unit Model Number: FX4DN(B,F)049

Manufacturer: CARRIER AIR CONDITIONING

Trade/Brand name: COMFORT 13 PURON HP

Manufacturer responsible for the rating of this system combination is CARRIER AIR CONDITIONING

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh)	47500
EER Rating (Cooling).	12 50
SEER Rating (Cooling)	15 00
Heating Capacity(Btuh) @ 47 F	45500*
Region IV HSPF Rating (Heating)	8 50
Heating Capacity(Btuh) @ 17 F	29000

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data unless accompanied with a WAS which indicates an involuntary rerate

## DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org)

## TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced, copied, disseminated, entered into a computer database, or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

## CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.



Air-Conditioning, Heating and Refrigeration Institute

©2013 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.: 130101642250997324

**GLENN I. JONES INC.**

**COOLING • HEATING  
SPECIALISTS**

***State Cert. # CAC051486***

552 N W Hilton Ave Lake City, FL 32055  
386 752-5389 fax 386-755-3401

gij@bellsouth.net

04/11/2013

Reference:HVAC permit

Eric Norman Home

Material proposal

Mastic

Foil tape

Insulation wrap

PVC drain piping

Equipment:

Carrier a 25HBC548, CE0901N10, TC-PHP01 and FX4DNF048T