

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler – Please type or print legibly)

Well #1
System Name: COLUMBIA COUNTY - ELLISVILLE 1-75|441 PWS I.D. #:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: 135 NE HERNANDEZ AVE

City: LAKE CITY State: FL ZIP Code: 32055

Phone #: 386-758-1005 Fax #: 386-758-2182

E-Mail Address: HUGWELL1840@AOL.COM

SAMPLE INFORMATION (to be completed by sampler)

CK Sample Number: WELL HEAD #1 REPEAT Location Code (if known): _____

Sample Date: 5-27-09 Sample Time: 8:00 AM PM (Circle One)

Sample Location (be specific): WELL HEAD ELLISVILLE 1-75|441

Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

Reason(s) for Sample (Check all that apply)

- Routine Compliance (with 62-550)
- Confirmation of MCL Exceedance*
- Composite of Multiple Sites**
- Clearance (permitting)
- Other: _____
- Quarterly (Which Quarter? _____)
- Special (not for compliance with 62-550)
- Violation Resolution
- Replacement (of Invalidated Sample)

Sampling Procedure Used or Other Comments: _____

*See 62-550.500(6) for requirements and restrictions.
NOTE: See 62-550.512(3) for additional requirements for nitrate or nitrite MCL exceedances.

**See 62-550.550(4) for requirements and attach a results page for each site.

Sampler's Name: RONNIE HUGHES

Sampler's Phone #: 386-752-1840 Sampler's Fax #: 386-758-2934

Sampler's E-Mail Address: HUGWELL1840@AOL.COM

CERTIFICATION (to be completed by sampler)

I, RONNIE HUGHES, OWNER
(Print Name) (Print Title)

do HEREBY CERTIFY that the above public water system and sample collection information is complete and correct.

Signature: Ronnie Hughes Date: 5-27-09

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

LABORATORY CERTIFICATION INFORMATION (to be completed by lab – Please type or print legibly)

ATTACH CURRENT DOH ANALYTE SHEET*

Lab Name: Advanced Environmental Laboratories, Inc. Florida Certification #: E82001
 Address: 6815 SW Archer Road Certification Expiration Date: 6/30/2009
Gainesville, Florida 32608 Phone #: 352-377-2349

ANALYSIS INFORMATION (to be completed by lab) Date Sample(s) Received: 5-27-09
 PWS ID (From Page 1): _____ Sample Number (From Page 1): 0905410 – 01

Lab Assigned Report Number or Job ID: 0905410

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

- | | | | |
|---|---|---|--|
| <u>Inorganics</u> | <u>Synthetic Organics</u> | <u>Volatile Organics</u> | <u>Disinfection Byproducts</u> |
| <input type="checkbox"/> All 17 | <input type="checkbox"/> All 30 | <input checked="" type="checkbox"/> All 21 | <input type="checkbox"/> Trihalomethanes |
| <input checked="" type="checkbox"/> Partial | <input checked="" type="checkbox"/> All Except Dioxin | <input type="checkbox"/> Partial | <input type="checkbox"/> Haloacetic Acids |
| <input type="checkbox"/> Nitrate | <input type="checkbox"/> Partial | <u>Radionuclides</u> | <input type="checkbox"/> Bromate |
| <input type="checkbox"/> Nitrite | <input type="checkbox"/> Dioxin Only | <input checked="" type="checkbox"/> Single Sample | <input type="checkbox"/> Chlorite |
| <input type="checkbox"/> Asbestos Only | | <input type="checkbox"/> Qtrly Composite** | <u>Secondaries</u> |
| | | | <input checked="" type="checkbox"/> All 14 |
| | | | <input type="checkbox"/> Partial |

Were any analyses subcontracted? Yes No


If yes, please provide DOH certification numbers: E82574, E84589, E83003

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB*

CERTIFICATION

I, Karen Daniels, Laboratory Manager
 (Print Name) (Print Title)

do HEREBY CERTIFY that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 6/10/09

* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

** Please provide radiological sample dates & locations for each quarter.

COMPLIANCE DETERMINATION (to be completed by DEP or DOH)

Sample Collection Info Satisfactory: Yes No Sample Analysis Info Satisfactory: Yes No

Replacement Sample(s) Requested (circle or highlight group(s) above) Revised Report Requested (circle or highlight group(s) above)

Additional Monitoring Required (circle or highlight group(s) above)

Reason(s): MCL(s) Exceeded Detection(s) Incomplete Report
 Missing Analyte Sheet(s) Location Unsatisfactory Analysis Unsatisfactory
 Other: _____

Person Notified: _____ Date Notified: _____

Comments: _____

Date Reviewed: _____ DEP/DOH Reviewing Official: _____

COPY

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

COPY

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: 0905410-01
PWS ID (From Page 1): _____

Contam ID	Contam Name	Unit	Analysis Result	Qualifier	Analytical Method	Lab MDL	Analysis Date	Analysis Time	Certification #
1040	NITRATE	mg/L	0.1	U	E300.0	0.1	5/28/09	12:58	E82001
1041	NITR	mg/L	0.1	U	E300.0	0.1	5/28/09	12:58	E82001
1025	AMMONIA	mg/L	0.3		E300.0	0.05	5/28/2009	12:58	E82001

Reporting Format 62-550.730
Effective January 1995. Revised January 2007

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

COPY

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: J0904136001 10905410-01

PWS ID (From Page 1):

Contam. ID	Contam. Name	MCL	Units	Analysis Result	Qualifier	Analytical Method	Lab MCL	Analysis Date	Analysis Time	DOH Lab Certification
	Arsenic	0.010	mg/L	0.003		EPA 200.8	0.00072	06/03/2009	01:57	E82574
	Barium	2	mg/L	0.01		EPA 200.7	0.00028	06/02/2009	17:21	E82574
	Bromine	0.050	mg/L	0.00016	U	EPA 200.8	0.00016	06/03/2009	01:57	E82574
	Chloride	250	mg/L	0.00033	U	EPA 200.8	0.00033	06/03/2009	01:57	E82574
	Copper	0.010	mg/L	0.00025	I	EPA 200.8	0.00012	06/08/2009	21:22	E82574
	Fluoride	2.0	mg/L	0.000014	U	EPA 245.1	0.000014	06/04/2009	14:38	E82574
	Iron	0.3	mg/L	0.00043	I	EPA 200.8	0.00032	06/03/2009	01:57	E82574
	Lead	0.010	mg/L	0.00098	U	EPA 200.8	0.00098	06/03/2009	01:57	E82574
	Nitrate	10	mg/L	9.2		EPA 200.7	0.026	06/02/2009	17:21	E82574
	Nitrite	0.060	mg/L	0.00018	U	EPA 200.8	0.00018	06/03/2009	01:57	E82574
	Sulfate	0.004	mg/L	0.00013	U	EPA 200.7	0.00013	06/02/2009	17:21	E82574
	Turbidity	0.002	mg/L	0.000061	U	EPA 200.8	0.000061	06/03/2009	01:57	E82574

Reporting Format 62-550.730
Effective January 1995. Revised January 2004

2 of 8
Page 1 of 4

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-180, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: T0907973001 *10905410-01*

PWS ID (From Page 1): _____

Contaminant Name	Unit	Result	Qualifier	Analytical Method	Lab ID	Analysis Date	Analysis Time	Lab ID
Cyanide	mg/L	0.00097	U	SM 4500-CN-E	0.00097	06/08/2009	17:52	E84589

COPY

Reporting Format 62-550.730
Effective January 1995. Revised January 2004

Page 3 *of 8*

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

SECONDARY CONTAMINANTS
62-550.320

Report Number / Job ID: J0904136001 / 0905410-01

PWS ID (From Page 1): _____

Contam. ID	Contam Name	MCL	Units	Analysis Result	Qualifier	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1001	Aluminum	0.2	mg/l	0.061	U	EPA 200.7	0.061	06/02/2009	17:21	E82574
1002	Copper	1	mg/l	0.0006	I	EPA 200.8	0.00040	06/03/2009	01:57	E82574
1003	Iron	0.3	mg/l	0.038	U	EPA 200.7	0.038	06/02/2009	17:21	E82574
1004	Manganese	0.05	mg/l	0.053		EPA 200.8	0.00023	06/03/2009	01:57	E82574
1005	Silver	0.01	mg/l	0.000062	U	EPA 200.8	0.000062	06/08/2009	21:22	E82574
1006	Zinc	0.3	mg/l	0.011		EPA 200.7	0.0020	06/02/2009	17:21	E82574

COPY

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

COPY

SECONDARY CONTAMINANTS
62-550.320

Report Number / Job ID: 0905410-01
PWS ID (From Page 1): _____

Contaminant	Value	Qualifier	Analysis Method	Lab MDL	Analysis Date	Analysis Time	Signature
	15.0		E300.0	0.2	6/3/2009	13:12	E82001
	0.3		E300.0	0.05	5/28/2009	12:58	E82001
	102		E300.0	1.0	6/3/2009	14:08	E82001
	10.0	I	E110.2	5.0	5/27/2009	15:00	E82001
	20.0		SM2150B	1.0	5/27/2009	11:55	E82001
	7.2		E150.1	0.1	5/27/2009	17:00	E82001
	331		E160.1	3.0	5/27/2009	15:00	E82001
	0.052	I	E425.1	0.050	5/28/2009	17:50	E82001

Reporting Format 62-550.730
Effective January 1995. Revised January 2007

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, * are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

548

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

VOLATILE ORGANICS
62-550.310(4)(a)

Report Number / Job ID: J0904136001 105910-01
PWS ID (From Page 1): _____

COPY

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier	Analytical Method	Lab MDL	RDL	Analysis Date	Analysis Time	DOH Lab Certification #
2378	1,2,4-Trichlorobenzene	70	ug/L	0.22	U	EPA 524.2	0.22	0.5	05/29/2009	18:32	E82574
2380	cis-1,2-Dichloroethylene	70	ug/L	0.12	U	EPA 524.2	0.12	0.5	05/29/2009	18:32	E82574
2955	Xylenes (total)	10,000	ug/L	0.37	U	EPA 524.2	0.37	0.5	05/29/2009	18:32	E82574
2964	Dichloromethane	5	ug/L	0.32	U	EPA 524.2	0.32	0.5	05/29/2009	18:32	E82574
2968	o-Dichlorobenzene	500	ug/L	0.15	U	EPA 524.2	0.15	0.5	05/29/2009	18:32	E82574
2969	para-Dichlorobenzene	75	ug/L	0.26	U	EPA 524.2	0.26	0.5	05/29/2009	18:32	E82574
2975	Vinyl Chloride	1	ug/L	0.20	U	EPA 524.2	0.20	0.5	05/29/2009	18:32	E82574
2977	trans-1,2-Dichloroethylene	7	ug/L	0.17	U	EPA 524.2	0.17	0.5	05/29/2009	18:32	E82574
2979	trans-1,2-Dichloroethylene	100	ug/L	0.27	U	EPA 524.2	0.27	0.5	05/29/2009	18:32	E82574
2980	1,2-Dichloroethane	5	ug/L	0.18	U	EPA 524.2	0.18	0.5	05/29/2009	18:32	E82574
2981	1,1,1-Trichloroethane	200	ug/L	0.20	U	EPA 524.2	0.20	0.5	05/29/2009	18:32	E82574
2982	Carbon tetrachloride	5	ug/L	0.24	U	EPA 524.2	0.24	0.5	05/29/2009	18:32	E82574
2983	1,2-Dichloropropane	5	ug/L	0.21	U	EPA 524.2	0.21	0.5	05/29/2009	18:32	E82574
2984	Trichloroethylene	3	ug/L	0.14	U	EPA 524.2	0.14	0.5	05/29/2009	18:32	E82574
2985	1,1,2-Trichloroethane	5	ug/L	0.28	U	EPA 524.2	0.28	0.5	05/29/2009	18:32	E82574
2987	Tetrachloroethylene	2	ug/L	0.24	U	EPA 524.2	0.24	0.5	05/29/2009	18:32	E82574
2989	Monochlorobenzene	100	ug/L	0.19	U	EPA 524.2	0.19	0.5	05/29/2009	18:32	E82574
2990	Benzene	1	ug/L	0.17	U	EPA 524.2	0.17	0.5	05/29/2009	18:32	E82574
2991	Toluene	1,000	ug/L	0.21	U	EPA 524.2	0.21	0.5	05/29/2009	18:32	E82574
2992	Ethylbenzene	700	ug/L	0.13	U	EPA 524.2	0.13	0.5	05/29/2009	18:32	E82574
2996	Styrene	100	ug/L	0.11	U	EPA 524.2	0.11	0.5	05/29/2009	18:32	E82574

Reporting Format 62-550.730
Effective January 1995. Revised January 2004

Page 3 of 4 6 of 8

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a non-compliance violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

SYNTHETIC ORGANICS
62-550.310(4)(b)

Report Number / Job ID: J0904136001 / 10905410-01

PWS ID (From Page 1):

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier	Analytical Method	Lab MDL	RDL	Extraction Date	Analysis Date	Analysis Time	DOH Lab Certification
2005	Endrin	2	ug/L	0.0016	U	EPA 508	0.0016	0.01	06/01/2009	06/08/2009	14:15	E82574
2010	Lindane	0.2	ug/L	0.0033	U	EPA 508	0.0033	0.02	06/01/2009	06/08/2009	14:15	E82574
2015	Methoxychlor	40	ug/L	0.011	U	EPA 508	0.011	0.1	06/01/2009	06/08/2009	14:15	E82574
2020	Texaphenes	3	ug/L	0.091	U	EPA 508	0.091	1	06/01/2009	06/08/2009	14:15	E82574
2031	Dalapon	200	ug/L	1.0	U	EPA 515.3	1.0	1	05/30/2009	06/01/2009	11:22	E82574
2032	Diquat	20	ug/L	7.6	U	EPA 549.2	7.6	0.4	06/03/2009	06/03/2009	12:37	E82574
2039	Endosulfan	100	ug/L	2.8	U	EPA 548.1	2.8	9	06/02/2009	06/09/2009	09:49	E82574
2042	Glyphosate	700	ug/L	6.5	U	EPA 547	6.5	6	06/01/2009	06/01/2009	14:45	E82574
2045	Di(2-ethylhexyl)adipate	200	ug/L	0.95	U	EPA 525.2	0.95	0.6	06/03/2009	06/03/2009	18:11	E82574
2046	Octamyl (Vydate)	200	ug/L	0.57	U	EPA 531.1	0.57	2	06/09/2009	06/09/2009	14:52	E82574
2047	Simazine	2	ug/L	0.19	U	EPA 525.2	0.19	0.07	06/03/2009	06/03/2009	18:11	E82574
2049	Di(2-Ethylhexyl)phthalate	5	ug/L	1.5	U	EPA 525.2	1.5	0.6	06/03/2009	06/03/2009	18:11	E82574
2070	Picloram	500	ug/L	0.23	U	EPA 515.3	0.23	0.1	05/30/2009	06/01/2009	11:22	E82574
2071	Dinoseb	7	ug/L	0.86	U	EPA 515.3	0.86	0.2	05/30/2009	06/01/2009	11:22	E82574
2074	Hexachlorocyclopentadiene	50	ug/L	0.014	U	EPA 508	0.014	0.1	06/01/2009	06/08/2009	14:15	E82574
2045	Carbofuran	20	ug/L	0.28	U	EPA 531.1	0.28	0.9	06/09/2009	06/09/2009	14:52	E82574
2050	Alachlor	3	ug/L	0.16	U	EPA 525.2	0.16	0.1	06/03/2009	06/03/2009	18:11	E82574
2051	Alachlor	2	ug/L	0.26	U	EPA 525.2	0.26	0.2	06/03/2009	06/03/2009	18:11	E82574
2065	Heptachlor	0.2	ug/L	0.0063	U	EPA 508	0.0063	0.04	06/01/2009	06/08/2009	14:15	E82574
2067	Heptachlor Epoxide	0.2	ug/L	0.0031	U	EPA 508	0.0031	0.02	06/01/2009	06/08/2009	14:15	E82574
2105	2,4-D	70	ug/L	1.5	U	EPA 515.3	1.5	0.1	05/30/2009	06/01/2009	11:22	E82574
2110	2,4,6-TP (Silvex)	50	ug/L	0.32	U	EPA 515.3	0.32	0.2	05/30/2009	06/01/2009	11:22	E82574
2272	Hexachlorobenzene	1	ug/L	0.0058	U	EPA 508	0.0058	0.1	06/01/2009	06/08/2009	14:15	E82574
2306	Benzo(a)pyrene	0.2	ug/L	0.096	U	EPA 525.2	0.096	0.02	06/03/2009	06/03/2009	18:11	E82574
2326	Benzo(a)phenanthrene	1	ug/L	0.069	U	EPA 515.3	0.069	0.04	05/30/2009	06/01/2009	11:22	E82574
2383	Polychlorinated biphenyls (PCB)	0.6	ug/L	0.11	U	EPA 508	0.11	0.1	06/01/2009	06/08/2009	14:15	E82574
2931	Dibromochloropropane	0.2	ug/L	0.0082	U	EPA 504.1	0.0082	0.02	06/02/2009	06/02/2009	23:16	E82574
2946	Ethylene Dibromide (EDB)	0.02	ug/L	0.0091	U	EPA 504.1	0.0091	0.01	06/02/2009	06/02/2009	23:16	E82574
2959	Chlordane	2	ug/L	0.048	U	EPA 508	0.048	0.2	06/01/2009	06/08/2009	14:15	E82574

NOTE: Effective January 1, 2004, results indicating non-detection with a reported lab MDL >50% of the MCL will not be accepted for compliance with 62-550.310(4)(b).

Reporting Format 62-550.730
Effective January 1995, Revised January 2004

Page 4 of 4 7 of 8

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ? are unacceptable for compliance with 62-550. Results qualified with a J, Q, P, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

COPY

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

COPY

RADIONUCLIDES
62-550.310(6)

Report Number / Job ID: 0905410-01
PWS ID (From Page 1): _____

Contaminant ID	Contaminant Name	Meq/L	Units	Analysis Result	Qualifier	Analytical Method	Lab MDL	RDI	Analysis Error	Analysis Date	Analysis Time	DQH Lab Certification #
4000	Uranium-238		µg/L	1.6	U	900	1.6	3.0	0.9	6/3/2009	13:28	E83033
4030	Radium-226		µg/L	0.5		903.1	0.10	1.0	0.10	6/9/2009	11:42	E83033
4030	Radium-226		µg/L	0.8	U	Ra-05	0.8	1.0	0.5	6/9/2009	12:05	E83033

** If the results exceed 5 pCi/L, a measurement for radium-226 is required.

*** If the results exceed 5 pCi/L, a measurement for radium-226 is required. If the results exceed 15 pCi/L, measurements for radium-226 and uranium are required.

**** If uranium (U) is reported as a measurement of activity (pCi/L) it will be converted to a mass measurement (ug/L) by multiplying the result by 1.5.

***** Reserved.

Reporting Format 62-550.730
Effective January 1995. Revised January 2007

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, R, * are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

8 of 8

Charlie Crist
Governor



Ana M. Viamonte Ros, M.D., M.P.H.
State Surgeon General

Laboratory Scope of Accreditation

Page 1 of 6

Attachment to Certificate #: E82001-21, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E82001

EPA Lab Code: FL00244

(352) 377-2349

E82001

Advanced Environmental Laboratories, Inc. - Gainesville
6815 SW Archer Road
Gainesville, FL 32608

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Chloride	EPA 300.0	Secondary Inorganic Contaminants	NELAP	4/1/2009
Color	SM 2120 B	Secondary Inorganic Contaminants	NELAP	4/1/2009
Escherichia coli	COLITAG	Microbiology	NELAP	2/1/2007
Fecal coliforms	SM 9222 D	Microbiology	NELAP	2/1/2007
Fluoride	EPA 300.0	Primary Inorganic Contaminants	NELAP	2/1/2007
Nitrate as N	EPA 300.0	Primary Inorganic Contaminants	NELAP	2/1/2007
Nitrite as N	EPA 300.0	Primary Inorganic Contaminants	NELAP	2/1/2007
Odor	SM 2150 B	Secondary Inorganic Contaminants	NELAP	4/1/2009
Orthophosphate as P	EPA 300.0	Primary Inorganic Contaminants	NELAP	2/1/2007
pH	EPA 150.1	Primary Inorganic Contaminants	NELAP	2/1/2007
pH	SM 4500-H+-B	Secondary Inorganic Contaminants	NELAP	4/1/2009
Residue-filterable (TDS)	EPA 160.1	Secondary Inorganic Contaminants	NELAP	4/1/2009
Residue-filterable (TDS)	SM 2540 C	Secondary Inorganic Contaminants	NELAP	4/1/2009
Sulfate	EPA 300.0	Primary Inorganic Contaminants	NELAP	2/1/2007
Surfactants - MBAS	EPA 425.1	Secondary Inorganic Contaminants	NELAP	4/1/2009
Surfactants - MBAS	SM 5540 C	Secondary Inorganic Contaminants	NELAP	4/1/2009
Total coliforms	COLITAG	Microbiology	NELAP	2/1/2007
Total coliforms	SM 9222 B	Microbiology	NELAP	2/1/2007
Total nitrate-nitrite	EPA 300.0	Primary Inorganic Contaminants	NELAP	2/1/2007

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 5/5/2009

Expiration Date: 6/30/2009

COPY



Laboratory Scope of Accreditation

Attachment to Certificate #: E82574-22, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E82574

EPA Lab Code: FL00949

(904) 363-9350

E82574

Advanced Environmental Laboratories, Inc.

6601 Southpoint Parkway

Jacksonville, FL 32216

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
1,1,1-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
1,1,2-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
1,1-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
1,2,4-Trichlorobenzene	EPA 524.2	Group II Unregulated Contaminants	NELAP	1/21/2005
1,2-Dibromo-3-chloropropane (DBCP)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/4/2002
1,2-Dibromoethane (EDB, Ethylene dibromide)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/4/2002
1,2-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
1,2-Dichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
1,2-Dichloropropane	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
1,4-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
2,4-D	EPA 515.3	Synthetic Organic Contaminants	NELAP	3/29/2006
Alachlor	EPA 525.2	Synthetic Organic Contaminants	NELAP	3/24/2005
Alkalinity as CaCO3	EPA 310.1	Primary Inorganic Contaminants	NELAP	12/8/2006
Alkalinity as CaCO3	SM 2320 B	Primary Inorganic Contaminants	NELAP	1/21/2005
Aluminum	EPA 200.7	Secondary Inorganic Contaminants	NELAP	4/4/2002
Aluminum	EPA 200.8	Secondary Inorganic Contaminants	NELAP	12/8/2006
Antimony	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Arsenic	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Arsenic	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Atrazine	EPA 525.2	Synthetic Organic Contaminants	NELAP	3/24/2005
Barium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Barium	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Benzene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Benzo(a)pyrene	EPA 525.2	Synthetic Organic Contaminants	NELAP	1/21/2005
Beryllium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Beryllium	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
bis(2-Ethylhexyl) phthalate (DEHP)	EPA 525.2	Synthetic Organic Contaminants	NELAP	1/21/2005
Boron	AEL MET-017, Revision No. 03	Secondary Inorganic Contaminants	NELAP	12/8/2006
Boron	EPA 200.7	Secondary Inorganic Contaminants	NELAP	12/8/2006
Bromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	1/21/2005
Bromochloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	1/21/2005
Bromodichloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	1/21/2005
Bromoform	EPA 524.2	Group II Unregulated Contaminants	NELAP	1/21/2005
Cadmium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Cadmium	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Calcium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 9/16/2008

Expiration Date: 6/30/2009

COPY

Charlie Crist
Governor



Ana M. Valente-Ros, M.D., M.P.H.
State Surgeon General

Laboratory Scope of Accreditation

Page 2 of 31

Attachment to Certificate #: E82574-22, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E82574

EPA Lab Code:

FL00949

(904) 363-9350

E82574

Advanced Environmental Laboratories, Inc.
6601 Southpoint Parkway
Jacksonville, FL 32216

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Carbofuran (Furadan)	EPA 531.1	Synthetic Organic Contaminants	NELAP	4/19/2005
Carbon tetrachloride	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Chlordane (tech.)	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Chloride	SM 4500 Cl-E	Secondary Inorganic Contaminants	NELAP	2/13/2003
Chloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	1/21/2005
Chlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Chloroform	EPA 524.2	Group II Unregulated Contaminants	NELAP	1/21/2005
Chromium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Chromium	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
cis-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Color	EPA 110.2	Secondary Inorganic Contaminants	NELAP	2/13/2003
Color	SM 2120 B	Secondary Inorganic Contaminants	NELAP	4/27/2007
Conductivity	EPA 120.1	Primary Inorganic Contaminants	NELAP	4/30/2008
Conductivity	SM 2510 B	Primary Inorganic Contaminants	NELAP	4/30/2008
Copper	EPA 200.7	Primary Inorganic Contaminants, Secondary Inorganic Contaminants	NELAP	4/4/2002
Copper	EPA 200.8	Primary Inorganic Contaminants, Secondary Inorganic Contaminants	NELAP	12/8/2006
Dalapon	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
Di(2-ethylhexyl)adipate	EPA 525.2	Synthetic Organic Contaminants	NELAP	1/21/2005
Dibromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	1/21/2005
Dibromochloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	1/21/2005
Dichloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	3/24/2005
Dichloromethane (DCM, Methylene chloride)	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Dinoseb (2-sec-butyl-4,6-dinitrophenol, DNBP)	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
Diquat	EPA 349.2	Synthetic Organic Contaminants	NELAP	4/19/2005
Endothal	EPA 548.1	Synthetic Organic Contaminants	NELAP	1/21/2005
Endrin	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Escherichia coli	SM 9223 B	Microbiology	NELAP	9/5/2002
Ethylbenzene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
gamma-BHC (Lindane, gamma-Hexachlorocyclohexane)	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Glyphosate	EPA 547	Synthetic Organic Contaminants	NELAP	4/30/2008
Hardness	SM 2340 B	Secondary Inorganic Contaminants	NELAP	12/8/2006
Heptachlor	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Heptachlor epoxide	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 9/16/2008

Expiration Date: 6/30/2009

COPY

Charlie Crist
Governor



Arne M. Villanueva, M.D., M.P.H.
State Surgeon General

Laboratory Scope of Accreditation

Page 2 of 31

Attachment to Certificate #: E82574-22, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E82574

EPA Lab Code: FL00949

(904) 363-9350

E82574

Advanced Environmental Laboratories, Inc.
6601 Southpoint Parkway
Jacksonville, FL 32216

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Carbofuran (Furadan)	EPA 531.1	Synthetic Organic Contaminants	NELAP	4/19/2005
Carbon tetrachloride	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Chlordane (tech.)	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Chloride	SM 4500 Cl- E	Secondary Inorganic Contaminants	NELAP	2/13/2003
Chloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	1/21/2005
Chlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Chloroform	EPA 524.2	Group II Unregulated Contaminants	NELAP	1/21/2005
Chromium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Chromium	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
cis-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Color	EPA 110.2	Secondary Inorganic Contaminants	NELAP	2/13/2003
Color	SM 2120 B	Secondary Inorganic Contaminants	NELAP	4/27/2007
Conductivity	EPA 120.1	Primary Inorganic Contaminants	NELAP	4/30/2008
Conductivity	SM 2510 B	Primary Inorganic Contaminants	NELAP	4/30/2008
Copper	EPA 200.7	Primary Inorganic Contaminants, Secondary Inorganic Contaminants	NELAP	4/4/2002
Copper	EPA 200.8	Primary Inorganic Contaminants, Secondary Inorganic Contaminants	NELAP	12/8/2006
Dalepon	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
Di(2-ethylhexyl)adipate	EPA 525.2	Synthetic Organic Contaminants	NELAP	1/21/2005
Dibromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	1/21/2005
Dibromochloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	1/21/2005
Dichloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	3/24/2005
Dichloromethane (DCM, Methylene chloride)	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Dinoseb (2-sec-butyl-4,6-dinitrophenol, DNBP)	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
Diquat	EPA 549.2	Synthetic Organic Contaminants	NELAP	4/19/2005
Endothall	EPA 548.1	Synthetic Organic Contaminants	NELAP	1/21/2005
Endrin	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Escherichia coli	SM 9223 B	Microbiology	NELAP	9/3/2002
Ethylbenzene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
gamma-BHC (Lindane, gamma-Hexachlorocyclohexane)	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Glyphosate	EPA 547	Synthetic Organic Contaminants	NELAP	4/30/2008
Hardness	SM 2340 B	Secondary Inorganic Contaminants	NELAP	12/8/2006
Heptachlor	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Heptachlor epoxide	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 9/16/2008

Expiration Date: 6/30/2009

COPY



Laboratory Scope of Accreditation

Attachment to Certificate #: E82574-22, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E82574

EPA Lab Code: FL00949

(904) 363-9350

E82574

Advanced Environmental Laboratories, Inc.
6601 Southpoint Parkway
Jacksonville, FL 32216

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Heterotrophic plate count	SM 9215 B	Microbiology	NELAP	1/21/2005
Hexachlorobenzene	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Hexachlorocyclopentadiene	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Iron	AEL MET-017, Revision No. 03	Secondary Inorganic Contaminants	NELAP	12/8/2006
Iron	EPA 200.7	Secondary Inorganic Contaminants	NELAP	4/4/2002
Lead	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Magnesium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Manganese	EPA 200.7	Secondary Inorganic Contaminants	NELAP	4/4/2002
Manganese	EPA 200.8	Secondary Inorganic Contaminants	NELAP	12/8/2006
Mercury	EPA 245.1	Primary Inorganic Contaminants	NELAP	4/4/2002
Mercury	SM 3112 B	Primary Inorganic Contaminants	NELAP	4/4/2002
Methoxychlor	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Molybdenum	EPA 200.7	Secondary Inorganic Contaminants	NELAP	12/8/2006
Molybdenum	EPA 200.8	Secondary Inorganic Contaminants	NELAP	4/27/2007
Nickel	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Nickel	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Nitrate	SM 4500-NO3 F	Primary Inorganic Contaminants	NELAP	2/13/2003
Nitrate-nitrite	SM 4500-NO3 F	Primary Inorganic Contaminants	NELAP	2/13/2003
Nitrite	SM 4500-NO3 F	Primary Inorganic Contaminants	NELAP	2/13/2003
Nitrite as N	SM 4500-NO2 B	Primary Inorganic Contaminants	NELAP	1/21/2005
Odor	SM 2150 B	Secondary Inorganic Contaminants	NELAP	2/13/2003
Orthophosphate as P	EPA 365.1	Primary Inorganic Contaminants	NELAP	2/13/2003
Orthophosphate as P	SM 4500-P E	Primary Inorganic Contaminants	NELAP	1/21/2005
Oxamyl	EPA 531.1	Synthetic Organic Contaminants	NELAP	4/19/2005
PCBs	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
Pentachlorophenol	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
pH	EPA 150.1	Primary Inorganic Contaminants, Secondary Inorganic Contaminants	NELAP	4/4/2002
pH	SM 4500-H+-B	Secondary Inorganic Contaminants	NELAP	2/28/2008
Picloram	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
Potassium	EPA 200.7	Secondary Inorganic Contaminants	NELAP	1/21/2005
Residue-filterable (TDS)	EPA 160.1	Secondary Inorganic Contaminants	NELAP	4/4/2002
Selenium	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Silica as SiO2	EPA 200.7	Primary Inorganic Contaminants	NELAP	1/21/2005
Silver	EPA 200.7	Secondary Inorganic Contaminants	NELAP	4/4/2002
Silver	EPA 200.8	Secondary Inorganic Contaminants	NELAP	12/8/2006

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 9/16/2008

Expiration Date: 6/30/2009

COPY

Charlie Crist
Governor



Ana M. Viamonte Res. M.D., M.P.H.
State Surgeon General

Laboratory Scope of Accreditation

Page 4 of 31

Attachment to Certificate #: E82574-22, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E82574

EPA Lab Code: FL00949

(904) 363-9350


E82574

Advanced Environmental Laboratories, Inc.
6601 Southpoint Parkway
Jacksonville, FL 32216

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Silvex (2,4,5-TP)	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
Simazine	EPA 525.2	Synthetic Organic Contaminants	NELAP	3/24/2005
Sodium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Strontium	AEL MET-017, Revision	Secondary Inorganic Contaminants	NELAP	12/8/2006

COPY



Laboratory Scope of Accreditation

Attachment to Certificate #: E82574-22, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: **E82574** EPA Lab Code: **FL00949** (904) 363-9350

E82574
Advanced Environmental Laboratories, Inc.
6601 Southpoint Parkway
Jacksonville, FL 32216

Matrix: **Drinking Water**

Analyte	Method/Tech	Category	Certification Type	Effective Date
Silvex (2,4,5-TP)	EPA 515.3	Synthetic Organic Contaminants	NELAP	1/21/2005
Simazine	EPA 525.2	Synthetic Organic Contaminants	NELAP	3/24/2005
Sodium	EPA 200.7	Primary Inorganic Contaminants	NELAP	4/4/2002
Strontium	AEL MET-017, Revision No. 03	Secondary Inorganic Contaminants	NELAP	12/8/2006
Styrene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Sulfate	EPA 375.4	Secondary Inorganic Contaminants	NELAP	2/13/2003
Sulfate	SM 4500 SO4-F	Secondary Inorganic Contaminants	NELAP	2/28/2008
Surfactants - MBAS	EPA 425.1	Secondary Inorganic Contaminants	NELAP	1/21/2005
Surfactants - MBAS	SM 5340 C	Secondary Inorganic Contaminants	NELAP	4/27/2007
Tetrachloroethylene (Perchloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Thallium	EPA 200.8	Primary Inorganic Contaminants	NELAP	12/8/2006
Thorium	EPA 200.8	Secondary Inorganic Contaminants	NELAP	12/8/2006
Tin	AEL MET-017, Revision No. 03	Secondary Inorganic Contaminants	NELAP	12/8/2006
Titanium	AEL MET-017, Revision No. 03	Secondary Inorganic Contaminants	NELAP	12/8/2006
Toluene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Total coliforms	SM 9222 B	Microbiology	NELAP	4/4/2002
Total coliforms	SM 9223 B	Microbiology	NELAP	9/5/2002
Total dissolved solids	SM 2540 C	Secondary Inorganic Contaminants	NELAP	2/28/2008
Total haloacetic acids	EPA 552.2	Synthetic Organic Contaminants	NELAP	1/21/2005
Total trihalomethanes	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Toxaphene (Chlorinated camphene)	EPA 508	Synthetic Organic Contaminants	NELAP	3/24/2005
trans-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Trichloroacetic acid	EPA 352.2	Group I Unregulated Contaminants	NELAP	1/21/2005
Trichloroethene (Trichloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Turbidity	EPA 180.1	Secondary Inorganic Contaminants	NELAP	7/17/2002
Uranium	EPA 200.8	Radiochemistry	NELAP	7/1/2007
Vinyl chloride	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Xylene (total)	EPA 524.2	Other Regulated Contaminants	NELAP	1/21/2005
Zinc	EPA 200.7	Secondary Inorganic Contaminants	NELAP	4/4/2002
Zinc	EPA 200.8	Secondary Inorganic Contaminants	NELAP	12/8/2006

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 9/16/2008

Expiration Date: 6/30/2009

COPY

Charlie Crist
Governor

Ana M. Viamonte, R.S., M.D., M.P.H.
State Surgeon General

Laboratory Scope of Accreditation

Page 1 of 4

Attachment to Certificate #: E84589-06, expiration date June 30, 2009. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84589

EPA Lab Code: FT.01092

(813) 630-9616

E84589

Advanced Environmental Laboratories, Inc. - Tampa
9610 Princess Palm Avenue
Tampa, FL 33619

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Alkalinity as CaCO ₃	SM 2320 B	Primary Inorganic Contaminants	NELAP	10/11/2002
Amenable cyanide	SM 4500-CN G	Primary Inorganic Contaminants	NELAP	10/11/2002
Bromate	EPA 300.0	Primary Inorganic Contaminants	NELAP	2/10/2005
Bromate	EPA 300.1	Primary Inorganic Contaminants	NELAP	2/10/2005
Bromide	EPA 300.0	Primary Inorganic Contaminants	NELAP	10/11/2002
Chloride	EPA 300.0	Secondary Inorganic Contaminants	NELAP	10/11/2002
Chloride	SM 4500 Cl- E	Secondary Inorganic Contaminants	NELAP	10/11/2002
Chlorite	EPA 300.0	Primary Inorganic Contaminants	NELAP	8/20/2003
Color	EPA 110.2	Secondary Inorganic Contaminants	NELAP	10/11/2002
Conductivity	SM 2510 B	Primary Inorganic Contaminants	NELAP	10/11/2002
Cyanide	SM 4500-CN E	Primary Inorganic Contaminants	NELAP	10/11/2002
Escherichia coli	SM 9223 B	Microbiology	NELAP	2/14/2003
Fluoride	EPA 300.0	Primary Inorganic Contaminants	NELAP	10/11/2002
Fluoride	SM 4500 F-C	Primary Inorganic Contaminants, Secondary Inorganic Contaminants	NELAP	10/11/2002
Heterotrophic plate count	SM 9215 B	Microbiology	NELAP	10/11/2002
Nitrate	EPA 300.0	Primary Inorganic Contaminants	NELAP	10/11/2002
Nitrate	SM 4500-NO3 F	Primary Inorganic Contaminants	NELAP	10/11/2002
Nitrate-nitrite	EPA 300.0	Primary Inorganic Contaminants	NELAP	10/11/2002
Nitrite	EPA 300.0	Primary Inorganic Contaminants	NELAP	10/11/2002
Nitrite	SM 4500-NO3 F	Primary Inorganic Contaminants	NELAP	10/11/2002
Odor	SM 2150 B	Secondary Inorganic Contaminants	NELAP	10/11/2002
Orthophosphate as P	EPA 300.0	Primary Inorganic Contaminants	NELAP	10/11/2002
Orthophosphate as P	EPA 365.1	Primary Inorganic Contaminants	NELAP	10/11/2002
pH	EPA 150.1	Secondary Inorganic Contaminants	NELAP	10/11/2002
Sulfate	EPA 300.0	Primary Inorganic Contaminants	NELAP	10/11/2002
Sulfate	EPA 375.4	Secondary Inorganic Contaminants	NELAP	10/11/2002
Surfactants - MBAS	EPA 425.1	Secondary Inorganic Contaminants	NELAP	10/11/2002
Total coliforms	SM 9222 B	Microbiology	NELAP	2/14/2003
Total coliforms	SM 9223 B	Microbiology	NELAP	2/14/2003
Total dissolved solids	EPA 160.1	Secondary Inorganic Contaminants	NELAP	10/11/2002
Total nitrate-nitrite	SM 4500-NO3 F	Primary Inorganic Contaminants	NELAP	10/11/2002
Total organic carbon	SM 5310B	Primary Inorganic Contaminants	NELAP	10/11/2002
Turbidity	EPA 180.1	Secondary Inorganic Contaminants	NELAP	10/11/2002

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 7/1/2008

Expiration Date: 6/30/2009

COPY